

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad (GPCB ID: 14438)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	01/12/2021, 02/12/2021, 03/12/2021, 06/12/2021, 08/12/2021, 15/12/2021, 21/12/2021	23	Nil	pH	7.71	pH	7.69	pH, Flow Meter, TOC, COD, BOD, TSS	Storage 23,000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1282	COD	164		
	BOD	700 mg/L	BOD	30 mg/L				BOD	319	BOD	23		
	SS	300 mg/L	SS	100 mg/L				SS	380	SS	42		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	25.93	NH ₃ -N	9.07		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.79	Phenolic Compounds	0.68		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad (GPCB ID: 12890)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	10/12/2021, 16/12/2021	1.1	Nil	pH	6.86	pH	6.135	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage 1165 MT,
	COD	2000 mg/L	COD	250 mg/L				COD	745	COD	458.5		
	BOD	700 mg/L	BOD	30 mg/L				BOD	149.5	BOD	51		
	SS	300 mg/L	SS	100 mg/L				SS	209	SS	159		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44.355	NH ₃ -N	16.495		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.665	Phenolic Compounds	0.31		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad (GPCB ID: 11536)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	10/12/2021, 16/12/2021	0.7	Nil	pH	7.02	pH	6.655	Flow Meter	Storage 1000-1100 MT
	COD	2000 mg/L	COD	250 mg/L				COD	389	COD	161.5		
	BOD	700 mg/L	BOD	30 mg/L				BOD	89	BOD	32		
	SS	300 mg/L	SS	100 mg/L				SS	370	SS	74		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	79.745	NH ₃ -N	96.405		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.975	Phenolic Compounds	0.365		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad (GPCB ID: 12891)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	10/12/2021, 16/12/2021	0.8	Nil	pH	6.86	pH	7.20	-	Storage 7 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1605	COD	588		
	BOD	700 mg/L	BOD	30 mg/L				BOD	400	BOD	153		
	SS	300 mg/L	SS	100 mg/L				SS	1404	SS	108		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	49.28	NH ₃ -N	46.70		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.42	Phenolic Compounds	0.30		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad (GPCB ID: 12718)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	04/12/2021, 16/12/2021	4.5	Nil	pH	7.198	pH	7.325	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	3051.333	COD	324		
	BOD	700 mg/L	BOD	30 mg/L				BOD	798.166	BOD	59.5		
	SS	300 mg/L	SS	100 mg/L				SS	902	SS	77		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58.166	NH ₃ -N	35.645		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.575	Phenolic Compounds	0.335		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad (GPCB ID: 12720)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.1	pH	6.5-8.5	pH	6.5-8.5	10/12/2021, 16/12/2021	0.020	Nil	pH	7.395	pH	7.395	-	Storage 20 MT
	COD	2000 mg/L	COD	250 mg/L				COD	577.5	COD	341.5		
	BOD	700 mg/L	BOD	30 mg/L				BOD	140	BOD	67		
	SS	300 mg/L	SS	100 mg/L				SS	71	SS	350		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	15.875	NH ₃ -N	9.66		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.565	Phenolic Compounds	0.45		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad (GPCB ID: 34244)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	10/12/2021, 14/12/2021, 16/12/2021	100	Nil	pH	7.67	pH	7.78	-	Storage 11,700 MT
	COD	1200 mg/L	COD	250 mg/L				COD	135	COD	123		
	BOD	500 mg/L	BOD	30 mg/L				BOD	29	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	36	SS	30		
	NH ₃ -N	50 mg/L	NH ₃ -N	-				NH ₃ -N	28.78	NH ₃ -N	30.575		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.36	Phenolic Compounds	0.335		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad (GPCB ID: 13515)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Not visited in this month	0.10	Nil	pH	-	pH	-	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad (GPCB ID: 14802)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	03/12/2021	1.8	Nil	pH	6.91	pH	6.64	pH, TOC meter	Storage 50 MT
	COD	850 mg/L	COD					COD	823	COD	30		
	BOD (5 days at 20°C)	400 mg/L	BOD (5 days at 20°C)					BOD (3 days at 27°C)	221	BOD (3 days at 27°C)	4.80		
	SS	300 mg/L	SS					SS	108	SS	6		
	NH ₃ -N	50 mg/L	NH ₃ -N					NH ₃ -N	19.20	NH ₃ -N	7.50		
	Phenolic Compounds	0.3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad (GPCB ID: 10653)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6-10.5	03/12/2021	0.3	Nil	pH	-	pH	7.57	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	668		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	227		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	268		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	15.46		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal SudhikaranSahakariMandali Ltd, Bavla, Ahmedabad (GPCB ID: 14686)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6 to 10.5	03/12/2021	4	Nil	pH	-	pH	7.82		-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	136		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	26		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	38		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	11.37		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara (GPCB ID: 22336)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	08/12/2021	6.4	Nil	pH	6.71	pH	7.41	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	827	COD	216		
	BOD	500 mg/L	BOD	100 mg/L				BOD	150	BOD	38		
	SS	600 mg/L	SS	100 mg/L				SS	68	SS	60		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	1.57	NH ₃ -N	4.93		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.32	Phenolic Compounds	0.16		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara (GPCB ID: 21878)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	20/12/2021	2.2	Nil	pH	7.21	pH	6.95	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	Storage 100 MT , Disposal 16.905 MT
	COD	2000 mg/L	COD	250 mg/L				COD	800	COD	223		
	BOD	500 mg/L	BOD	100 mg/L				BOD	185	BOD	45		
	SS	600 mg/L	SS	100 mg/L				SS	134	SS	88		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	30.86	NH ₃ -N	6.38		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.18	Phenolic Compounds	0.1		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch (GPCB ID: 15074)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	06/12/2021	2.31	Nil	pH	7.625	pH	7.75	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	3636.5	COD	512		
	BOD	3600 mg/L	BOD	200 mg/L				BOD (3 days at 27°C)	808	BOD (3 days at 27°C)	26		
	SS	-	SS	150 mg/L				SS	295	SS	46		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	293.44	NH ₃ -N	40.88		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	3.81	Phenolic Compounds	0.11		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar (GPCB ID: 27833)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	01/12/2021	31.92	Nil	pH	7.32	pH	7.1	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	766	COD	570		
	BOD	200 mg/L	BOD	100 mg/L				BOD	180	BOD	102		
	SS	150 mg/L	SS	100 mg/L				SS	221	SS	80		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58.52	NH ₃ -N	104.16		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.545	Phenolic Compounds	0.85		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch (GPCB ID: 15460)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	04/12/2021	0.45	Nil	pH	7.47	pH	7.84	pH, Flow Meter, TOC	Storage 125 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2495	COD	656		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	598	BOD	142		
	SS	-	SS	150 mg/L				SS	608	SS	58		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	14	NH ₃ -N	8.4		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	2.96	Phenolic Compounds	0.50		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat (GPCB ID: 20721)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	07/12/2021	0.236	Nil	pH	7.79	pH	7.82	pH, TOC, TSS, Flow meter	Storage 1297.65 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1159	COD	170		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	290	BOD	24		
	SS	300 mg/L	SS	100 mg/L				SS	298	SS	68		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	80.1	NH ₃ -N	49		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.95	Phenolic Compounds	0.66		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat (GPCB ID: 21204)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	6.5 - 8.5	pH	6.5-8.5	07/12/2021	32.83	Nil	pH	7.35	pH	7.71	pH, Flow Meter, TOC	-
	COD	1000 mg/L	COD	250 mg/L				COD	708	COD	246		
	BOD	400 mg/L	BOD	30 mg/L				BOD	172	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	244	SS	46		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	19.8	NH ₃ -N	14.3		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.51	Phenolic Compounds	0.39		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat (GPCB ID: 21044)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	07/12/2021	98	Nil	pH	7.32	pH	7.92	pH, Flow Meter, COD, BOD, TSS	Storage 531.261 MT , Disposal 290.06 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1051	COD	248		
	BOD	400 mg/L	BOD	30 mg/L				BOD	258	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	128	SS	72		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	21.3	NH ₃ -N	15.4		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.52	Phenolic Compounds	0.36		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat (GPCB ID: 11142)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	07/12/2021	81.5	Nil	pH	7.30	pH	7.66	pH, Flow Meter, TOC, COD	Storage 1500 MT, Disposal 364.82 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1008	COD	172		
	BOD	400 mg/L	BOD	30 mg/L				BOD	260	BOD	20		
	SS	300 mg/L	SS	100 mg/L				SS	240	SS	64		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	13.7	NH ₃ -N	8.7		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.52	Phenolic Compounds	0.33		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL (GPCB ID: 41302)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25	pH	6.5-8.5	pH	6.5-8.5	08/12/2021	0.1	Nil	pH	-	pH	7.82	-	-
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	18		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	<5		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	10		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	5.3		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat (GPCB ID: 31233)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal		
60	pH	6.5-8.5	pH	6.5 to 8.5	07/12/2021	29	Nil	pH	6.47	pH	7.54	pH, Flow Meter, COD Meter including TOC	Storage 1200 MT, Disposal 22.09 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1018	COD	241.6		
	BOD	400 mg/L	BOD	30 mg/L				BOD	285	BOD	29		
	SS	300 mg/L	SS	100 mg/L				SS	296	SS	92		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	22.7	NH ₃ -N	18.2		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.96	Phenolic Compounds	0.67		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat (GPCB ID:34209)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	6.5 -7.5	pH	7 to 8	08/12/2021	1.39	Nil	pH	-	pH	7.34	pH, Flow Meter	Storage 7 MT
	COD	500 mg/L	COD	<100 mg/L				COD	-	COD	94		
	BOD	200 mg/L	BOD	<30 mg/L				BOD	-	BOD	22		
	SS	100 mg/L	SS	<60 mg/L				SS	-	SS	8		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	8.52		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat (GPCB ID: 10462)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	07/12/2021	25	Nil	pH	8.09	pH	7.39	pH, Flow meter, COD, BOD, TSS	Storage 700 MT
	COD	1000 mg/L	COD	250 mg/L				COD	828	COD	144		
	BOD	400 mg/L	BOD	30 mg/L				BOD	195	BOD	19		
	SS	300 mg/L	SS	<60 mg/L				SS	108	SS	42		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	18.8	NH ₃ -N	12.6		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.41	Phenolic Compounds	0.21		

Vapi Green Enviro Ltd(VGEL,Vapi) (OldName-Vapi Waste & Effluent Management Co.Ltd) (GPCB ID: 24764)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	pH.	6.5-8.5	04/12/2021, 16/12/2021	54	Nil	pH	7.71	pH	7.26	pH, Flow Meter, TOC & DO Meter	Storage 12,750 MT
	COD	1000 mg/L	COD	250 mg/L				COD	971.5	COD	304		
	BOD	400 mg/L	BOD	30 mg/L				BOD	204	BOD	37		
	SS	300 mg/L	SS	100 mg/L				SS	304	SS	109		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	91.28	NH ₃ -N	72.24		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.44	Phenolic Compounds	0.515		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam (GPCB ID: 43677)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	07/12/2021, 16/12/2021, 30/12/2021	9	Nil	pH	7.356	pH	7.266	Flow Meter, TOC meter	Storage 850 MT
	COD	1000 mg/L	COD	250 mg/L				COD	720	COD	597.66		
	BOD	400 mg/L	BOD	30 mg/L				BOD (3 days at 27°C)	145.66	BOD (3 days at 27°C)	84.66		
	SS	300 mg/L	SS	100 mg/L				SS	309	SS	480		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	34.16	NH ₃ -N	28		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.966	Phenolic Compounds	0.466		

M/s. Veraval Industries Association, Veraval, Junagadh (GPCB ID: 17197)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	5.5 to 9.5	02/12/2021,	5	Nil	pH	8.13	pH	7.85		Storage 2.839 MT
	COD	3500 mg/L	COD	250 mg/L				COD	1466	COD	1224		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	459	BOD	393		
	SS	200 mg/L	SS	100 mg/L				SS	512	SS	328		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	224	NH ₃ -N	112		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing GhatSuddhikaranYojana Pvt. Ltd., Bhatgam,Rajkot (GPCB ID: 23674)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6-9	13/12/2021	10	Nil	pH	10.82	pH	9.03	pH, Flow meter, SS, Color, MLSS, COD	Storage 1020 MT
	COD	1000 mg/L	COD	250 mg/L				COD	560	COD	418		
	BOD	350 mg/L	BOD	100 mg/L				BOD	182	BOD	133		
	SS	2000 mg/L	SS	100 mg/L				SS	234	SS	26		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	19.6	NH ₃ -N	7.0		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.76	Phenolic Compounds	BDL		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot (GPCB ID: 19722)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
7	pH	10.5-12.0	pH	6.5-9	07/12/2021	7.00	Nil	pH	9.75	pH	7.93	pH, Flow meter	Storage 508 MT
	COD	1000 mg/L	COD	250 mg/L				COD	3517.5	COD	669		
	BOD	350 mg/L	BOD	100 mg/L				BOD	1089	BOD	212		
	SS	2000 mg/L	SS	100 mg/L				SS	345	SS	82		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12.6	NH ₃ -N	9.8		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot (GPCB ID: 20111)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	21/12/2021	0.09	Nil	pH	7.40	pH	7.67	pH, Flow Meter	Storage 22.05 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1104	COD	554		
	BOD	350 mg/L	BOD	100 mg/L				BOD	343	BOD	187		
	SS	2000 mg/L	SS	100 mg/L				SS	208	SS	12		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	28	NH ₃ -N	12.6		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	0.26		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot (GPCB ID: 19690)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.009	pH	Up to 5	pH	6.5 to 8.5	07/12/2021	0.013	Nil	pH	<2	pH	7.48		-
	COD	250 mg/L	COD	100 mg/L				COD	154	COD	42.2		
	BOD	100 mg/L	BOD	30 mg/L				BOD	51	BOD	13		
	SS	250 mg/L	SS	100 mg/L				SS	142	SS	14		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar (GPCB ID: 28811)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.04	pH	6.5 to 8.5	pH	6.5 to 8.5	04/12/2021	0.35	Nil	pH	6.69	pH	7.51		Storage 80 MT
	COD	2000 mg/L	COD	250 mg/L				COD	945	COD	245		
	BOD	700 mg/L	BOD	100 mg/L				BOD	282	BOD	53		
	SS	-	SS	100 mg/L				SS	304	SS	48		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	57.51	NH ₃ -N	50.18		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.42	Phenolic Compounds	0.24		

M/s CETP of Dahej Industrial Estate (GPCB ID: 50837)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9.0	10/12/2021	0.66	Nil	pH	-	pH	7.6	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	807		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	184		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	52		
	NH ₃ -N	150 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	124.88		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	1.11		

M/s Mangrol Enviro Protection LLP (MEPL) (GPCB ID: 72852)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5-7.5	pH	6.5-8.5	08/12/2021	1	Nil	pH	8.06	pH	8.18	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	4000 mg/L	COD	100 mg/L				COD	279	COD	90		
	BOD	2500 mg/L	BOD	30 mg/L				BOD	64	BOD	24		
	SS	500 mg/L	SS	<60 mg/L				SS	126	SS	52		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	3.1	NH ₃ -N	2.24		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s Hojiwala Infrastructure Limited (GPCB ID: 47794)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10	pH	6.5-8.5	pH	6.5-8.5	07/12/2021	10	Nil	pH	-	pH	7.67		Storage 3 MT
	COD	400	COD	<40				COD	-	COD	12		
	BOD	200	BOD	<30				BOD	-	BOD	<5		
	SS	200	SS	<10				SS	-	SS	4		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	0.28		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		