

**M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value for the month of January-2021  (04/01/2021 & 12/01/2021)	23	Nil	pH	7.89	pH	7.76	pH, Flow Meter, TOC, COD, BOD, TSS	Storage 1000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	2555	COD	358		
	BOD	700 mg/L	BOD	30 mg/L				BOD	285	BOD	26		
	SS	300 mg/L	SS	100 mg/L				SS	148	SS	128		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	48.58	NH <sub>3</sub> -N	4.78		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.21	Phenolic Compounds	0.63		

**M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	Average value for the month of January-2021 (11/01/2021 & 25/01/2021)	1.1	Nil	pH	7.90	pH	8.03	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage 60 MT
	COD	2000 mg/L	COD	250 mg/L				COD	2384	COD	185		
	BOD	700 mg/L	BOD	30 mg/L				BOD	386	BOD	23		
	SS	300 mg/L	SS	100 mg/L				SS	168	SS	76		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	30.24	NH <sub>3</sub> -N	7.95		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.29	Phenolic Compounds	0.17		

**M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	11/01/2021	0.7	Nil	pH	7.31	pH	7.55	Flow Meter	Storage 1300 MT
	COD	2000 mg/L	COD	250 mg/L				COD	594	COD	223		
	BOD	700 mg/L	BOD	30 mg/L				BOD	106	BOD	34		
	SS	300 mg/L	SS	100 mg/L				SS	96	SS	84		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	51.07	NH <sub>3</sub> -N	26.77		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.33	Phenolic Compounds	0.17		

**M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value for the month of January-2021 (11/01/2021 & 25/01/2021)	0.8	Nil	pH	6.86	pH	7.51	-	Storage 10 MT
	COD	750 mg/L	COD	250 mg/L				COD	828	COD	457		
	BOD	250 mg/L	BOD	30 mg/L				BOD	142	BOD	48		
	SS	300 mg/L	SS	100 mg/L				SS	78	SS	56		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	51.07	NH <sub>3</sub> -N	21.28		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.40	Phenolic Compounds	0.3		

**M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	11/01/2021	4.5	Nil	pH	7.80	pH	7.94	-	Storage 1500 MT
	COD	2000 mg/L	COD	250 mg/L				COD	3889	COD	340		
	BOD	700 mg/L	BOD	30 mg/L				BOD	687	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	382	SS	82		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	17.25	NH <sub>3</sub> -N	19.38		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.14	<b>Phenolic Compounds</b>	0.44		

**M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.045	pH	6.5-8.5	pH	6.5-8.5	Not inspected for the month of January-2021	0.020	Nil	pH	-	pH		-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Not inspected for the month of January-2021	100	Nil	pH	-	pH	-	-	-
	COD	1200 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Not inspected for the month of January-2021	0.10	Nil	pH	-	pH	-	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		



**M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	06/01/2021	1.8	Nil	pH	7.90	pH	7.52	pH, TOC meter	Storage 8 MT
	COD	850 mg/L	COD					COD	710	COD	33		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	206	BOD (3 days at 27°C)	<5		
	SS	300 mg/L	SS					SS	26	SS	8		
	NH <sub>3</sub> -N	<10 mg/L	NH <sub>3</sub> -N					NH <sub>3</sub> -N	10.92	NH <sub>3</sub> -N	1.55		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.19	Phenolic Compounds	BDL		

**M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	13/01/2021	0.3	Nil	pH	-	pH	8.09	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	1629		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	362		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	158		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	11.87		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Vinayak Jal SudhikaranSahakariMandali Ltd, Bavla, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	13/01/2021	4	Nil	pH	-	pH	8.34		-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	368		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	90		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	48		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	3.42		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	22/01/2021	6.4	Nil	pH	-	pH	6.73	pH, COD, BOD, TSS, NH <sub>3</sub> -N, Color, TOC, Temperature	Storage 4 MT
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	217		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	45		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	40		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	1.23		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.3		

**M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	12/01/2021	2.2	Nil	pH	-	pH	7.50	pH, Flow Meter, TOC, TSS, Color, NH <sub>3</sub> -N	Storage 200 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	245		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	51		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	86		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	3.81		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.16		

**M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	02/01/2021	2.31	Nil	pH	7.23	pH	7.26	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	4332	COD	974		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	787	BOD (3 days at 27°C)	23		
	SS	-	SS	150 mg/L				SS	454	SS	90		
	NH <sub>3</sub> -N	100 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	43.68	NH <sub>3</sub> -N	31.36		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	2.78	Phenolic Compounds	0.23		

**M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	04/01/2021	31.92	Nil	pH	7.68	pH	7.14	pH, Flow Meter, TOC, TSS	Storage 500 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1849	COD	808		
	BOD	200 mg/L	BOD	100 mg/L				BOD	197	BOD	20		
	SS	150 mg/L	SS	100 mg/L				SS	1444	SS	144		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	78.96	NH <sub>3</sub> -N	122.08		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	4.80	Phenolic Compounds	0.81		

**M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	Average value for the month of January-2021 (04/01/2021 & 18/01/2021)	0.45	Nil	pH	7.03	pH	8.00	pH, Flow Meter, TOC	-
	COD	10000 mg/L	COD	1000 mg/L				COD	4542	COD	578		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	588	BOD	32		
	SS	-	SS	150 mg/L				SS	4456	SS	194		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	140	NH <sub>3</sub> -N	28		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.70	Phenolic Compounds	0.45		



**M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	07/01/2021	0.236	Nil	pH	7.72	pH	7.71	pH, TOC, TSS, Flow meter	Storage 545 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1686	COD	236		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	450	BOD	25		
	SS	300 mg/L	SS	100 mg/L				SS	192	SS	88		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	65.52	NH <sub>3</sub> -N	18.96		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.01	Phenolic Compounds	0.48		

**M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	6.5 - 8.5	pH	6.5-8.5	07/01/2021	32.83	Nil	pH	8.14	pH	8.05	pH, Flow Meter, TOC	Storage 3500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1312	COD	238		
	BOD	400 mg/L	BOD	30 mg/L				BOD	270	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	212	SS	96		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	35.84	NH <sub>3</sub> -N	7.84		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.37	Phenolic Compounds	0.23		

**M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	06/01/2021	98	Nil	pH	8.29	pH	8.28	pH, Flow Meter, COD, BOD, TSS	MT
	COD	1000 mg/L	COD	250 mg/L				COD	1074	COD	238		
	BOD	400 mg/L	BOD	30 mg/L				BOD	270	BOD	25		
	SS	300 mg/L	SS	100 mg/L				SS	170	SS	72		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	32.48	NH <sub>3</sub> -N	11.76		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.28	Phenolic Compounds	0.21		

**M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	06/01/2021	81.5	Nil	pH	7.71	pH	7.51	pH, Flow Meter, TOC, COD	Storage 3400 MT, Disposal 353.59MT
	COD	1000 mg/L	COD	250 mg/L				COD	1030	COD	204		
	BOD	400 mg/L	BOD	30 mg/L				BOD	282	BOD	21		
	SS	300 mg/L	SS	100 mg/L				SS	210	SS	44		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	40.32	NH <sub>3</sub> -N	10.08		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.22	Phenolic Compounds	0.15		

**M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25	pH	6.5-8.5	pH	6.5-8.5	07/01/2021	0.1	Nil	pH	7.70	pH	8.05	-	Storage 16 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	466	COD	20		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	117	BOD	<5		
	SS	<150 mg/L	SS	<5 mg/L				SS	58	SS	10		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-				NH <sub>3</sub> -N	0.56	NH <sub>3</sub> -N	1.12		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

**M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Final Effluent Quality				Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	06/01/2021	29	Nil	pH	8.34	pH	8.25	pH, Flow Meter, COD Meter including TOC	Storage 1300 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1085	COD	244		
	BOD	400 mg/L	BOD	100 mg/L				BOD	323	BOD	29		
	SS	300 mg/L	SS	<60 mg/L				SS	266	SS	92		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	11.2	NH <sub>3</sub> -N	16.8		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.15	Phenolic Compounds	0.92		

**M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	6.5 -7.5	pH	6.5 to 8.5	Average value for the month of January-2021 (16/01/2021 & 26/01/2021)	1.39	Nil	pH	6.905	pH	7.55	pH, Flow Meter	Storage 6 MT, Disposal 3.43 MT
	COD	500 mg/L	COD	100 mg/L				COD	567.5	COD	107.5		
	BOD	200 mg/L	BOD	30 mg/L				BOD	114	BOD	17.5		
	SS	100 mg/L	SS	<60 mg/L				SS	103	SS	11		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.37	Phenolic Compounds	BDL		

**M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	06/01/2021	25	Nil	pH	7.86	pH	8.20	pH, Flow meter, COD, BOD, TSS	Storage 640 MT
	COD	1000 mg/L	COD	250 mg/L				COD	948	COD	192		
	BOD	400 mg/L	BOD	30 mg/L				BOD	210	BOD	23		
	SS	300 mg/L	SS	<60 mg/L				SS	172	SS	52		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	24.64	NH <sub>3</sub> -N	2.8		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.46	Phenolic Compounds	0.12		



**Vapi Green Enviro Ltd(VGEL,Vapi) (OldName-Vapi Waste & Effluent Management Co.Ltd)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value for the month of January-2021 (19/01/2021 & 22/01/2021 & 28/01/2021)	54	Nil	pH	7.35	pH	6.93	pH, Flow Meter, TOC & DO Meter	Storage 10200 MT
	COD	1500 mg/L	COD	250 mg/L				COD	1051.66	COD	241.33		
	BOD	500 mg/L	BOD	30 mg/L				BOD	215.33	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	194	SS	84		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	69.72	NH <sub>3</sub> -N	45.54		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.67	Phenolic Compounds	0.26		

**M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	21/01/2021	9	Nil	pH	6.72	pH	7.39	Flow Meter, TOC meter	Storage 250 MT Disposal 34.365 MT
	COD	1000 mg/L	COD	250 mg/L				COD	330	COD	215		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	73	BOD (3 days at 27°C)	24		
	SS	300 mg/L	SS	100 mg/L				SS	106	SS	98		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	11.2	NH <sub>3</sub> -N	19.6		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.94	Phenolic Compounds	0.24		

**M/s. Veraval Industries Association, Veraval, Junagadh**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	Not inspected for the month of January-2021	5	Nil	pH	-	pH	-		-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Bhatgam Washing GhatSuddhikaranYojana Pvt. Ltd., Bhatgam,Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	08/01/2021	10	Nil	pH	10.98	pH	8.76	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	653	COD	524		
	BOD	350 mg/L	BOD	30 mg/L				BOD	223	BOD	163		
	SS	2000 mg/L	SS	100 mg/L				SS	132	SS	484		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	30.8	NH <sub>3</sub> -N	16.8		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.5	Phenolic Compounds	BDL		

**M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	12/01/2021	7.00	Nil	pH	-	pH	7.98	pH, Flow meter	Storage 160 MT
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	747		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	245		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	158		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	6.16		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	28/01/2021	0.09	Nil	pH	-	pH	7.03	pH, Flow Meter	Storage 5.2 MT
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	358		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	108		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	14		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	6.16		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.009	pH	Up to 5	pH	6.5 to 8.5	12/01/2021	0.013	Nil	pH	<1	pH	7.98		Storage 7 MT
	COD	250 mg/L	COD	100 mg/L				COD	249	COD	50		
	BOD	100 mg/L	BOD	30 mg/L				BOD	82	BOD	16		
	SS	250 mg/L	SS	100 mg/L				SS	134	SS	28		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	4.2	NH <sub>3</sub> -N	1.4		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

**M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.04	pH	6.5 to 8.5	pH	6.5 to 8.5	02/01/2021	0.35	Nil	pH	7.40	pH	7.60		Storage 40 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1313	COD	494		
	BOD	700 mg/L	BOD	100 mg/L				BOD	315	BOD	84		
	SS	-	SS	100 mg/L				SS	198	SS	22		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	10.92	NH <sub>3</sub> -N	6.44		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		



**M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	01/01/2021	0.15	Nil	pH	7.46	pH	7.86	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	155	COD	80		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	48	BOD(3 days at 27° C)	24		
	SS	800 mg/L	SS	100 mg/L				SS	110	SS	48		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	3.36	NH <sub>3</sub> -N	3.92		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.59	Phenolic Compounds	0.0		

### M/s CETP of Dahej Industrial Estate

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6.5-9.0	Not inspected for the month of January-2021	0.66	Nil	pH	-	pH	7.475	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	519		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	68		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	68		
	NH <sub>3</sub> -N	150 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	84		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	9.415		

**M/s Mangrol Enviro Protection LLP (MEPL) (GPCB ID: 72852)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 7.5	pH	6.5-8.5	Not inspected for the month of January-2021	1	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	4000mg/l	COD	100 mg/L				COD	-	COD	-		
	BOD	2500mg/l	BOD	30mg/L				BOD	-	BOD	-		
	SS	500mg/l	SS	<60mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		