

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad (GPCB ID: 14438)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	07/11/2021, 09/11/2021	23	Nil	pH	7.64	pH	7.51	pH, Flow Meter, TOC, COD, BOD, TSS	Storage 8000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	920	COD	304		
	BOD	700 mg/L	BOD	30 mg/L				BOD	176	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	370	SS	88		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51.8	NH ₃ -N	4.59		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.69	Phenolic Compounds	0.36		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad (GPCB ID: 12890)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	09/11/2021	1.1	Nil	pH	7.18	pH	7.68	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage 1650 MT, Disposal 12.99 MT
	COD	2000 mg/L	COD	250 mg/L				COD	457	COD	282		
	BOD	700 mg/L	BOD	30 mg/L				BOD	123	BOD	29		
	SS	300 mg/L	SS	100 mg/L				SS	124	SS	40		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	50.12	NH ₃ -N	24.02		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.89	Phenolic Compounds	0.31		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad (GPCB ID: 11536)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	09/11/2021	0.7	Nil	pH	7.04	pH	7.14	Flow Meter	Storage 1500 MT
	COD	2000 mg/L	COD	250 mg/L				COD	189	COD	118		
	BOD	700 mg/L	BOD	30 mg/L				BOD	46	BOD	23		
	SS	300 mg/L	SS	100 mg/L				SS	300	SS	62		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	96.04	NH ₃ -N	4.98		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.84	Phenolic Compounds	0.21		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad (GPCB ID: 12891)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	12/11/2021	0.8	Nil	pH	7.17	pH	7.44	-	Storage 10 MT
	COD	2000 mg/L	COD	250 mg/L				COD	210	COD	268		
	BOD	700 mg/L	BOD	30 mg/L				BOD	50	BOD	37		
	SS	300 mg/L	SS	100 mg/L				SS	186	SS	88		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	17.25	NH ₃ -N	36.57		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.74	Phenolic Compounds	0.31		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad (GPCB ID: 12718)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	11/11/2021	4.5	Nil	pH	6.94	pH	7.08	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	2722.667	COD	510		
	BOD	700 mg/L	BOD	30 mg/L				BOD	887.66	BOD	62		
	SS	300 mg/L	SS	100 mg/L				SS	1652	SS	72		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	42.86	NH ₃ -N	58.18		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.543	Phenolic Compounds	0.68		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad (GPCB ID: 12720)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.1	pH	6.5-8.5	pH	6.5-8.5	09/11/2021	0.020	Nil	pH	7.79	pH	7.68	-	Storage 18.20 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1304	COD	676		
	BOD	700 mg/L	BOD	30 mg/L				BOD	251	BOD	126		
	SS	300 mg/L	SS	100 mg/L				SS	8	SS	116		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39.09	NH ₃ -N	12.88		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.12	Phenolic Compounds	0.42		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad (GPCB ID: 34244)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	09/11/2021, 15/11/2021, 17/11/2021	100	Nil	pH	7.56	pH	7.75	-	Storage 9000-950002 MT
	COD	1200 mg/L	COD	250 mg/L				COD	1207.5	COD	119		
	BOD	500 mg/L	BOD	30 mg/L				BOD	343.5	BOD	18		
	SS	300 mg/L	SS	100 mg/L				SS	685	SS	30		
	NH ₃ -N	50 mg/L	NH ₃ -N	-				NH ₃ -N	29.595	NH ₃ -N	13.08		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.3	Phenolic Compounds	0.235		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad (GPCB ID: 13515)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	02/11/2021	0.10	Nil	pH	-	pH	7.87	pH, DO meter, TOC meter, Flow meter	Storage 15 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	39		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	<5		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	48		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2.02		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad (GPCB ID: 14802)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	01/11/2021	1.8	Nil	pH	8.56	pH	7.00	pH, TOC meter	Storage 44 MT
	COD	850 mg/L	COD					COD	503	COD	28		
	BOD (5 days at 20°C)	400 mg/L	BOD (5 days at 20°C)					BOD (3 days at 27°C)	133	BOD (3 days at 27°C)	<5		
	SS	300 mg/L	SS					SS	104	SS	4		
	NH ₃ -N	50 mg/L	NH ₃ -N					NH ₃ -N	24.47	NH ₃ -N	2.41		
	Phenolic Compounds	0.3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad (GPCB ID: 10653)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6-10.5	02/11/2021	0.3	Nil	pH	-	pH	7.56	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	331		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	66		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	202		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	35.22		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal SudhikaranSahakariMandali Ltd, Bavla, Ahmedabad (GPCB ID: 14686)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6 to 10.5	01/11/2021	4	Nil	pH	-	pH	7.58		-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	125		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	16		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	98		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	11.93		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara (GPCB ID: 22336)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	08/11/2021	6.4	Nil	pH	8.07	pH	7.65	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	978	COD	229		
	BOD	500 mg/L	BOD	100 mg/L				BOD	275	BOD	61		
	SS	600 mg/L	SS	100 mg/L				SS	86	SS	44		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	26.77	NH ₃ -N	11.54		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.53	Phenolic Compounds	0.22		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara (GPCB ID: 21878)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	20/11/2021	2.2	Nil	pH	7.55	pH	7.87	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	Storage 150 MT , Disposal 34.720 MT
	COD	2000 mg/L	COD	250 mg/L				COD	8.01	COD	238		
	BOD	500 mg/L	BOD	100 mg/L				BOD	175	BOD	56		
	SS	600 mg/L	SS	100 mg/L				SS	212	SS	64		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	18.31	NH ₃ -N	8.12		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.17	Phenolic Compounds	BDL		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch (GPCB ID: 15074)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	22/11/2021	2.31	Nil	pH	7.715	pH	7.82	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	4216	COD	744		
	BOD	3600 mg/L	BOD	200 mg/L				BOD (3 days at 27°C)	1129	BOD (3 days at 27°C)	32		
	SS	-	SS	150 mg/L				SS	222	SS	60		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	122.36	NH ₃ -N	45.36		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	3.37	Phenolic Compounds	0.25		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.) (BEAIL), Ankleshwar (GPCB ID: 27833)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	15/11/2021	31.92	Nil	pH	-	pH	-	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch (GPCB ID: 15460)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	22/11/2021	0.45	Nil	pH	7.2	pH	8.03	pH, Flow Meter, TOC	Storage 140 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	3454	COD	669		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	894	BOD	136		
	SS	-	SS	150 mg/L				SS	398	SS	50		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39.2	NH ₃ -N	41.44		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	3.85	Phenolic Compounds	0.63		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat (GPCB ID: 20721)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	01/11/2021	0.236	Nil	pH	7.46	pH	7.26	pH, TOC, TSS, Flow meter	Storage 1149.970 MT
	COD	3000 mg/L	COD	250 mg/L				COD	2149	COD	248		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	573	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	578	SS	98		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	62.7	NH ₃ -N	47		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.94	Phenolic Compounds	0.52		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat (GPCB ID: 21204)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	6.5 - 8.5	pH	6.5-8.5	01/11/2021	32.83	Nil	pH	7.28	pH	7.31	pH, Flow Meter, TOC	-
	COD	1000 mg/L	COD	250 mg/L				COD	1041	COD	238		
	BOD	400 mg/L	BOD	30 mg/L				BOD	280	BOD	23		
	SS	300 mg/L	SS	100 mg/L				SS	178	SS	58		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	13.4	NH ₃ -N	7.8		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.29	Phenolic Compounds	0.21		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat (GPCB ID: 21044)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	01/11/2021	98	Nil	pH	7.63	pH	7.94	pH, Flow Meter, COD, BOD, TSS	Storage 764.321 MT , Disposal 366.78 MT
	COD	1000 mg/L	COD	250 mg/L				COD	978	COD	242		
	BOD	400 mg/L	BOD	30 mg/L				BOD	258	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	224	SS	52		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	14.6	NH ₃ -N	5.6		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.62	Phenolic Compounds	0.24		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat (GPCB ID: 11142)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	01/11/2021	81.5	Nil	pH	6.63	pH	7.53	pH, Flow Meter, TOC, COD	Storage 1653.429 MT, Disposal 172.8 MT
	COD	1000 mg/L	COD	250 mg/L				COD	949	COD	212		
	BOD	400 mg/L	BOD	30 mg/L				BOD	240	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	278	SS	68		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	8.4	NH ₃ -N	3.4		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.43	Phenolic Compounds	0.23		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL (GPCB ID: 41302)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25	pH	6.5-8.5	pH	6.5-8.5	01/11/2021	0.1	Nil	pH	-	pH	7.29	-	-
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	20		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	<5		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	4		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	BDL		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat (GPCB ID: 31233)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal		
60	pH	6.5-8.5	pH	6.5 to 8.5	01/11/2021	29	Nil	pH	7.50	pH	7.77	pH, Flow Meter, COD Meter including TOC	Storage 1496 MT, Disposal 19.77 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1090	COD	246		
	BOD	400 mg/L	BOD	30 mg/L				BOD	273	BOD	24		
	SS	300 mg/L	SS	100 mg/L				SS	312	SS	32		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	11.8	NH ₃ -N	6.2		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.44	Phenolic Compounds	0.32		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat (GPCB ID:34209)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	6.5 -7.5	pH	7 to 8	02/11/2021	1.39	Nil	pH	-	pH	8.49	pH, Flow Meter	Storage 6.6 MT
	COD	500 mg/L	COD	<100 mg/L				COD	-	COD	58		
	BOD	200 mg/L	BOD	<30 mg/L				BOD	-	BOD	15		
	SS	100 mg/L	SS	<60 mg/L				SS	-	SS	8		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	BDL		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat (GPCB ID: 10462)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	01/11/2021	25	Nil	pH	7.43	pH	7.92	pH, Flow meter, COD, BOD, TSS	Storage 914 MT
	COD	1000 mg/L	COD	250 mg/L				COD	710	COD	198		
	BOD	400 mg/L	BOD	30 mg/L				BOD	190	BOD	25		
	SS	300 mg/L	SS	<60 mg/L				SS	204	SS	54		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	8.4	NH ₃ -N	3.4		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.72	Phenolic Compounds	0.52		

Vapi Green Enviro Ltd(VGEL,Vapi) (OldName-Vapi Waste & Effluent Management Co.Ltd) (GPCB ID: 24764)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	pH.	6.5-8.5	11/11/2021, 24/11/2021	54	Nil	pH	7.795	pH	7.81	pH, Flow Meter, TOC & DO Meter	Storage 15000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1149	COD	236.5		
	BOD	400 mg/L	BOD	30 mg/L				BOD	235	BOD	26.5		
	SS	300 mg/L	SS	100 mg/L				SS	278	SS	58		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58.52	NH ₃ -N	29.96		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.375	Phenolic Compounds	0.615		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam (GPCB ID: 43677)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	11/11/2021	9	Nil	pH	7.68	pH	7.59	Flow Meter, TOC meter	Storage 675 MT
	COD	1000 mg/L	COD	250 mg/L				COD	2822	COD	163		
	BOD	400 mg/L	BOD	30 mg/L				BOD (3 days at 27°C)	588	BOD (3 days at 27°C)	22		
	SS	300 mg/L	SS	100 mg/L				SS	592	SS	56		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	53.2	NH ₃ -N	22.4		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.30	Phenolic Compounds	0.21		

M/s. Veraval Industries Association, Veraval, Junagadh (GPCB ID: 17197)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	5.5 to 9.5	10/11/2021	5	Nil	pH	6.82	pH	6.99		Storage 2.8 MT
	COD	3500 mg/L	COD	250 mg/L				COD	1853	COD	155		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	630	BOD	52		
	SS	200 mg/L	SS	100 mg/L				SS	392	SS	288		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	291.2	NH ₃ -N	101		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing GhatSuddhikaranYojana Pvt. Ltd., Bhatgam,Rajkot (GPCB ID: 23674)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6-9	18/11/2021	10	Nil	pH	10.90	pH	8.32	pH, Flow meter, SS, Color, MLSS, COD	Storage 1050 MT
	COD	1000 mg/L	COD	250 mg/L				COD	235	COD	135		
	BOD	350 mg/L	BOD	100 mg/L				BOD	72	BOD	34		
	SS	2000 mg/L	SS	100 mg/L				SS	102	SS	52		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20	NH ₃ -N	8.4		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot (GPCB ID: 19722)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
7	pH	10.5-12.0	pH	6.5-9	25/11/2021	7.00	Nil	pH	9.01	pH	7.86	pH, Flow meter	Storage 488 MT
	COD	1000 mg/L	COD	250 mg/L				COD	3049	COD	744		
	BOD	350 mg/L	BOD	100 mg/L				BOD	931	BOD	225		
	SS	2000 mg/L	SS	100 mg/L				SS	397.5	SS	132		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	14.35	NH ₃ -N	8.4		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.84		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot (GPCB ID: 20111)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	29/11/2021	0.09	Nil	pH	8.38	pH	8.10	pH, Flow Meter	Storage 21.2 MT
	COD	1000 mg/L	COD	250 mg/L				COD	2091	COD	514		
	BOD	350 mg/L	BOD	100 mg/L				BOD	687	BOD	163		
	SS	2000 mg/L	SS	100 mg/L				SS	378	SS	98		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	19.6	NH ₃ -N	8.4		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	0.26		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot (GPCB ID: 19690)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.009	pH	Up to 5	pH	6.5 to 8.5	12/11/2021	0.013	Nil	pH	<2	pH	8.24		-
	COD	250 mg/L	COD	100 mg/L				COD	94	COD	26		
	BOD	100 mg/L	BOD	30 mg/L				BOD	32	BOD	7		
	SS	250 mg/L	SS	100 mg/L				SS	40	SS	10		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	9.8	NH ₃ -N	2.8		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar (GPCB ID: 28811)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.04	pH	6.5 to 8.5	pH	6.5 to 8.5	01/11/2021	0.35	Nil	pH	7.39	pH	7.59		Storage 75 MT
	COD	2000 mg/L	COD	250 mg/L				COD	423	COD	178		
	BOD	700 mg/L	BOD	100 mg/L				BOD	94	BOD	23		
	SS	-	SS	100 mg/L				SS	72	SS	8		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	10.14	NH ₃ -N	12.43		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.68	Phenolic Compounds	0.16		

M/s CETP of Dahej Industrial Estate (GPCB ID: 50837)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9.0	Not visited in November month	0.66	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	150 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s Mangrol Enviro Protection LLP (MEPL) (GPCB ID: 72852)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5-7.5	pH	6.5-8.5	02/11/2021	1	Nil	pH	-	pH	8.41	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	4000 mg/L	COD	100 mg/L				COD	-	COD	66		
	BOD	2500 mg/L	BOD	30 mg/L				BOD	-	BOD	16		
	SS	500 mg/L	SS	<60 mg/L				SS	-	SS	60		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1.68		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s Hojiwala Infrastructure Limited (GPCB ID: 47794)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10	pH	6.5-8.5	pH	6.5-8.5	01/11/2021	10	Nil	pH	-	pH	8.20		Storage 2920 MT
	COD	400	COD	<40				COD	-	COD	14		
	BOD	200	BOD	<30				BOD	-	BOD	<5		
	SS	200	SS	<10				SS	-	SS	6		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	BDL		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

