

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad (GPCB ID: 14438)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	07/08/2021	23	Nil	pH	7.65	pH	7.37	pH, Flow Meter, TOC, COD, BOD, TSS	Storage 62 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1031	COD	388		
	BOD	700 mg/L	BOD	30 mg/L				BOD	312	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	348	SS	248		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	70.22	NH ₃ -N	4.14		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.68	Phenolic Compounds	0.54		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad (GPCB ID: 12890)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	06/08/2021	1.1	Nil	pH	7.29	pH	7.36	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage 1250 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1577	COD	588		
	BOD	700 mg/L	BOD	30 mg/L				BOD	331	BOD	99		
	SS	300 mg/L	SS	100 mg/L				SS	584	SS	134		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	170.8	NH ₃ -N	49.06		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.78	Phenolic Compounds	0.42		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad (GPCB ID: 11536)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	03/08/2021	0.7	Nil	pH	7.15	pH	7.06	Flow Meter	Storage 1400-1600 MT
	COD	2000 mg/L	COD	250 mg/L				COD	713	COD	149		
	BOD	700 mg/L	BOD	30 mg/L				BOD	296	BOD	30		
	SS	300 mg/L	SS	100 mg/L				SS	694	SS	98		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	103.44	NH ₃ -N	97.44		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.82	Phenolic Compounds	0.39		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad (GPCB ID: 12891)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	06/08/2021	0.8	Nil	pH	7.67	pH	7.62	-	Storage 5 MT
	COD	2000 mg/L	COD	250 mg/L				COD	424	COD	329		
	BOD	700 mg/L	BOD	30 mg/L				BOD	144	BOD	79		
	SS	300 mg/L	SS	100 mg/L				SS	166	SS	338		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44.97	NH ₃ -N	53.59		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.21	Phenolic Compounds	0.56		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad (GPCB ID: 12718)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	11/08/2021	4.5	Nil	pH	6.783	pH	7.37	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	2426	COD	117		
	BOD	700 mg/L	BOD	30 mg/L				BOD	745.66	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	325.33	SS	24		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	78.29	NH ₃ -N	7.67		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.293	Phenolic Compounds	0.10		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad (GPCB ID: 12720)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.1	pH	6.5-8.5	pH	6.5-8.5	07/08/2021	0.020	Nil	pH	7.64	pH	7.42	-	Storage 22 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1157	COD	388		
	BOD	700 mg/L	BOD	30 mg/L				BOD	304	BOD	52		
	SS	300 mg/L	SS	100 mg/L				SS	348	SS	184		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	28.75	NH ₃ -N	10.70		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.16	Phenolic Compounds	0.52		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad (GPCB ID: 34244)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	10/08/2021, 23/08/2021, 24/08/2021 & 25/08/2021	100	Nil	pH	7.346	pH	7.65	-	-
	COD	1200 mg/L	COD	250 mg/L				COD	1039.8	COD	97.2		
	BOD	500 mg/L	BOD	30 mg/L				BOD	333	BOD	18		
	SS	300 mg/L	SS	100 mg/L				SS	561.6	SS	31.2		
	NH ₃ -N	50 mg/L	NH ₃ -N	-				NH ₃ -N	39.622	NH ₃ -N	8.546		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.724	Phenolic Compounds	0.288		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad (GPCB ID: 13515)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	05/08/2021	0.10	Nil	pH	-	pH	7.93	pH, DO meter, TOC meter, Flow meter	
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	41		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	2.57		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	52		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3.92		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	0.36		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad (GPCB ID: 14802)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	05/08/2021	1.8	Nil	pH	7.89	pH	7.88	pH, TOC meter	Storage 35 MT
	COD	850 mg/L	COD					COD	349	COD	180		
	BOD (5 days at 20°C)	400 mg/L	BOD (5 days at 20°C)					BOD (3 days at 27°C)	90	BOD (3 days at 27°C)	34		
	SS	300 mg/L	SS					SS	176	SS	32		
	NH ₃ -N	50 mg/L	NH ₃ -N					NH ₃ -N	26.88	NH ₃ -N	4.48		
	Phenolic Compounds	0.3 mg/L	Phenolic Compounds					Phenolic Compounds	0.86	Phenolic Compounds	0.1		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad (GPCB ID: 10653)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6-10.5	05/08/2021	0.3	Nil	pH	-	pH	7.94	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	496		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	85		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	166		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	68.88		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal SudhikaranSahakariMandali Ltd, Bavla, Ahmedabad (GPCB ID: 14686)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6 to 10.5	05/08/2021	4	Nil	pH	-	pH	7.89		-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	197		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	36		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	90		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	28.0		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara (GPCB ID: 22336)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	02/08/2021	6.4	Nil	pH	-	pH	7.12	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	187		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	46		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	94		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1.46		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara (GPCB ID: 21878)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	09/08/2021	2.2	Nil	pH	-	pH	7.41	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	Storage 90 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	211		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	54		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	106		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1.01		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch (GPCB ID: 15074)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	04/08/2021, 23/08/2021	2.31	Nil	pH	7.7725	pH	7.535	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	3318.25	COD	769		
	BOD	3600 mg/L	BOD	200 mg/L				BOD (3 days at 27°C)	688.75	BOD (3 days at 27°C)	54.5		
	SS	-	SS	150 mg/L				SS	287	SS	100		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	152.075	NH ₃ -N	39.55		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	6.08	Phenolic Compounds	0.15		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar (GPCB ID: 27833)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	03/08/2021, 10/08/2021, 12/08/2021 & 13/08/2021	31.92	Nil	pH	7.93	pH	7.055	pH, Flow Meter, TOC, TSS	Storage 125 MT
	COD	1000 mg/L	COD	500 mg/L				COD	971	COD	618		
	BOD	200 mg/L	BOD	100 mg/L				BOD	231	BOD	98.5		
	SS	150 mg/L	SS	100 mg/L				SS	78	SS	125		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	67.2	NH ₃ -N	100.1		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.215	Phenolic Compounds	0.98		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch (GPCB ID: 15460)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
1.02	pH	6.5-8.5	pH	6.5-8.5	07/08/2021	0.45	Nil	pH	6.71	pH	7.74	pH, Flow Meter, TOC	Storage 80 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2519	COD	637		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	619	BOD	112		
	SS	-	SS	150 mg/L				SS	442	SS	592		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	70	NH ₃ -N	39.2		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	1.43	Phenolic Compounds	1.15		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat (GPCB ID: 20721)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	04/08/2021, 09/08/2021	0.236	Nil	pH	6.85	pH	7.305	pH, TOC, TSS, Flow meter	Storage 1030 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1198	COD	228		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	355	BOD	31		
	SS	300 mg/L	SS	100 mg/L				SS	284	SS	69		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	111.49	NH ₃ -N	26.37		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.672	Phenolic Compounds	0.3745		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat (GPCB ID: 21204)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	6.5 - 8.5	pH	6.5-8.5	04/08/2021, 09/08/2021	32.83	Nil	pH	7.345	pH	7.51	pH, Flow Meter, TOC	Storage 5400 MT
	COD	1000 mg/L	COD	250 mg/L				COD	809.5	COD	224		
	BOD	400 mg/L	BOD	30 mg/L				BOD	244.5	BOD	31.5		
	SS	300 mg/L	SS	100 mg/L				SS	153	SS	67		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	31.055	NH ₃ -N	14.15		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.718	Phenolic Compounds	0.351		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat (GPCB ID: 21044)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	05/08/2021	98	Nil	pH	6.73	pH	7.44	pH, Flow Meter, COD, BOD, TSS	Storage 768.51 MT , Disposal 89.47 MT
	COD	1000 mg/L	COD	250 mg/L				COD	894	COD	234		
	BOD	400 mg/L	BOD	30 mg/L				BOD	212	BOD	26		
	SS	300 mg/L	SS	100 mg/L				SS	186	SS	44		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23.34	NH ₃ -N	17.08		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.476	Phenolic Compounds	0.259		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat (GPCB ID: 11142)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	04/ 08/2021	81.5	Nil	pH	6.61	pH	7.16	pH, Flow Meter, TOC, COD	Storage 315 MT, Disposal 223.925 MT
	COD	1000 mg/L	COD	250 mg/L				COD	920	COD	195		
	BOD	400 mg/L	BOD	30 mg/L				BOD	255	BOD	23		
	SS	300 mg/L	SS	100 mg/L				SS	196	SS	92		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	28.46	NH ₃ -N	19.92		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.568	Phenolic Compounds	0.243		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL (GPCB ID: 41302)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25	pH	6.5-8.5	pH	6.5-8.5	05/08/2021	0.1	Nil	pH	-	pH	7.28	-	Storage 15116 MT , Disposal 5.76 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	19		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	<5		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	8		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	0.57		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat (GPCB ID: 31233)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal		
60	pH	6.5-8.5	pH	6.5 to 8.5	04/08/2021	29	Nil	pH	7.01	pH	7.44	pH, Flow Meter, COD Meter including TOC	Storage 1078 MT, Disposal 71.01 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1132	COD	248		
	BOD	400 mg/L	BOD	30 mg/L				BOD	342	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	240	SS	96		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44.97	NH ₃ -N	36.43		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.924	Phenolic Compounds	0.476		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat (GPCB ID:34209)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	6.5 -7.5	pH	7 to 8	06/08/2021	1.39	Nil	pH	-	pH	7.69	pH, Flow Meter	Storage 4.13 MT, Disposal 5.5 MT
	COD	500 mg/L	COD	<100 mg/L				COD	-	COD	33		
	BOD	200 mg/L	BOD	<30 mg/L				BOD	-	BOD	<5		
	SS	100 mg/L	SS	<60 mg/L				SS	-	SS	6		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	0.57		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat (GPCB ID: 10462)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	04/08/2021	25	Nil	pH	7.35	pH	7.48	pH, Flow meter, COD, BOD, TSS	Storage 270 MT,
	COD	1000 mg/L	COD	250 mg/L				COD	1007	COD	148		
	BOD	400 mg/L	BOD	30 mg/L				BOD	268	BOD	19		
	SS	300 mg/L	SS	<60 mg/L				SS	138	SS	58		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	21.06	NH ₃ -N	13.66		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.513	Phenolic Compounds	0.438		

Vapi Green Enviro Ltd(VGEL,Vapi) (OldName-Vapi Waste & Effluent Management Co.Ltd) (GPCB ID: 24764)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	pH.	6.5-8.5	21/08/2021, 31/08/2021	54	Nil	pH	7.43	pH	7.225	pH, Flow Meter, TOC & DO Meter	Storage 6500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	658.5	COD	225.5		
	BOD	400 mg/L	BOD	30 mg/L				BOD	128.5	BOD	28.5		
	SS	300 mg/L	SS	100 mg/L				SS	129	SS	90		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35.28	NH ₃ -N	44.24		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.875	Phenolic Compounds	0.49		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam (GPCB ID: 43677)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	02/08/2021	9	Nil	pH	8.19	pH	7.76	Flow Meter, TOC meter	Storage 500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	390	COD	168		
	BOD	400 mg/L	BOD	30 mg/L				BOD (3 days at 27°C)	85	BOD (3 days at 27°C)	25		
	SS	300 mg/L	SS	100 mg/L				SS	116	SS	90		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	5.04	NH ₃ -N	36.4		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.39	Phenolic Compounds	0.18		

M/s. Veraval Industries Association, Veraval, Junagadh (GPCB ID: 17197)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	5.5 to 9.5	Not visited in Aug 2021	5	Nil	pH	-	pH	-		-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing GhatSuddhikaranYojana Pvt. Ltd., Bhatgam,Rajkot (GPCB ID: 23674)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6-9	03/08/2021	10	Nil	pH	11.15	pH	8.57	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	250 mg/L				COD	562	COD	429		
	BOD	350 mg/L	BOD	100 mg/L				BOD	429	BOD	138		
	SS	2000 mg/L	SS	100 mg/L				SS	100	SS	126		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	22.4	NH ₃ -N	11.2		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.26	Phenolic Compounds	0.21		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot (GPCB ID: 19722)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
7	pH	10.5-12.0	pH	6.5-9	11/08/2021	7.00	Nil	pH	9.74	pH	7.87	pH, Flow meter	Storage 420 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1233.25	COD	342		
	BOD	350 mg/L	BOD	100 mg/L				BOD	409.5	BOD	121		
	SS	2000 mg/L	SS	100 mg/L				SS	272.5	SS	22		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	8.05	NH ₃ -N	9.8		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot (GPCB ID: 20111)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	11/08/2021	0.09	Nil	pH	7.55	pH	7.47	pH, Flow Meter	Storage 17.5 MT
	COD	1000 mg/L	COD	250 mg/L				COD	904	COD	285		
	BOD	350 mg/L	BOD	100 mg/L				BOD	294	BOD	92		
	SS	2000 mg/L	SS	100 mg/L				SS	432	SS	38		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	15.4	NH ₃ -N	8.4		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.60	Phenolic Compounds	BDL		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot (GPCB ID: 19690)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.009	pH	Up to 5	pH	6.5 to 8.5	Not Visited in Aug 2021	0.013	Nil	pH	-	pH	-		-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar (GPCB ID: 28811)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.04	pH	6.5 to 8.5	pH	6.5 to 8.5	11/08/2021	0.35	Nil	pH	7.65	pH	7.65		Storage 50 MT,
	COD	2000 mg/L	COD	250 mg/L				COD	666	COD	178		
	BOD	700 mg/L	BOD	100 mg/L				BOD	174	BOD	33		
	SS	-	SS	100 mg/L				SS	94	SS	20		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51.57	NH ₃ -N	2.18		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.42	Phenolic Compounds	0.28		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch (GPCB ID: 10605)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6-9	02/08/2021	0.15	Nil	pH	7.69	pH	7.36	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	670	COD	64		
	BOD	1000 mg/L	BOD	100 mg/L				BOD(3 days at 27° C)	221	BOD(3 days at 27° C)	20		
	SS	800 mg/L	SS	100 mg/L				SS	162	SS	36		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12.3	NH ₃ -N	5.6		
	Phenolic Compounds	2 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.15	Phenolic Compounds	0.8		

M/s CETP of Dahej Industrial Estate (GPCB ID: 50837)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9.0	07/08/2021	0.66	Nil	pH	-	pH	7.48	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	625		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	133		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	88		
	NH ₃ -N	150 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	173.6		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.29		

M/s Mangrol Enviro Protection LLP (MEPL) (GPCB ID: 72852)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5-7.5	pH	6.5-8.5	06/08/2021		Nil	pH	8.27	pH	8.04	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	4000 mg/L	COD	100 mg/L				COD	498	COD	56		
	BOD	2500 mg/L	BOD	30 mg/L				BOD	108	BOD	18		
	SS	500 mg/L	SS	<60 mg/L				SS	86	SS	28		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	0.85	NH ₃ -N	0.85		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s Hojiwala Infrastructure Limited (GPCB ID: 47794)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10	pH	6.5-8.5	pH	6.5-8.5	05/08/2021	-	Nil	pH	-	pH	8.09		Storage 1.388 MT
	COD	400	COD	<40				COD	-	COD	18		
	BOD	200	BOD	<30				BOD	-	BOD	<5		
	SS	200	SS	<10				SS	-	SS	2		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	0.57		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		