

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	14/10/2020	23	Nil	pH	7.68	pH	7.43	pH, Flow Meter, TOC, COD, BOD, TSS	Storage- 4500 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1253	COD	459		
	BOD	700 mg/L	BOD	30 mg/L				BOD	178	BOD	58		
	SS	300 mg/L	SS	100 mg/L				SS	408	SS	76		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	64.68	NH ₃ -N	25.54		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.47	Phenolic Compounds	0.26		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	8/10/2020	1.1	Nil	pH	7.60	pH	7.55	Flow meter at inlet & outlet, COD, pH, TSS, BOD	storage-125 MT
	COD	2000 mg/L	COD	250 mg/L				COD	755	COD	53		
	BOD	700 mg/L	BOD	30 mg/L				BOD	185	BOD	9		
	SS	300 mg/L	SS	100 mg/L				SS	126	SS	16		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33.77	NH ₃ -N	9.58		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.3	Phenolic Compounds	0.14		

M/s. Gujarat VepariMaha Mandal SahkariUdhyogikVasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	8/10/2020	0.7	Nil	pH	6.91	pH	6.88	Flow Meter	Storage-425MT
	COD	2000 mg/L	COD	250 mg/L				COD	252	COD	116		
	BOD	700 mg/L	BOD	30 mg/L				BOD	64	BOD	19		
	SS	300 mg/L	SS	100 mg/L				SS	660	SS	28		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	93.07	NH ₃ -N	93.52		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.2	Phenolic Compounds	0.13		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	8/10/2020	0.8	Nil	pH	7.11	pH	6.94	-	Storage -8 MT
	COD	750 mg/L	COD	250 mg/L				COD	567	COD	376		
	BOD	250 mg/L	BOD	30 mg/L				BOD	136	BOD	74		
	SS	300 mg/L	SS	100 mg/L				SS	62	SS	54		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12.15	NH ₃ -N	23.02		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.38	Phenolic Compounds	0.17		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	8/10/2020	4.5	Nil	pH	7.44	pH	7.23	-	Storage- 1200 MT
	COD	2000 mg/L	COD	250 mg/L				COD	3169	COD	363		
	BOD	700 mg/L	BOD	30 mg/L				BOD	762	BOD	48		
	SS	300 mg/L	SS	100 mg/L				SS	254	SS	36		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	86.35	NH ₃ -N	42.90		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.64	Phenolic Compounds	0.16		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.045	pH	6.5-8.5	pH	6.5-8.5	6/10/2020	0.020	Nil	pH	8.42	pH	7.88	-	storage-22MT
	COD	1500 mg/L	COD	250 mg/L				COD	730	COD	435		
	BOD	500 mg/L	BOD	30 mg/L				BOD	135	BOD	52		
	SS	300 mg/L	SS	100 mg/L				SS	74	SS	108		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	34.22	NH ₃ -N	49		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.73	Phenolic Compounds	0.47		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	6/10/2020	100	Nil	pH	7.82	pH	8.28	-	Storage –100 MT
	COD	1200 mg/L	COD	250 mg/L				COD	1419	COD	97		
	BOD	500 mg/L	BOD	30 mg/L				BOD	302	BOD	16		
	SS	300 mg/L	SS	100 mg/L				SS	568	SS	40		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	55.50	NH ₃ -N	18.82		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.26	Phenolic Compounds	0.16		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	7/10/2020	0.10	Nil	pH	-	pH	8.31	pH, DO meter, TOC meter, Flow meter	Storage-2.5 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	38		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	7		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	4		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	0.67		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.1		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	2/10/2020	1.8	Nil	pH	8.19	pH	7.52	pH, TOC meter	Storage-25 MT
	COD	850 mg/L	COD					COD	354	COD	14		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	65	BOD (3 days at 27°C)	2		
	SS	300 mg/L	SS					SS	52	SS	0.0		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	22.46	NH ₃ -N	0.56		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.17	Phenolic Compounds	0.11		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	3/10/2020	0.3	Nil	pH	-	pH	7.98	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	245		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	56		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	9.07		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	5/10/2020	4	Nil	pH	-	pH	7.81	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	150		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	25		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	66		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	6.22		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	13/10/2020	6.4	Nil	pH	-	pH	6.69	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	209		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	37		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	214		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2.35		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.12		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	12/10/2020	2.2	Nil	pH	-	pH	7.55	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	Storage -80 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	236		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	37		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	102		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1.34		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	8/10/2020	2.31	Nil	pH	7.13	pH	6.73	pH, Flow, COD, BOD, TSS, TOC	disposal-6.92 MT
	COD	11000 mg/L	COD	1000 mg/L				COD	3296	COD	619		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	520	BOD (3 days at 27°C)	24		
	SS	-	SS	150 mg/L				SS	205	SS	8		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51.52	NH ₃ -N	45.92		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	8.91	Phenolic Compounds	6.31		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	13/10/2020	31.92	Nil	pH	7.93	pH	7.10	pH, Flow Meter, TOC, TSS	Storage-400 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1974	COD	555		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	357	SS	18		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	203.84	NH ₃ -N	77.28		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	1.98	Phenolic Compounds	1.34		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	Average value for the month of october-2020 (8/10/2020, 26/10/2020)	0.45	Nil	pH	7.63	pH	7.71	pH, Flow Meter, TOC	-
	COD	10000 mg/L	COD	1000 mg/L				COD	3527.5	COD	533.5		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	803	BOD	57		
	SS	-	SS	150 mg/L				SS	1264	SS	88		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	83.44	NH ₃ -N	48.58		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	9.66	Phenolic Compounds	0.88		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	22/10/2020	0.236	Nil	pH	7.12	pH	7.07	pH, TOC, TSS, Flow meter	Disposal-242.04 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1024	COD	209		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	288	BOD	24		
	SS	300 mg/L	SS	100 mg/L				SS	268	SS	72		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	69.44	NH ₃ -N	13.44		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.12	Phenolic Compounds	0.82		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	6.5 - 8.5	pH	6.5-8.5	22/10/2020	32.83	Nil	pH	6.61	pH	7.03	pH, Flow Meter, TOC	Storage-566.70 MT
	COD	1000 mg/L	COD	250 mg/L				COD	746	COD	190		
	BOD	400 mg/L	BOD	30 mg/L				BOD	195	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	108	SS	64		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4.48	NH ₃ -N	8.96		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.96	Phenolic Compounds	0.49		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	22/10/2020	98	Nil	pH	7.16	pH	7.41	pH, Flow Meter, COD, BOD, TSS	Storage-603.07MT
	COD	1000 mg/L	COD	250 mg/L				COD	900	COD	216		
	BOD	400 mg/L	BOD	30 mg/L				BOD	242	BOD	24		
	SS	300 mg/L	SS	100 mg/L				SS	248	SS	78		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12.88	NH ₃ -N	2.8		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.76	Phenolic Compounds	0.34		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	22/10/2020	81.5	Nil	pH	6.73	pH	7.00	pH, Flow Meter, TOC, COD	Storage-2200 MT
	COD	1000 mg/L	COD	250 mg/L				COD	837	COD	169		
	BOD	400 mg/L	BOD	30 mg/L				BOD	215	BOD	22		
	SS	300 mg/L	SS	100 mg/L				SS	138	SS	48		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	2.52	NH ₃ -N	2.24		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.05	Phenolic Compounds	0.26		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25	pH	6.5-8.5	pH	6.5-8.5	22/10/2020	0.1	Nil	pH	-	pH	7.03	-	-
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	15		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	<5.0		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	6		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	0.56		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Final Effluent Quality				Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	22/10/2020	29	Nil	pH	6.89	pH	7.58	pH, Flow Meter, COD Meter including TOC	Storage -730 MT
	COD	1000 mg/L	COD	250 mg/L				COD	950	COD	212		
	BOD	400 mg/L	BOD	100 mg/L				BOD	248	BOD	29		
	SS	300 mg/L	SS	<60 mg/L				SS	264	SS	94		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	11.76	NH ₃ -N	10.08		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.14	Phenolic Compounds	0.35		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	6.5 -7.5	pH	6.5 to 8.5	23/10/2020	1.39	Nil	pH	-	pH	6.80	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	47		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	<5.0		
	SS	100 mg/L	SS	<60 mg/L				SS	-	SS	18		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	67		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	22/10/2020	25	Nil	pH	7.47	pH	7.26	pH, Flow meter, COD, BOD, TSS	Storage-740.8 MT
	COD	1000 mg/L	COD	250 mg/L				COD	904	COD	152		
	BOD	400 mg/L	BOD	30 mg/L				BOD	226	BOD	20		
	SS	300 mg/L	SS	<60 mg/L				SS	224	SS	52		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20.16	NH ₃ -N	1.68		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.64	Phenolic Compounds	0.28		

Vapi Green Enviro Ltd(VGEL,Vapi) (OldName-Vapi Waste & Effluent Management Co.Ltd)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value for the month of october-2020 (6/10/2020, 30/10/2020)	54	Nil	pH	7.68	pH	7.42	pH, Flow Meter, TOC & DO Meter	Storage-10400 MT
	COD	1500 mg/L	COD	250 mg/L				COD	790.5	COD	222		
	BOD	500 mg/L	BOD	30 mg/L				BOD	161	BOD	23.5		
	SS	300 mg/L	SS	100 mg/L				SS	315	SS	86		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	54.20	NH ₃ -N	42		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.44	Phenolic Compounds	0.35		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	19/10/2020	9	Nil	pH	7.71	pH	8.14	Flow Meter, TOC meter	Storage- 225 MT
	COD	1000 mg/L	COD	250 mg/L				COD	550	COD	240		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	98	BOD (3 days at 27°C)	24		
	SS	300 mg/L	SS	100 mg/L				SS	298	SS	52		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	27.44	NH ₃ -N	11.76		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.60	Phenolic Compounds	0.89		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	27/10/2020	5	Nil	pH	6.70	pH	7.37	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	1916	COD	126		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	637	BOD	43		
	SS	200 mg/L	SS	100 mg/L				SS	224	SS	176		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	254.8	NH ₃ -N	134.4		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam,Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value for the month of october-2020 (14/10/2020, 28/10/2020)	10	Nil	pH	10.72	pH	8.63	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	279.5	COD	252.5		
	BOD	350 mg/L	BOD	30 mg/L				BOD	97	BOD	76.5		
	SS	2000 mg/L	SS	100 mg/L				SS	102	SS	65		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	11.9	NH ₃ -N	7		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.29	Phenolic Compounds	BDL		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	Average value for the month of october-2020 (7/10/2020, 19/10/2020)	7.00	Nil	pH	-	pH	8.24	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	917.5		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	272.5		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	447		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	24.6		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	7/10/2020	0.09	Nil	pH	-	pH	7.76	pH, Flow Meter	Storage-14 MT
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	417		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	123		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	10		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	28		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.009	pH	Up to 5	pH	6.5 to 8.5	14/10/2020	0.013	Nil	pH	1.82	pH	8.23	-	Storage-7 MT
	COD	250 mg/L	COD	100 mg/L				COD	143	COD	46		
	BOD	100 mg/L	BOD	30 mg/L				BOD	23	BOD	13		
	SS	250 mg/L	SS	100 mg/L				SS	2	SS	2		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	2.8	NH ₃ -N	1.4		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.04	pH	6.5 to 8.5	pH	6.5 to 8.5	14/10/2020	0.35	Nil	pH	7.58	pH	7.42	-	Storage-50 MT
	COD	2000 mg/L	COD	250 mg/L				COD	380	COD	104		
	BOD	700 mg/L	BOD	100 mg/L				BOD	90	BOD	24		
	SS	-	SS	100 mg/L				SS	38	SS	18		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	5.32	NH ₃ -N	15.62		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	8/10/2020	0.15	Nil	pH	7.27	pH	7.57	pH, COD, BOD, TSS, Ammonical Nitrogen	Storage - 1.1 MT
	COD	2000 mg/L	COD	250 mg/L				COD	118	COD	211		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	38	BOD(3 days at 27° C)	66		
	SS	800 mg/L	SS	100 mg/L				SS	44	SS	24		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	7.84	NH ₃ -N	12		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.0	Phenolic Compounds	0.0		

M/s CETP of Dahej Industrial Estate

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6.5-9.0	Not inspected for the month of October-2020	0.66	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	150 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		