

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2020	23	Nil	pH	8.18	pH	8.30	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 1000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1011 mg/L	COD	366 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	307 mg/L	BOD	88 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	244 mg/L	SS	110 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	26 mg/L	NH ₃ -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.10 mg/L	Phenolic Compounds	0.20 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of April 2020	1.1	Nil	pH	-	pH	-	Flow meter at inlet & outlet, COD, pH, TSS, BOD	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of April 2020	0.7	Nil	pH	-	pH	-	Flow Meter	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of April 2020	0.8	Nil	pH	-	pH	-	-	-
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of April 2020	4.5	Nil	pH	-	pH	-	-	Storage - 800 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.040	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April 2020	0.020	Nil	pH	-	pH	-	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of April 2020	100	Nil	pH	-	pH	-	-	-
	COD	1200 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of April - 2020	0.10	Nil	pH	-	pH	8.51	pH, DO meter, TOC meter, Flow meter	Storage – 3 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	12 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	2 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	4 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of April - 2020	1.8	Nil	pH	7.59	pH	7.10	pH, TOC meter	Storage – 25 MT
	COD	850 mg/L	COD					COD	401 mg/L	COD	12 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	162 mg/L	BOD (3 days at 27°C)	2 mg/L		
	SS	300 mg/L	SS					SS	70 mg/L	SS	4 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	17 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.36 mg/L	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of April- 2020	0.3	Nil	pH	-	pH	7.76	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	167 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	44 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	22 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	20 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of April- 2020	4	Nil	pH	6.99	pH	7.82	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	1087 mg/L	COD	165 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	347 mg/L	BOD	35 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	94 mg/L	SS	52 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	77 mg/L	NH ₃ -N	8 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	Average value of April - 2020	6.4	Nil	pH	6.60	pH	7.66	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	896 mg/L	COD	143 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	96 mg/L	BOD	19 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	796 mg/L	SS	128 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	344 mg/L	NH ₃ -N	6 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of April - 2020	2.2	Nil	pH	-	pH	7.79	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	226 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	31 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	104 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April 2020	2.31	Nil	pH	-	pH	-	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	-	COD	-		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	-	BOD (3 days at 27°C)	-		
	SS	-	SS	150 mg/L				SS	-	SS	-		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	No visit in the month of April 2020	31.92	Nil	pH	-	pH	-	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of April 2020	0.45	Nil	pH	-	pH	-	pH, Flow Meter, TOC	-
	COD	10000 mg/L	COD	1000 mg/L				COD	-	COD	-		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	-	BOD	-		
	SS	-	SS	150 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	No visit in the month of April 2020	0.236	Nil	pH	-	pH	-	pH, TOC, TSS, Flow meter	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	No visit in the month of April 2020	32.83	Nil	pH	-	pH	-	pH, Flow Meter, TOC	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	No visit in the month of April 2020	98	Nil	pH	-	pH	-	pH, Flow Meter, COD, BOD, TSS	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April 2020	81.5	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.84	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April 2020	0.5	Nil	pH	-	pH	-	-	-
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	-		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	-		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	No visit in the month of April 2020	29	Nil	pH	-	pH	-	pH, Flow Meter, COD Meter including TOC	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.75	pH	-	pH	6.5 to 8.5	No visit in the month of April 2020	1.39	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April 2020	25	Nil	pH	-	pH	-	pH, Flow meter, COD, BOD, TSS	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of April 2020	54	Nil	pH	7.48	pH	7.00	pH, Flow Meter, TOC & DO Meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	925 mg/L	COD	218 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	241 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	131 mg/L	SS	55 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44 mg/L	NH ₃ -N	41 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.43 mg/L	Phenolic Compounds	0.32 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April 2020	9	Nil	pH	-	pH	-	Flow Meter, TOC meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	-	BOD (3 days at 27°C)	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of April 2020	5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	No sampling in the month of April 2020	10	Nil	pH	-	pH	-	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	No sampling in the month of April 2020	7.00	Nil	pH	-	pH	-	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	No visit in the month of April 2020	0.09	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No visit in the month of April 2020	0.013	Nil	pH	-	pH	-	-	-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.35	pH	6.5 to 8.5	pH	6.5 to 8.5	No sampling in the month of April 2020	0.35	Nil	pH	-	pH	-	-	Storage – 42 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	-	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2020	0.15	Nil	pH	7.69	pH	7.17	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	291 mg/L	COD	77 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	98 mg/L	BOD(3 days at 27° C)	24 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	52 mg/L	SS	12 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	75 mg/L	NH ₃ -N	67 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.4 mg/L	Phenolic Compounds	0.1 mg/L		