

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	23	Nil	pH	7.48	pH	7.30	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	2000 mg/L	COD	250 mg/L				COD	1242 mg/L	COD	384 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	386 mg/L	BOD	98 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	228 mg/L	SS	36 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	68 mg/L	NH ₃ -N	29 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.21 mg/L	Phenolic Compounds	0.94 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	1.1	Nil	pH	7.18	pH	8.03	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 90 MT
	COD	2000 mg/L	COD	250 mg/L				COD	667 mg/L	COD	566 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	218 mg/L	BOD	71 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	300 mg/L	SS	44 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.39 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	0.7	Nil	pH	7.20	pH	7.20	Flow Meter	Storage – 30 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1097 mg/L	COD	566 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	224 mg/L	BOD	95 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1790 mg/L	SS	82 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	117 mg/L	NH ₃ -N	133 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.50 mg/L	Phenolic Compounds	0.75 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	0.8	Nil	pH	7.54	pH	7.19	-	-
	COD	750 mg/L	COD	250 mg/L				COD	564 mg/L	COD	172 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	201 mg/L	BOD	81 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	125 mg/L	SS	70 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	82 mg/L	NH ₃ -N	43 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.68 mg/L	Phenolic Compounds	0.60 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	4.5	Nil	pH	7.13	pH	6.92	-	Storage – 700 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1865 mg/L	COD	1105 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	615 mg/L	BOD	252 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	335 mg/L	SS	70 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	57 mg/L	NH ₃ -N	75 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.31 mg/L	Phenolic Compounds	0.52 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.040	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	0.020	Nil	pH	8.13	pH	7.78	-	Storage – 30 MT
	COD	1500 mg/L	COD	250 mg/L				COD	511 mg/L	COD	172 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	134 mg/L	BOD	55 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	198 mg/L	SS	50 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.86 mg/L	Phenolic Compounds	BDL		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	100	Nil	pH	7.14	pH	7.85	-	-
	COD	1200 mg/L	COD	250 mg/L				COD	1107 mg/L	COD	296 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	520 mg/L	BOD	102 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	635 mg/L	SS	132 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	62 mg/L	NH ₃ -N	30 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.01 mg/L	Phenolic Compounds	0.4 mg/L		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of Feb - 2020	0.10	Nil	pH	-	pH	8.25	pH, DO meter, TOC meter, Flow meter	Storage – 3 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	28 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	3 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	8 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of Feb - 2020	1.8	Nil	pH	7.54	pH	7.57	pH, TOC meter	Storage – 5 MT
	COD	850 mg/L	COD					COD	476 mg/L	COD	8 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	200 mg/L	BOD (3 days at 27°C)	2 mg/L		
	SS	300 mg/L	SS					SS	60 mg/L	SS	4 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	24 mg/L	NH ₃ -N	4 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.39 mg/L	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	0.3	Nil	pH	-	pH	7.59	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	207 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	54 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	106 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	11 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicabl e				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	4	Nil	pH	-	pH	7.84	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	178 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	51 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	56 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	8 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	No visit in the month of Feb-2020	6.4	Nil	pH	-	pH	-	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of Feb - 2020	2.2	Nil	pH	-	pH	7.67	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	Storage – 250 MT Disposal – 30 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	213 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	38 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	36 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	8 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	2.31	Nil	pH	7.87	pH	7.68	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	3804 mg/L	COD	573 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	647 mg/L	BOD (3 days at 27°C)	21 mg/L		
	SS	-	SS	150 mg/L				SS	714 mg/L	SS	70 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	72 mg/L	NH ₃ -N	52 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	7.08 mg/L	Phenolic Compounds	0.49 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	No sampling in the month of Feb - 2020	31.92	Nil	pH	-	pH	-	pH, Flow Meter, TOC, TSS	Storage - 1900 MT
	COD	1000 mg/L	COD	500 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	0.45	Nil	pH	7.02	pH	7.59	pH, Flow Meter, TOC	Storage - 150 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2477 mg/L	COD	702 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	331 mg/L	BOD	21 mg/L		
	SS	-	SS	150 mg/L				SS	448 mg/L	SS	44 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	52 mg/L	NH ₃ -N	51 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	5.12 mg/L	Phenolic Compounds	1.30 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of Feb - 2020	0.236	Nil	pH	7.98	pH	7.82	pH, TOC, TSS, Flow meter	Storage - 1706 MT Disposal – 186 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1272 mg/L	COD	211 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	256 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	202 mg/L	SS	82 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44 mg/L	NH ₃ -N	27 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.22 mg/L	Phenolic Compounds	0.58 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of Feb - 2020	32.83	Nil	pH	7.75	pH	7.85	pH, Flow Meter, TOC	Storage – 250 MT Disposal – 1206 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1072 mg/L	COD	229 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	262 mg/L	BOD	27 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	224 mg/L	SS	68 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	17 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.20 mg/L	Phenolic Compounds	0.49 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of Feb - 2020	98	Nil	pH	7.95	pH	7.81	pH, Flow Meter, COD, BOD, TSS	Storage – 615 MT Disposal - 67 MT
	COD	1000 mg/L	COD	250 mg/L				COD	922 mg/L	COD	218 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	229 mg/L	BOD	23 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	212 mg/L	SS	70 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	24 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.14 mg/L	Phenolic Compounds	0.58 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	81.5	Nil	pH	7.70	pH	7.81	pH, Flow Meter, TOC, COD	Storage – 800 MT Disposal – 1810 MT
	COD	1000 mg/L	COD	250 mg/L				COD	890 mg/L	COD	198 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	207 mg/L	BOD	22 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	222 mg/L	SS	76 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	29 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.83 mg/L	Phenolic Compounds	0.61 mg/L		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.84	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of Feb-2020	0.5	Nil	pH	-	pH	-	-	-
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	-		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	-		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of Feb - 2020	29	Nil	pH	7.99	pH	7.60	pH, Flow Meter, COD Meter including TOC	Storage – 250 MT Disposal – 623 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1086 mg/L	COD	208 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	214 mg/L	BOD	27 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	226 mg/L	SS	84 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	28 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.14 mg/L	Phenolic Compounds	0.61 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.75	pH	-	pH	6.5 to 8.5	No visit in the month of Feb-2020	1.39	Nil	pH	-	pH	-	pH, Flow Meter	
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	25	Nil	pH	7.77	pH	7.75	pH, Flow meter, COD, BOD, TSS	Storage – 1200 MT Disposal – 734 MT
	COD	1000 mg/L	COD	250 mg/L				COD	796 mg/L	COD	212 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	160 mg/L	BOD	23 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	256 mg/L	SS	76 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	22 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.34 mg/L	Phenolic Compounds	0.58 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of Feb - 2020	54	Nil	pH	8.02	pH	7.22	pH, Flow Meter, TOC & DO Meter	Storage - 16000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1068 mg/L	COD	239 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	260 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	202 mg/L	SS	70 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44 mg/L	NH ₃ -N	23 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	4.5 mg/L	Phenolic Compounds	0.82 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	9	Nil	pH	6.61	pH	7.18	Flow Meter, TOC meter	Storage – 150 MT
	COD	1000 mg/L	COD	250 mg/L				COD	582 mg/L	COD	226 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	168 mg/L	BOD (3 days at 27°C)	27 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	316 mg/L	SS	88 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	21 mg/L	NH ₃ -N	26 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.2	Phenolic Compounds	0.25		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	Average value of Feb - 2020	5	Nil	pH	-	pH	7.62	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	135 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	42 mg/L		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	204 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	185 mg/L		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of Feb - 2020	10	Nil	pH	10.79	pH	8.01	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	402 mg/L	COD	193 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	125 mg/L	BOD	42 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	290 mg/L	SS	246 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	No sampling in the month of Feb-2020	7.00	Nil	pH	-	pH	-	pH, Flow meter	Storage - 6 MT
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of Feb - 2020	0.09	Nil	pH	6.60	pH	6.55	pH, Flow Meter	Storage – 4 MT Disposal – 11 MT
	COD	1000 mg/L	COD	100 mg/L				COD	1073 mg/L	COD	353 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	314 mg/L	BOD	101 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	338 mg/L	SS	94 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	9 mg/L	NH ₃ -N	26 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of Feb - 2020	0.013	Nil	pH	2.45	pH	8.02	-	Storage – 7 MT
	COD	250 mg/L	COD	100 mg/L				COD	15 mg/L	COD	7 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	3 mg/L	BOD	2 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	74 mg/L	SS	48 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	2 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.35	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of Feb - 2020	0.35	Nil	pH	-	pH	7.75	-	Storage - 50 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	232 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	58 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	82 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	9 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of Feb - 2020	0.15	Nil	pH	7.56	pH	7.42	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	517 mg/L	COD	76 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	184 mg/L	BOD(3 days at 27° C)	24 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	262 mg/L	SS	56 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	66 mg/L	NH ₃ -N	40 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.3 mg/L	Phenolic Compounds	0.1 mg/L		