

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	22/09/2020	23	Nil	pH	7.62	pH	7.71	pH, Flow Meter, TOC, COD, BOD, TSS	Storage-4800 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1349	COD	393		
	BOD	700 mg/L	BOD	30 mg/L				BOD	290	BOD	36		
	SS	300 mg/L	SS	100 mg/L				SS	586	SS	50		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51.8	NH ₃ -N	2.91		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.57	Phenolic Compounds	0.47		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	4/9/2020	1.1	Nil	pH	7.18	pH	7.89	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage-120 MT
	COD	2000 mg/L	COD	250 mg/L				COD	780	COD	269		
	BOD	700 mg/L	BOD	30 mg/L				BOD	246	BOD	36		
	SS	300 mg/L	SS	100 mg/L				SS	78	SS	24		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	30.94	NH ₃ -N	12.88		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.08	Phenolic Compounds	0.76		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	22/09/2020	0.7	Nil	pH	6.80	pH	7.48	Flow Meter	Storage-300 MT
	COD	2000 mg/L	COD	250 mg/L				COD	565	COD	94		
	BOD	700 mg/L	BOD	30 mg/L				BOD	54	BOD	22		
	SS	300 mg/L	SS	100 mg/L				SS	452	SS	22		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	76.16	NH ₃ -N	66.78		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.3	Phenolic Compounds	0.21		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	22/09/2020	0.8	Nil	pH	7.55	pH	7.69	-	Storage – 6 MT
	COD	750 mg/L	COD	250 mg/L				COD	929	COD	356		
	BOD	250 mg/L	BOD	30 mg/L				BOD	208	BOD	43		
	SS	300 mg/L	SS	100 mg/L				SS	632	SS	96		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	31.92	NH ₃ -N	12.66		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.38	Phenolic Compounds	0.38		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	22/09/2020	4.5	Nil	pH	7.71	pH	7.19	-	Storage -1500 MT
	COD	2000 mg/L	COD	250 mg/L				COD	3537	COD	406		
	BOD	700 mg/L	BOD	30 mg/L				BOD	956	BOD	42		
	SS	300 mg/L	SS	100 mg/L				SS	448	SS	30		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	84.84	NH ₃ -N	12.26		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	5.34	Phenolic Compounds	0.23		

M/s. Narol Dyestuff Enviro Society, Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.045	pH	6.5-8.5	pH	6.5-8.5	22/09/2020	0.020	Nil	pH	8.10	pH	7.55	-	Storage -20 MT
	COD	1500 mg/L	COD	250 mg/L				COD	589	COD	192		
	BOD	500 mg/L	BOD	30 mg/L				BOD	132	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	44	SS	8		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	132.44	NH ₃ -N	6.58		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.26	Phenolic Compounds	0.21		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value for the month of September-2020 (10/9/2020 & 20/09/2020)	100	Nil	pH	7.58	pH	8.12	-	Storage-900 MT
	COD	1200 mg/L	COD	250 mg/L				COD	1265.5	COD	97.5		
	BOD	500 mg/L	BOD	30 mg/L				BOD	306.5	BOD	12.5		
	SS	300 mg/L	SS	100 mg/L				SS	625	SS	10		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	50.4	NH ₃ -N	22.19		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.175	Phenolic Compounds	0.05		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	18/09/2020	0.10	Nil	pH	-	pH	8.22	pH, DO meter, TOC meter, Flow meter	Storage-3 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	43		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	6		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	4		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1.01		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.09		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	11/9/2020	1.8	Nil	pH	7.53	pH	6.56	pH, TOC meter	Storage-37 MT
	COD	850 mg/L	COD					COD	425	COD	07		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	84	BOD (3 days at 27°C)	1.03		
	SS	300 mg/L	SS					SS	22	SS	6		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	31.78	NH ₃ -N	0.42		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.56	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	11/9/2020	0.3	Nil	pH	-	pH	7.90	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	157		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	26		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	38		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	9.41		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	11/9/2020	4	Nil	pH	-	pH	8.15		-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	169		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	62		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	5.26		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	5/9/2020	6.4	Nil	pH	-	pH	6.73	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	222		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	25		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	94		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2.46		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Not inspected for the month of September-2020	2.2	Nil	pH	-	pH	-	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	30/9/2020	2.31	Nil	pH	7.70	pH	6.63	pH, Flow, COD, BOD, TSS, TOC	Disposal- 10.11 MT
	COD	11000 mg/L	COD	1000 mg/L				COD	2622	COD	776		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	654	BOD (3 days at 27°C)	32		
	SS	-	SS	150 mg/L				SS	646	SS	20		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	49.28	NH ₃ -N	45.92		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	2.02	Phenolic Compounds	0.10		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Sampling not done for the month of September-2020	31.92	Nil	pH	-	pH	-	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	30/09/2020	0.45	Nil	pH	7.08	pH	7.59	pH, Flow Meter, TOC	Storage-125 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	1722	COD	545		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	430	BOD	140		
	SS	-	SS	150 mg/L				SS	1106	SS	164		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	64.96	NH ₃ -N	57.12		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.76	Phenolic Compounds	0.18		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	30/09/2020	0.236	Nil	pH	6.91	pH	7.36	pH, TOC, TSS, Flow meter	Storage- 514 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1300	COD	197		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	340	BOD	22		
	SS	300 mg/L	SS	100 mg/L				SS	244	SS	46		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	66.08	NH ₃ -N	13.44		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.80	Phenolic Compounds	0.77		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	6.5 - 8.5	pH	6.5-8.5	30/09/2020	32.83	Nil	pH	6.73	pH	6.88	pH, Flow Meter, TOC	Storage-1500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1327	COD	240		
	BOD	400 mg/L	BOD	30 mg/L				BOD	350	BOD	27		
	SS	300 mg/L	SS	100 mg/L				SS	84	SS	66		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4.48	NH ₃ -N	3.92		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.95	Phenolic Compounds	0.44		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	30/09/2020	98	Nil	pH	7.65	pH	7.47	pH, Flow Meter, COD, BOD, TSS	Storage-500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1144	COD	153		
	BOD	400 mg/L	BOD	30 mg/L				BOD	320	BOD	28		
	SS	300 mg/L	SS	100 mg/L				SS	82	SS	66		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	13.44	NH ₃ -N	12.32		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.66	Phenolic Compounds	0.59		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	30/09/2020	81.5	Nil	pH	6.83	pH	7.40	pH, Flow Meter, TOC, COD	Storage-1500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1216	COD	184		
	BOD	400 mg/L	BOD	30 mg/L				BOD	300	BOD	18		
	SS	300 mg/L	SS	100 mg/L				SS	168	SS	92		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	14.56	NH ₃ -N	12.32		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.80	Phenolic Compounds	0.52		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25	pH	6.5-8.5	pH	6.5-8.5	30/09/2020	0.1	Nil	pH	-	pH	7.24	-	Storage-15 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	-	COD	18		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	-	BOD	2.5		
	SS	<150 mg/L	SS	<5 mg/L				SS	-	SS	12		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	-	NH ₃ -N	0.28		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Cetp Of Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal		
60	pH	6.5-8.5	pH	6.5 to 8.5	30/09/2020	29	Nil	pH	7.79	pH	7.54	pH, Flow Meter, COD Meter including TOC	Storage – 700 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1025	COD	245		
	BOD	400 mg/L	BOD	100 mg/L				BOD	300	BOD	27		
	SS	300 mg/L	SS	<60 mg/L				SS	76	SS	42		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	43.68	NH ₃ -N	10.08		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.50	Phenolic Compounds	0.32		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	6.5 -7.5	pH	6.5 to 8.5	Not inspected for the month of September-2020	1.39	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	100 mg/L	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	30/09/2020	25	Nil	pH	7.96	pH	7.74	pH, Flow meter, COD, BOD, TSS	Storage-600 MT
	COD	1000 mg/L	COD	250 mg/L				COD	949	COD	210		
	BOD	400 mg/L	BOD	30 mg/L				BOD	286	BOD	27		
	SS	300 mg/L	SS	<60 mg/L				SS	124	SS	62		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36.96	NH ₃ -N	7.84		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.19	Phenolic Compounds	0.49		

Vapi Green Enviro Ltd (VGEL,Vapi) (Old Name-Vapi Waste & Effluent Management Co.Ltd)

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value for the month of September-2020 (11/9/2020 & 19/09/2020 & 24/09/2020)	54	Nil	pH	7.9	pH	7.6	pH, Flow Meter, TOC & DO Meter	Storage-7500 MT
	COD	1500 mg/L	COD	250 mg/L				COD	920.3	COD	228.0		
	BOD	500 mg/L	BOD	30 mg/L				BOD	184.0	BOD	27.0		
	SS	300 mg/L	SS	100 mg/L				SS	278.3	SS	80.7		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	54.7	NH ₃ -N	38.6		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.5	Phenolic Compounds	0.2		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	18/09/2020	9	Nil	pH	5.86	pH	8.09	Flow Meter, TOC meter	Storage-175 MT
	COD	1000 mg/L	COD	250 mg/L				COD	492.0	COD	190		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	108	BOD (3 days at 27°C)	24		
	SS	300 mg/L	SS	100 mg/L				SS	86	SS	32		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4.48	NH ₃ -N	39.20		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.29	Phenolic Compounds	0.42		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	3/9/2020	5	Nil	pH	6.99	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	406	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	136	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	84	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	42	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam,Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value for the month of September-2020 (7/9/2020 & 21/09/2020)	10	Nil	pH	-	pH	9.32	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	170		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	56		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	312		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2.24		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.1		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	25/09/2020	7.00	Nil	pH	-	pH	8.30	pH, Flow meter	Storage- 320 MT
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	800		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	262		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	100		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	5.6		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	21/09/2020	0.09	Nil	pH	-	pH	7.60	pH, Flow Meter	Storage-13 MT
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	273		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	85		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	26		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	32.2		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.009	pH	Up to 5	pH	6.5 to 8.5	Not inspected for the month of September-2020	0.013	Nil	pH	-	pH	-	-	-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.04	pH	6.5 to 8.5	pH	6.5 to 8.5	21/09/2020	0.35	Nil	pH	-	pH	7.57	-	Storage-40 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	83		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	12		
	SS	-	SS	100 mg/L				SS	-	SS	34		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1.85		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.64		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	1/9/2020	0.15	Nil	pH	7.45	pH	7.35	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	120	COD	104		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	38	BOD(3 days at 27° C)	31		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	8		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	11.2	NH ₃ -N	12.8		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.0	Phenolic Compounds	0.0		

M/s CETP of Dahej Industrial Estate

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6.5-9.0	19/09/2020	0.66	Nil	pH	-	pH	6.63	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	441		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	78		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	6		
	NH ₃ -N	150 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	143.36		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		