

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	8.5	Nil	pH	7.03	pH	7.51	Flow Meter, TOC meter	Storage – 350 MT
	COD	750 mg/L	COD	250 mg/L				COD	626 mg/L	COD	137.7 mg/L		
	BOD (3 days at 27°C)	300 mg/L	BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	186 mg/L	BOD (3 days at 27°C)	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	61 mg/L	SS	184.7 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	17.93 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.21 mg/L	Phenolic Compounds	0.29 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
55	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	55	Nil	pH	7.95	pH	7.44	pH, Flow Meter, TOC & DO Meter	Storage - 4100 MT
	COD	1000 mg/L	COD	250 mg/L				COD	615.57 mg/L	COD	223.12 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	141.97 mg/L	BOD	33.76 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	178.78 mg/L	SS	149.09 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	43.67 mg/L	NH ₃ -N	31.43 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.71 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of July - 2016	47	Nil	pH	6.80	pH	7.06	Flow Meter, TOC	Storage - 1200 MT Disposal - 29.94 MT
	COD	1000 mg/L	COD	250 mg/L				COD	945 mg/L	COD	266 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	305 mg/L	BOD	54 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	128 mg/L	SS	84 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	16 mg/L	NH ₃ -N	7.21 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.73 mg/L	Phenolic Compounds	0.71 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2016	0.35	Nil	pH	7.07	pH	7.93	Flow Meter, TOC	Storage – 4 MT
	COD	4000 mg/L	COD	250 mg/L				COD	1408.5 mg/L	COD	344.5 mg/L		
	BOD	1500 mg/L	BOD	30 mg/L				BOD	450.5 mg/L	BOD	69.5 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	148 mg/L	SS	86 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	465.9 mg/L	NH ₃ -N	56.16 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.45 mg/L	Phenolic Compounds	0.89 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	88	Nil	pH	7.28	pH	7.52	Flow Meter, TOC	Storage – 200 MT Disposal – 257.31 MT
	COD	1000 mg/L	COD	250 mg/L				COD	959 mg/L	COD	306 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	325 mg/L	BOD	68 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	284 mg/L	SS	28 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3.88 mg/L	NH ₃ -N	1.11 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.28 mg/L	Phenolic Compounds	0.70 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL),Kadodara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2016	95	Nil	pH	7.15	pH	7.30	pH, Flow Meter, TOC	Storage :1900 MT
	COD	1000 mg/L	COD	250 mg/L				COD	945 mg/L	COD	274 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	315 mg/L	BOD	72 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	134 mg/L	SS	104 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	22	Nil	pH	7.46	pH	7.52	-	Storage - 650 MT Disposal – 27.49 MT
	COD	1000 mg/L	COD	100 mg/L				COD	948 mg/L	COD	331 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	310 mg/L	BOD	66 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	380 mg/L	SS	77 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	12.2 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.78 mg/L	Phenolic Compounds	0.97 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd,Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2016	35	Nil	pH	7.03	pH	7.57	pH, Flow Meter, COD Meter including TOC	Storage - 25 MT
	COD		COD	100 mg/L				COD	1098 mg/L	COD	294 mg/L		
	BOD		BOD	30 mg/L				BOD	383 mg/L	BOD	75 mg/L		
	SS		SS	<60 mg/L				SS	282 mg/L	SS	46 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.94 mg/L	Phenolic Compounds	0.12 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2016	35	Nil	pH	7.21	pH	7.16	pH, Flow Meter, COD Meter including TOC	Storage – 2.5 MT Disposal – 53 MT
	COD		COD	100 mg/L				COD	739 mg/L	COD	221 mg/L		
	BOD		BOD	30 mg/L				BOD	240 mg/L	BOD	48 mg/L		
	SS		SS	<60 mg/L				SS	54 mg/L	SS	6 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	Not Furnished	pH	5.5-8.5	Average value of July - 2016	0.35	Nil	pH	6.89	pH	6.91	pH, Flow Meter, TOC	Storage - 20 MT
	COD		COD	100 mg/L				COD	2377 mg/L	COD	905.5 mg/L		
	BOD		BOD	30 mg/L				BOD	731.5 mg/L	BOD	209.5 mg/L		
	SS		SS	100 mg/L				SS	295 mg/L	SS	113 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	69.7 mg/L	NH ₃ -N	14.56 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	1.2 mg/L	Phenolic Compounds	1.01 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.8	pH	Not Furnished	pH	5.5-8.5	Average value of July - 2016	1.10	Nil	pH	1.69	pH	7.20	-	Storage - Nil Disposal- 867.62 MT
	COD		COD	100 mg/L				COD	3753 mg/L	COD	679 mg/L		
	BOD (3 days at 27°C)		BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	1260 mg/L	BOD (3 days at 27°C)	63 mg/L		
	SS		SS	100 mg/L				SS	186 mg/L	SS	62 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	60.98 mg/L	NH ₃ -N	27.72 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	4.59 mg/L	Phenolic Compounds	0.86 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.)(BEAIL), Ankleshwar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6-9	Average value of July - 2016	40	Nil	pH	7.44	pH	7.74	pH, Flow Meter, TOC	Storage - 5000 MT
	COD		COD	500 mg/L				COD	909 mg/L	COD	470 mg/L		
	BOD		BOD	100 mg/L				BOD	300 mg/L	BOD	54 mg/L		
	SS		SS	100 mg/L				SS	56 mg/L	SS	16 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	61 mg/L	NH ₃ -N	55 mg/L		
	Phenolic Compounds		Phenolic Compounds	5 mg/L				Phenolic Compounds	3.36 mg/L	Phenolic Compounds	1.64 mg/L		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of July - 2016	4.80	Nil	pH	7.07	pH	8.43	Flow Meter, COD	-
	COD	2000 mg/L	COD	250 mg/L				COD	1217 mg/L	COD	504 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	436 mg/L	BOD	375 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	256 mg/L	SS	124 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	9.52 mg/L	NH ₃ -N	10.08 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.064 mg/L	Phenolic Compounds	0.84 mg/L		

M/s. Enviro Infrastructure Co. Ltd., Umraya(Padra), Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of July - 2016	1.50	Nil	pH	7.72	pH	8.06	pH, Flow Meter, TOC and Total Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	499 mg/L	COD	31 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	333 mg/L	BOD	14 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	504 mg/L	SS	72 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	2.24 mg/L	NH ₃ -N	14.56 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.70 mg/L	Phenolic Compounds	0.51 mg/L		

M/s. Naroda Enviro Project Ltd.,Naroda, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
3	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	3	Nil	pH	8.33	pH	8.38	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	3627 mg/L	COD	1934 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	946 mg/L	BOD	655 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	285 mg/L	SS	276 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	45.92 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.89 mg/L	Phenolic Compounds	0.685 mg/L		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	20	Nil	pH	7.20	pH	7.26	Flow Meter, TOC	-
	COD	3000 mg/L	COD	250 mg/L				COD	2167 mg/L	COD	805 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	760 mg/L	BOD	280 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	308 mg/L	SS	202 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	79.52 mg/L	NH ₃ -N	69.44 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.70 mg/L	Phenolic Compounds	0.48 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	1	Nil	pH	-	pH	7.16	Flow meter at inlet & outlet	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	408 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	92 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	52 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	22.4 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.26 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	0.6	Nil	pH	7.40	pH	8.19	-	Storage – 6-8 MT
	COD	3000 mg/L	COD	250 mg/L				COD	644 mg/L	COD	173 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	310 mg/L	BOD	68 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	760 mg/L	SS	110 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3.36 mg/L	NH ₃ -N	22.96 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.29 mg/L	Phenolic Compounds	BDL		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	0.015	Nil	pH	7.79	pH	8.07	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	1287 mg/L	COD	203 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	369 mg/L	BOD	66 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	384 mg/L	SS	118 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33.60 mg/L	NH ₃ -N	8.4 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.56 mg/L	Phenolic Compounds	BDL		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
1.0	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	0.6	Nil	pH	4.59	pH	7.36	Flow Meter	Storage – 100 MT
	COD	3000 mg/L	COD	250 mg/L				COD	575.5 mg/L	COD	122 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	269 mg/L	BOD	36 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	338 mg/L	SS	26 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23.8 mg/L	NH ₃ -N	17.36 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.542 mg/L	Phenolic Compounds	0.16 mg/L		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2016	0.35	Nil	pH	7.76	pH	7.15	-	Storage – 20-22 MT Disposal – 85.24 MT
	COD	2500 mg/L	COD	250 mg/L				COD	1810 mg/L	COD	636 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	718 mg/L	BOD	175 mg/L		
	SS	-	SS	100 mg/L				SS	344 mg/L	SS	204 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	38.64 mg/L	NH ₃ -N	21.28 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.55 mg/L		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.75	pH	6 to 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of July - 2016	0.75	Nil	pH	7.78	pH	7.08	-	Storage : 40 MT
	COD	850 mg/L	COD					COD	213 mg/L	COD	35 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	75 mg/L	BOD (3 days at 27°C)	12 mg/L		
	SS	300 mg/L	SS					SS	48 mg/L	SS	4 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	30.8 mg/L	NH ₃ -N	1.12 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.15 mg/L	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of July - 2016	1.5	Nil	pH	-	pH	7.71	-	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	42 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	17 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	10 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3.03 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	No CETP Inlet norms prescribed as it is a CETP of rice mill cluster	pH	6.5-8.5	Average value of July - 2016	1	Nil	pH	-	pH	7.45	-	Sludge is used as Manure
	COD		COD	250 mg/L				COD	-	COD	282 mg/L		
	BOD		BOD	100 mg/L				BOD	-	BOD	86 mg/L		
	SS		SS	100 mg/L				SS	-	SS	144 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	20.16 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	0.16 mg/L		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No sampling in the month of July - 2016									

M/s. Rajkot Electroplating Association, Rajkot

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No sampling in the month of July-2016									

M/s. Jay Khodiyar Enviro -Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No sampling in the month of July-2016									

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2016	0.007	Nil	pH	8.05	pH	7.68	-	Storage – 25 MT Disposal – 90 MT
	COD		COD	250 mg/L				COD	587.5 mg/L	COD	124 mg/L		
	BOD		BOD	30 mg/L				BOD	209 mg/L	BOD	40 mg/L		
	SS		SS	100 mg/L				SS	1190 mg/L	SS	40 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	14.84 mg/L	NH ₃ -N	8.4 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2016	0.007	Nil	pH	-	pH	7.52	-	Storage – 15 MT
	COD		COD	250 mg/L				COD	-	COD	775 mg/L		
	BOD		BOD	30 mg/L				BOD	-	BOD	290 mg/L		
	SS		SS	100 mg/L				SS	-	SS	120 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	16.8 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	-	pH	6.5 to 8.5	Average value of July - 2016	6	Nil	pH	11.28	pH	8.88	-	Disposal :260 MT
	COD	-	COD	100 mg/L				COD	818 mg/L	COD	253.5 mg/L		
	BOD	-	BOD	30 mg/L				BOD	288.5 mg/L	BOD	85 mg/L		
	SS	-	SS	100 mg/L				SS	575 mg/L	SS	2340 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	5.6 mg/L	NH ₃ -N	3.64 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No sampling in the month of July-2016									

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2016	2.0	Nil	pH	7.6	pH	7.6	-	Storage – 1.5 MT
	COD	2000 mg/L	COD	100 mg/L				COD	53 mg/L	COD	60 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	30 mg/L				BOD(3 days at 27° C)	13.8 mg/L	BOD(3 days at 27° C)	15.9 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	2 mg/L	SS	8 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	BDL	NH ₃ -N	BDL		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.32 mg/L	Phenolic Compounds	0.2 mg/L		