

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	20	Nil	pH	-	pH	7.31	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 4000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	456 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	87 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	108 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	15 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	1.00	Nil	pH	7.28	pH	6.95	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 100 MT
	COD	2000 mg/L	COD	250 mg/L				COD	807 mg/L	COD	393 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	233 mg/L	BOD	97 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	643 mg/L	SS	58 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	22 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.95 mg/L	Phenolic Compounds	1.17 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	0.60	Nil	pH	2.73	pH	7.16	Flow Meter	Storage - 250 MT
	COD	2000 mg/L	COD	250 mg/L				COD	895 mg/L	COD	260 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	326 mg/L	BOD	91 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	2608 mg/L	SS	464 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	126 mg/L	NH ₃ -N	109 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	0.60	Nil	pH	-	pH	7.73	-	Storage – 15 MT
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	155 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	48 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	96 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	37 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	3.00	Nil	pH	7.6	pH	7.4	-	Storage – 4000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	4810 mg/L	COD	1288 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	863 mg/L	BOD	341 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	707 mg/L	SS	303 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	155 mg/L	NH ₃ -N	37 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	5.02 mg/L	Phenolic Compounds	BDL		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	0.015	Nil	pH	-	pH	8.08	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	355 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	58 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	54 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	4 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	100	Nil	pH	7.04	pH	7.84	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 300 MT
	COD	1200 mg/L	COD	250 mg/L				COD	984 mg/L	COD	392 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	380 mg/L	BOD	132 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	548 mg/L	SS	155 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	75 mg/L	NH ₃ -N	55 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of August - 2018	0.10	Nil	pH	-	pH	7.83	pH, DO meter, TOC meter, Flow meter	Storage – 3 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	31 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	6 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	6 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	5 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of August - 2018	1.3	Nil	pH	7.47	pH	7.01	pH, TOC meter	Storage – 30 MT
	COD	850 mg/L	COD					COD	166 mg/L	COD	7 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	385 mg/L	BOD (3 days at 27°C)	2 mg/L		
	SS	300 mg/L	SS					SS	66 mg/L	SS	4 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	31 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of August - 2018	1.00	Nil	pH	-	pH	7.91	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	482 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	96 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	130 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	49 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	--		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of August - 2018	1.50	Nil	pH	-	pH	8	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250mg/L				COD	-	COD	276 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	60 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	96 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	21 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of August - 2018	4.80	Nil	pH	7.08	pH	6.72	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1501 mg/L	COD	230 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	414 mg/L	BOD	32 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	150 mg/L	SS	48 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	22 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.49 mg/L	Phenolic Compounds	0.68 mg/L		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of August - 2018	1.50	Nil	pH	7.36	pH	7.83	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	297 mg/L	COD	104 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	48 mg/L	BOD	22 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	316 mg/L	SS	40 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.46 mg/L	Phenolic Compounds	0.66 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of August - 2018	1.10	Nil	pH	7.05	pH	7.61	pH, Flow, COD, BOD, TSS, TOC	Storage – 1 MT
	COD	11000 mg/L	COD	1000 mg/L				COD	4281 mg/L	COD	765 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	928 mg/L	BOD (3 days at 27°C)	28 mg/L		
	SS	-	SS	100 mg/L				SS	1866 mg/L	SS	94 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	81 mg/L	NH ₃ -N	56 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	9.68 mg/L	Phenolic Compounds	0.25 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of August - 2018	40	Nil	pH	7.205	pH	7.07	pH, Flow Meter, TOC, TSS	Storage – 3200 MT
	COD	1000 mg/L	COD	500 mg/L				COD	872 mg/L	COD	440 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	294 mg/L	BOD	22 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	88 mg/L	SS	68 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	83 mg/L	NH ₃ -N	59 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	3 mg/L	Phenolic Compounds	0.35 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	-	pH	5.5-8.5	Average value of August - 2018	0.35	Nil	pH	6.73	pH	7.54	pH, Flow Meter, TOC	Storage – 125 MT
	COD	3500 mg/L	COD	500 mg/L				COD	3644 mg/L	COD	861 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	999 mg/L	BOD	29 mg/L		
	SS	-	SS	100 mg/L				SS	470 mg/L	SS	58 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	93 mg/L	NH ₃ -N	45 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	4.51 mg/L	Phenolic Compounds	0.405 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2018	0.35	Nil	pH	7.48	pH	7.07	pH, TOC, TSS, Flow meter	Storage – 31 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1116 mg/L	COD	240 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	290 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	342 mg/L	SS	94 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	197 mg/L	NH ₃ -N	45 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.59 mg/L	Phenolic Compounds	0.39 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of August - 2018	40	Nil	pH	6.9	pH	7.40	pH, Flow Meter, TOC	Storage – 1200 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1230 mg/L	COD	237 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	305 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	220 mg/L	SS	106 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.51 mg/L	Phenolic Compounds	0.27 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August – 2018	95	Nil	pH	7.26	pH	7.47	pH, Flow Meter, COD, BOD, TSS	Storage- 563 MT Disposal – 58 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1491 mg/L	COD	282 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	339 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	254 mg/L	SS	93 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	42 mg/L	NH ₃ -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.10 mg/L	Phenolic Compounds	0.06 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	88	Nil	pH	7.25	pH	7.48	pH, Flow Meter, TOC, COD	Storage – 3100 MT Disposal – 1085 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1280 mg/L	COD	260 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	363 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	290 mg/L	SS	46 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33 mg/L	NH ₃ -N	20 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.08 mg/L	Phenolic Compounds	0.12 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of August – 2018	35	Nil	pH	7.58	pH	7.41	pH, Flow Meter, COD Meter including TOC	Storage - 315 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1125 mg/L	COD	230 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	286 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	176 mg/L	SS	52 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	21 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.67 mg/L	Phenolic Compounds	0.37 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	Average value of August - 2018	1.00	Nil	pH	6.74	pH	8.12	pH, Flow Meter	Storage – 2 MT Disposal – 6 MT
	COD	500 mg/L	COD	100 mg/L				COD	441 mg/L	COD	89 mg/L		
	BOD	200 mg/L	BOD	30 mg/L				BOD	94 mg/L	BOD	21 mg/L		
	SS	-	SS	<60 mg/L				SS	122 mg/L	SS	36 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.07 mg/L	Phenolic Compounds	0.06 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	22	Nil	pH	7.64	pH	8.18	pH, Flow meter, COD, BOD, TSS	Storage - 300 MT
	COD	1000 mg/L	COD	250 mg/L				COD	960 mg/L	COD	136 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	270 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	333 mg/L	SS	26 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	24 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.56 mg/L	Phenolic Compounds	0.29 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of August - 2018	55	Nil	pH	8.405	pH	7.455	pH, Flow Meter, TOC & DO Meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	1371 mg/L	COD	285 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	394 mg/L	BOD	35 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	253 mg/L	SS	105 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	89 mg/L	NH ₃ -N	60 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.6 mg/L	Phenolic Compounds	0.78 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	8.5	Nil	pH	7.365	pH	8.145	Flow Meter, TOC meter	Storage – 500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	258 mg/L	COD	151 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	55 mg/L	BOD (3 days at 27°C)	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	147 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.31 mg/L	Phenolic Compounds	0.09 mg/L		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of August – 2018	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam,Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of August - 2018	6.00	Nil	pH	10.77	pH	8.825	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	243 mg/L	COD	73 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	66 mg/L	BOD	22 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	190 mg/L	SS	60 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	13 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	Average value of August - 2018	7.00	Nil	pH	10.20	pH	7.85	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	986 mg/L	COD	146 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	325 mg/L	BOD	31 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	494 mg/L	SS	92 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	17 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of August - 2018	0.07	Nil	pH	7.34	pH	7.02	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	762 mg/L	COD	395 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	200 mg/L	BOD	98 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	194 mg/L	SS	136 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	15 mg/L	NH ₃ -N	28 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No visit in the month of August – 2018	0.007	Nil	pH	-	pH	-	-	-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2018	0.35	Nil	pH	6.86	pH	7.11	-	Storage – 20 MT
	COD	2000 mg/L	COD	250 mg/L				COD	3314 mg/L	COD	669 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	1527 mg/L	BOD	106 mg/L		
	SS	-	SS	100 mg/L				SS	923 mg/L	SS	244 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	14 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2018	0.10	Nil	pH	6.78	pH	6.74	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	295 mg/L	COD	76 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	91 mg/L	BOD(3 days at 27° C)	24 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	138 mg/L	SS	44 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36 mg/L	NH ₃ -N	20 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.3 mg/L	Phenolic Compounds	0.2 mg/L		