

**M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad (GPCB ID: 14438)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	05/09/2022	23	--	pH	7.78	pH	7.50	Provided	Provided
	COD	2000	COD	250				COD	422	COD	149		
	BOD	700	BOD	30				BOD	91	BOD	14		
	SS	300	SS	100				SS	146	SS	<b>106</b>		
	NH <sub>3</sub> -N	50	NH <sub>3</sub> -N	50				NH <sub>3</sub> -N	24.19	NH <sub>3</sub> -N	11.54		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	2.45	Phenolic Compounds	0.57		

**M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad (GPCB ID: 12890 )**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	09/09/2022	1.1	--	pH	7.15	pH	7.03	Provided	Provided
	COD	2000	COD	250				COD	696	COD	232		
	BOD	700	BOD	30				BOD	156	BOD	<b>34</b>		
	SS	300	SS	100				SS	950	SS	<b>114</b>		
	NH <sub>3</sub> -N	50	NH <sub>3</sub> -N	50				NH <sub>3</sub> -N	29.12	NH <sub>3</sub> -N	24.19		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	1.64	Phenolic Compounds	<b>1.14</b>		

**M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad (GPCB ID: 11536)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	01/09/2022	0.385	--	pH	6.97	pH	6.65	Provided	Provided
	COD	2000	COD	250				COD	59	COD	54		
	BOD	700	BOD	30				BOD	13	BOD	9		
	SS	300	SS	100				SS	26	SS	<b>210</b>		
	NH3-N	50	NH3-N	50				NH3-N	23.30	NH3-N	18.26		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	0.82	Phenolic Compounds	0.61		

**M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad (GPCB ID: 12891)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.0	pH	6.5-8.5	pH	6.5-8.5	01/09/2022	1.0	--	pH	7.85	pH	7.76	Provided but pH meter found in maintenance	Provided
	COD	2000	COD	250				COD	497	COD	231		
	BOD	700	BOD	30				BOD	160	BOD	58		
	SS	300	SS	100				SS	84	SS	90		
	NH3-N	50	NH3-N	50				NH <sub>3</sub> -N	31.2	NH <sub>3</sub> -N	18.21		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	1.09	Phenolic Compounds	0.79		

**M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad (GPCB ID: 12718)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
14	pH	6.5-8.5	pH	6.5-8.5	03/09/2022	5.2	--	pH	7.39	pH	7.10	Provided	Provided
	COD	2000	COD	250				COD	2193	COD	324		
	BOD	700	BOD	30				BOD	536	BOD	36		
	SS	300	SS	100				SS	572	SS	46		
	NH3-N	50	NH3-N	50				NH3-N	45.47	NH <sub>3</sub> -N	18.42		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	3.87	Phenolic Compounds	1.59		

**M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad (GPCB ID: 12720)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.1	pH	6.5-8.5	pH	6.5-8.5	02/09/2022	0.045	--	pH	7.46	pH	7.49	Provided but not in operation	Provided
	COD	2000	COD	250				COD	297	COD	90		
	BOD	700	BOD	30				BOD	70	BOD	21		
	SS	300	SS	100				SS	114	SS	<b>104</b>		
	NH <sub>3</sub> -N	50	NH <sub>3</sub> -N	50				NH <sub>3</sub> -N	29.57	NH <sub>3</sub> -N	18.59		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	3.64	Phenolic Compounds	<b>1.11</b>		

**M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad (GPCB ID: 34244)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	03/09/2022	90	--	pH	7.09	pH	7.59	Provided	Provided
	COD	1200	COD	250				COD	929	COD	85		
	BOD	500	BOD	30				BOD	483	BOD	22		
	SS	300	SS	100				SS	124	SS	102		
	NH3-N	50	NH3-N	50				NH <sub>3</sub> -N	40.99	NH <sub>3</sub> -N	17.92		
	Phenolic Compounds	1	Phenolic Compounds	1				Phenolic Compounds	0.72	Phenolic Compounds	0.52		

**M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad (GPCB ID: 13515)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6 to 10.5	pH	6.5 to 8.5	05.09.2022	0.12	-	pH	--	pH	7.60	Provided	@4 MT ETP sludge is found stored.
	COD	900	COD	100				COD	--	COD	29		
	BOD	250	BOD	30				BOD	--	BOD	6		
	SS	100	SS	100				SS	--	SS	6		
	NH <sub>3</sub> -N	--	NH <sub>3</sub> -N	50				NH <sub>3</sub> -N	--	NH <sub>3</sub> -N	7.56		
	Phenolic Compounds	--	Phenolic Compounds	---				Phenolic Compounds	--	Phenolic Compounds	BDL		



**M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad (GPCB ID: 14802)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6 to 8	pH	ZLD Condition	01.09.2022	2	-	pH	7.40	pH	6.94	Provided	Stock of ETP sludge approx @ 38 MT (MEE salt & ETP sludge) is observed stored in separate hazardous waste storage area.
	COD	850	COD					COD	396	COD	30		
	BOD	400	BOD					BOD	122	BOD	6		
	SS	300	SS					SS	64	SS	8		
	NH <sub>3</sub> -N	50	NH <sub>3</sub> -N					NH <sub>3</sub> -N	30.69	NH <sub>3</sub> -N	7.16		
	Phenolic Compounds	0.3	Phenolic Compounds					Phenolic Compounds	0.72	Phenolic Compounds	0.58		

**M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad (GPCB ID: 10653)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	5.5 to 8.5	pH	6 to 10.5	02.09.2022	0.35	-	pH	---	pH	7.58	Not installed	Sludge is used as manure
	COD	4500	COD	250				COD	---	COD	336		
	BOD	1500	BOD	100				BOD	---	BOD	84		
	SS	300	SS	100				SS	---	SS	66		
	NH <sub>3</sub> -N	---	NH <sub>3</sub> -N	50				NH <sub>3</sub> -N	---	NH <sub>3</sub> -N	19.94		
	Phenolic Compounds	----	Phenolic Compounds	---				Phenolic Compounds	---	Phenolic Compounds	----		

**M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad (GPCB ID: 14686)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	5.5 to 8.5	pH	6 to 10.5	08.09.2022	0.2	-	pH	--	pH	7.60	Not installed	Sludge is used as manure
	COD	4500	COD	250				COD	---	COD	188		
	BOD	1500	BOD	100				BOD	---	BOD	47		
	SS	300	SS	100				SS	---	SS	52		
	NH <sub>3</sub> -N	---	NH <sub>3</sub> -N	50				NH <sub>3</sub> -N	---	NH <sub>3</sub> -N	18.09		
	Phenolic Compounds	---	Phenolic Compounds	---				Phenolic Compounds	---	Phenolic Compounds	---		

**M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara (GPCB ID: 22336)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	01/09/2022	@6.2	--	pH	--	pH	8.15	In operation	Nil
	COD	1500 mg/l	COD	250 mg/l				COD	--	COD	239		
	BOD	500 mg/l	BOD	100 mg/l				BOD	--	BOD	49		
	SS	600 mg/l	SS	100 mg/l				SS	--	SS	90		
	NH <sub>3</sub> -N	50 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	--	NH <sub>3</sub> -N	0.73		
	Phenolic Compounds	5 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	--	Phenolic Compounds	BDL		

**M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara (GPCB ID: 21878)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.5	pH	5 to 9	pH	6.5 to 8.5	01/09/2022	@2.2	--	pH	--	pH	8.06	In operation	580 MT ETP sludge stored within premises
	COD	2000 mg/l	COD	250 mg/l				COD	--	COD	218		
	BOD	500 mg/l	BOD	100 mg/l				BOD	--	BOD	41		
	SS	600 mg/l	SS	100 mg/l				SS	--	SS	124		
	NH <sub>3</sub> -N	50 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	--	NH <sub>3</sub> -N	1.12		
	Phenolic Compounds	5 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	--	Phenolic Compounds	BDL		

**M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch (GPCB ID: 15074)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.2	pH	6.5 to 8.5	pH	6.5 to 8.5	13/09/2022	2.2	0	pH	6.89	pH	7.46	CEQMS provided and operational	Unit has provided hazardous waste storage area and disposing ETP sludge to TSDF. No stock of ETP sludge is observed in provided designated storage area
	COD	11000 mg/L	COD	1000 mg/L				COD	2927 mg/L	COD	548 mg/L		
	BOD	3600 mg/L	BOD	200 mg/L				BOD	612 mg/L	BOD	18 mg/L		
	SS	—	SS	150 mg/L				SS	1125 mg/L	SS	56 mg/L		
	NH <sub>3</sub> -N	100 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	25.2 mg/L	NH <sub>3</sub> -N	33.6 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	4.64 mg/L	Phenolic Compounds	BDL mg/L		

**M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.), (BEAIL), Ankleshwar (GPCB ID: 27833)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5 to 8.5	pH	6-9	27.09.2022	40	0	pH	8.40	pH	7.21	CEQMS provided and operational	Unit has provided hazardous waste storage area and disposing ETP sludge to TSDF.
	COD	1000 mg/L	COD	500 mg/L				COD	1334	COD	427		
	BOD	200 mg/L	BOD	100 mg/L				BOD	318	BOD	102		
	SS	150 mg/L	SS	100 mg/L				SS	212	SS	14		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	82.32	NH <sub>3</sub> -N	80.08		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.87	Phenolic Compounds	1.06		

**M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch (GPCB ID: 15460)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5 to 8.5	pH	6.5 to 8.5	19/09/2022	1.02	0	pH	7.17	pH	7.72	CEQMS provided and operational	Unit has provided hazardous waste storage area and disposing ETP sludge to TSDF.
	COD	10000 mg/L	COD	1000 mg/L				COD	3196 mg/L	COD	476 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	760 mg/L	BOD	112 mg/L		
	SS	—	SS	150 mg/L				SS	414 mg/L	SS	36 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	22.96 mg/L	NH <sub>3</sub> -N	28 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.89 mg/L	Phenolic Compounds	BDL mg/L		



**M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat (GPCB ID: 20721)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.0 MLD	pH	6.5 to-8.5pH unit	pH	6.5 to8.5 pH Unit	02-09-2022	0.45 MLD	NIL	pH	7.69	pH	7.90	Yes, Provided	Stock of HAZ waste @1153.850 MT (for TSDf site) and Stock of gypsum waste @ 10.095 MT. Disposal - NIL
	COD	1000ppm	COD	250ppm				COD	990	COD	246		
	BOD	400ppm	BOD	30ppm				BOD	218	BOD	29		
	SS	300ppm	SS	100ppm				SS	160	SS	92		
	NH <sub>3</sub> -N	50ppm	NH <sub>3</sub> -N	50ppm				NH <sub>3</sub> -N	65.69	NH <sub>3</sub> -N	43		
	Phenolic Compounds	1ppm	Phenolic Compounds	1ppm				Phenolic Compounds	0.88	Phenolic Compounds	0.70		

**M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat (GPCB ID: 21204)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50 MLD	pH	6.5 to-8.5pH unit	pH	6.5 to8.5 pH Unit	02/09/2022	35 MLD	NIL	pH	7.8	pH	8.3	Yes Provided	Stock of ETP Sludge @1500 MT. Disposal of Sludge NIL at M/s. J K Laxmi Cement Ltd, Rajasthan (for Co-processing)
	COD	1000ppm	COD	250ppm				COD	707	COD	239		
	BOD	400ppm	BOD	30ppm				BOD	190	BOD	26		
	SS	300ppm	SS	100ppm				SS	96	SS	52		
	NH <sub>3</sub> -N	50ppm	NH <sub>3</sub> -N	50ppm				NH <sub>3</sub> -N	28.56	NH <sub>3</sub> -N	3.43		
	Phenolic Compounds	1ppm	Phenolic Compounds	1ppm				Phenolic Compounds	0.18	Phenolic Compounds	0.35		

**M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat (GPCB ID: 21044)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150 MLD	pH	6.5 to-8.5pH unit	pH	6.5 to8.5 pH Unit	02/09/2022	110 MLD	NIL	pH	8.02	pH	8.20	Yes provided	. CETP sludge stock @ 538.481MT is observed stored in the HAZ waste storage area. CETP sludge is sent to M/s. Ambuja Cement Ltd. for co-processing. As per the records, they have sent sludge @302.96MT at M/s. Ambuja Cement Ltd for co-processing
	COD	1000ppm	COD	250ppm				COD	891	COD	231		
	BOD	400ppm	BOD	30ppm				BOD	225	BOD	27		
	SS	300ppm	SS	100ppm				SS	62	SS	20		
	NH <sub>3</sub> -N	50ppm	NH <sub>3</sub> -N	50ppm				NH <sub>3</sub> -N	30.84	NH <sub>3</sub> -N	14.85		
	Phenolic Compounds	1ppm	Phenolic Compounds	1ppm				Phenolic Compounds	0.40	Phenolic Compounds	0.15		

**M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat (GPCB ID: 11142)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100 MLD	pH	6.5 to-8.5pH unit	pH	6.5 to8.5 pH Unit	22-09-2022	75 MLD	NIL	pH	8.44	pH	8.4	Yes Provided	Stock of CETP sludge @ 1569.48 MT, Disposal of Sludge @37.180 MT at M/s. J. K Laxmi Cement LTD, 105.665 MT at Ambuja Cement Ltd for co-processing
	COD	1000ppm	COD	250ppm				COD	853	COD	195		
	BOD	400ppm	BOD	30ppm				BOD	190	BOD	23		
	SS	300ppm	SS	100ppm				SS	62	SS	60		
	NH <sub>3</sub> -N	50ppm	NH <sub>3</sub> -N	50ppm				NH <sub>3</sub> -N	22.28	NH <sub>3</sub> -N	17.14		
	Phenolic Compounds	1ppm	Phenolic Compounds	1ppm				Phenolic Compounds	0.55	Phenolic Compounds	0.25		

**M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL (GPCB ID: 41302)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.25 MLD	pH	6.5 to-8.5pH unit	pH	6.6 to8.5 pH Unit	02-09-2022	0.5MLD	NIL	pH	-	pH	7.75	No	Stock of CETP sludge @ 10 MT. Disposal- Nil
	COD	<500Mgl/l	COD	<20mg/l				COD	-	COD	26		
	BOD	<200mg/l	BOD	<5mg/l				BOD	-	BOD	<5.0		
	SS	<150mg/l	SS	<5mg/l				SS	-	SS	4		
	NH <sub>3</sub> -N	In cca not mentioned	NH <sub>3</sub> -N	In cca not mentioned				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	0.57		
	Phenolic Compounds	In cca not mentioned	Phenolic Compounds	In cca not mentioned				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat (GPCB ID: 31233)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60 MLD	pH	6.5 to-8.5pH unit	pH	6.5 to8.5 pH Unit	02-09-2022	37 MLD	NIL	pH	7.7	pH	8.17	Yes, Provided	Stock of CETP Sludge @1241 MT. Disposal of Sludge NIL
	COD	1000ppm	COD	250ppm				COD	1077	COD	183		
	BOD	400ppm	BOD	30ppm				BOD	278	BOD	22		
	SS	300ppm	SS	100ppm				SS	64	SS	28		
	NH <sub>3</sub> -N	50ppm	NH <sub>3</sub> -N	50ppm				NH <sub>3</sub> -N	19.42	NH <sub>3</sub> -N	7.43		
	Phenolic Compounds	1ppm	Phenolic Compounds	1ppm				Phenolic Compounds	0.55	Phenolic Compounds	0.55		

**M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat (GPCB ID:34209 )**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25 MLD	pH	6.5 to-7.5pH unit	pH	7 to8 pH Unit	02-09-2022	2 MLD	NIL	pH	-	pH	8.40	No	Stock of HAZ waste @ 7.250 MT Disposal - NIL
	COD	<500mg/l	COD	<100mg/l				COD	-	COD	11		
	BOD	<200mg/l	BOD	<30mg/l				BOD	-	BOD	<5		
	SS	In cca not mentioned	SS	In cca not mentioned				SS	-	SS	8		
	NH <sub>3</sub> -N	In cca not mentioned	NH <sub>3</sub> -N	In cca not mentioned				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	0.57		
	Phenolic Compounds	In cca not mentioned	Phenolic Compounds	In cca not mentioned				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat (GPCB ID: 10462)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45 MLD	pH	6.5 to-8.5pH unit	pH	6.5 to8.5 pH Unit	02-09-2022	25 MLD	NIL	pH	8.43	pH	8.16	Yes, Provided	Stock of CETP Sludge @599.4 MT. Disposal of Sludge NIL
	COD	1000ppm	COD	250ppm				COD	1071	COD	247		
	BOD	400ppm	BOD	30ppm				BOD	293	BOD	26		
	SS	300ppm	SS	60 ppm				SS	78	SS	32		
	NH <sub>3</sub> -N	50ppm	NH <sub>3</sub> -N	50ppm				NH <sub>3</sub> -N	54.84	NH <sub>3</sub> -N	12.57		
	Phenolic Compounds	1ppm	Phenolic Compounds	1ppm				Phenolic Compounds	0.3	Phenolic Compounds	0.20		



**Vapi Green Enviro Ltd. (VGEL,Vapi) (Old Name-Vapi Waste & Effluent Management Co. Ltd) (GPCB ID: 24764)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55 MLD	pH	6.8 to 8.5	pH	6.8 to 8.5	05/09/2022, 12/09/2022, 16/09/2022, 20/09/2022	55 MLD	No	pH	7.685	pH	7.6	CETP has provided Online CEQMS which is connected to GPCB and CPCB	Approximately 23700 MTsludge observed stored in storage area of CETP
	COD	1000 mg/l	COD	250 mg/l				COD	800	COD	219.25		
	BOD	400 mg/l	BOD	30 mg/l				BOD	221.5	BOD	25.75		
	SS	300 mg/l	SS	100 mg/l				SS	185.5	SS	102.5		
	NH <sub>3</sub> -N	50 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	39.06	NH <sub>3</sub> -N	22.82		
	Phenolic Compounds	1 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	0.9975	Phenolic Compounds	0.4125		

**M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam (GPCB ID: 43677)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5 MLD	pH	6.8 to 8.5	pH	6.8 to 8.5	03/09/2022, 16/09/2022	11 MLD (Approximate Average)	---	pH	7.13	pH	7.635	CETP has provided Online CEQMS which is connected to GPCB and CPCB	Approximately 350 MT sludge stored in storage area of CETP. Disposal during September 2022 is Nil
	COD	1000 mg/l	COD	250 mg/l				COD	285.5	COD	132.5		
	BOD	400 mg/l	BOD	30 mg/l				BOD	77.5	BOD	27.5		
	SS	300 mg/l	SS	100 mg/l				SS	140	SS	45		
	NH <sub>3</sub> -N	50 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	14.84	NH <sub>3</sub> -N	12.88		
	Phenolic Compounds	1 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	0.62	Phenolic Compounds	0.33		

**M/s. Veraval Industries Association, Veraval, Junagadh (GPCB ID: 17197)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5 MLD	pH	5.5 to 9.5	pH	5.5 to 9.5	09/09/2022	@ 1MLD	-	pH	7.67	pH	6.80	CEMS is not working properly.	Sludge stock - @4.225 MT
	COD	3500 mg/l	COD	250 mg/l				COD	1250	COD	175		
	BOD	1000 mg/l	BOD	100 mg/l				BOD	414	BOD	58.0		
	SS	200 mg/l	SS	100 mg/l				SS	34	SS	38		
	NH <sub>3</sub> -N	50 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	134.4	NH <sub>3</sub> -N	39.2		
	Phenolic Compounds	NA	Phenolic Compounds	NA				Phenolic Compounds	NA	Phenolic Compounds	NA		

\*Note: - The CETP operation started from 17/08/2022 as season of fish processing units started.

**M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot (GPCB ID: 23674 )**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5 to 12	pH	6 to 9	04/09/2022	30	Null	pH	10.81	pH	9.13	Online CEQMS for BOD, COD, TSS& pH is operational	approx. 125 MT of sludge is stored at CETP.
	COD	1000 mg/l	COD	250 mg/l				COD	903 mg/l	COD	514 mg/l		
	BOD	350 mg/l	BOD	100 mg/l				BOD	306 mg/l	BOD	163 mg/l		
	SS	2000 mg/l	SS	100 mg/l				SS	112 mg/l	SS	18 mg/l		
	NH3-N	75 mg/l	NH3-N	50 mg/l				NH3-N	44.8 mg/l	NH3-N	7 mg/l		
	Phenolic Compounds	5 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	1.45 mg/l	Phenolic Compounds	0.43 mg/l		

**M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot (GPCB ID: 19722)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
7	pH	10.5 to 12	pH	6.5 to 9	06/09/2022	7	Nil	pH	11.46	pH	7.70	Online CEQMS for COD & pH is operational	approx. 90.910 MT of sludge is stored at CETP.
	COD	1000 mg/l	COD	250 mg/l				COD	<b>1425 mg/l</b>	COD	<b>271 mg/l</b>		
	BOD	250 mg/l	BOD	100 mg/l				BOD	<b>458 mg/l</b>	BOD	91 mg/l		
	SS	2000 mg/l	SS	100 mg/l				SS	278 mg/l	SS	<b>114 mg/l</b>		
	NH <sub>3</sub> -N	75 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	30.8 mg/l	NH <sub>3</sub> -N	19.6 mg/l		
	Phenolic Compounds	5 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	1.38 mg/l	Phenolic Compounds	0.38 mg/l		

**M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot (GPCB ID: 20111)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.091	pH	10.5 to 12	pH	6.5 to 9	06/09/2022	0.091	Nil	pH	7.44	pH	7.38	<b>Not installed Online CEQMS</b>	approx. 30.80 MT of sludge is stored at CETP.
	COD	1000 mg/l	COD	250 mg/l				COD	<b>1304</b> mg/l	COD	<b>406</b> mg/l		
	BOD	350 mg/l	BOD	100 mg/l				BOD	<b>446</b> mg/l	BOD	<b>140</b> mg/l		
	SS	2000 mg/l	SS	100 mg/l				SS	412 mg/l	SS	22 mg/l		
	NH <sub>3</sub> -N	75 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	22.4 mg/l	NH <sub>3</sub> -N	8.4 mg/l		
	Phenolic Compounds	5 mg/l	Phenolic Compounds	1 mg/l				Phenolic Compounds	----	Phenolic Compounds	0.53 mg/l		

**M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot (GPCB ID: 19690)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	27/09/2022	@ 0.025	-	pH	<2	pH	8.30	CEMS not provided	Sludge - @5-6 MT stored within hazardous waste storage room.
	COD	250 mg/l	COD	100 mg/l				COD	308 mg/l	COD	62 mg/l		
	BOD	100 mg/l	BOD	30 mg/l				BOD	105 mg/l	BOD	17 mg/l		
	SS	250 mg/l	SS	100 mg/l				SS	68 mg/l	SS	24 mg/l		
	NH <sub>3</sub> -N	N.A	NH <sub>3</sub> -N	N.A				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	NA	Phenolic Compounds	NA				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

**M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar (GPCB ID: 28811)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.4 MLD	pH	6.5 – 8.5	pH	6.5 to 8.5	09/09/2022	0.250MLD	NIL	pH	7.37	pH	7.55	Online analyzer provided at the final outlet of the CETP	separate hazardous waste storage area provided
	COD	2000 mg/l	COD	250 mg/l				COD	910 mg/l	COD	220 mg/l		
	BOD	700 mg/l	BOD	100 mg/l				BOD	405 mg/l	BOD	34 mg/l		
	SS	--	SS	100 mg/l				SS	120 mg/l	SS	60 mg/l		
	NH <sub>3</sub> -N	50 mg/l	NH <sub>3</sub> -N	50 mg/l				NH <sub>3</sub> -N	29.79mg/l	NH <sub>3</sub> -N	18.59 mg/l		
	Phenolic Compounds	--	Phenolic Compounds	01 mg/l				Phenolic Compounds	2.73 mg/l	Phenolic Compounds	0.98 mg/l		



**M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch (GPCB ID: 10605)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5 MLD	pH	6.5 to 8.5	pH	6 to 9	28-09-2022	0.978*	--	pH	7.12	pH	8.23	Operational	Unit had lastly sent 10.02 MT of ETP sludge to Ambuja Cement Ltd. on 21/09/2022, manifest no. 1845492.  Present stock of ETP sludge is @ 10 MT.
	COD	2000 mg/L	COD	250 mg/L				COD	1102	COD	296		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	365	BOD	97		
	SS	800 mg/L	SS	100 mg/L				SS	136	SS	48		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	11.76	NH <sub>3</sub> -N	7.28		
	Phenolic Compounds	2 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.75	Phenolic Compounds	0.28		

- Total quantity of Waste water treated in CETP is 32.489 ML/month of August 2022.

**M/s CETP of Dahej Industrial Estate (GPCB ID: 50837)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5 to 8.5	pH	6 to 9	14.09.2022*	@1 MLD	Nil	pH	-	pH	7.15	CEQMS provided for TOC,COD, BOD TSS ,pH and Temperature Yet Not Connected with server	Filter press conveyor and storage shed provided. ETP sludge disposal to TSDf of BEIL Dahej.
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	216		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	49		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	10		
	NH <sub>3</sub> -N	150 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	BDL		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.24		

**\*Note : Wastewater receipt is much less than CETP’s capacity presently.**

**M/s Mangrol Enviro Protection LLP (MEPL) (GPCB ID: 72852)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1 MLD	pH	6.5 to-8.5pH unit	pH	6.6 to8.5 pH Unit	02-09-2022	1 MLD	NIL	pH	-	pH	8.25	No	Storage facility is provided. Member of TSDF, SEPPL
	COD	<400Mgl/1	COD	<40mg/1				COD	-	COD	98		
	BOD	<200mg/1	BOD	<30mg/1				BOD	-	BOD	28		
	SS	<200mg/1	SS	<10mg/1				SS	-	SS	12		
	NH <sub>3</sub> -N	In cca not mentioned	NH <sub>3</sub> -N	In cca not mentioned				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	1.14		
	Phenolic Compounds	In cca not mentioned	Phenolic Compounds	In cca not mentioned				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s Hojiwala Infrastructure Limited (GPCB ID: 47794)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10 MLD	pH	6.5 to-8.5pH unit	pH	6.6 to8.5 pH Unit	02-09-2022	20 MLD	NIL	pH	-	pH	7.70	No	Stock of CETP sludge @ 7.560 MT. Disposal – Nil.
	COD	<400Mgl/l	COD	<40mg/l				COD	-	COD	30		
	BOD	<200mg/l	BOD	<30mg/l				BOD	-	BOD	<5.0		
	SS	<200mg/l	SS	<10mg/l				SS	-	SS	2		
	NH <sub>3</sub> -N	In cca not mentioned	NH <sub>3</sub> -N	In cca not mentioned				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	1.14		
	Phenolic Compounds	In cca not mentioned	Phenolic Compounds	In cca not mentioned				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Gujarat Industrial Development Corporation (GPCB ID: 71763)**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6 to 6.5	pH	6 to 9	23.09.2022	*	Nil	pH	--	pH	--	Not Connected	Filter press with storage shed provided
	COD	3500 mg/L	COD	250 mg/L				COD	--	COD	--		
	BOD	1200 mg/L	BOD	100 mg/L				BOD	--	BOD	--		
	SS	400 mg/L	SS	100 mg/L				SS	--	SS	--		
	NH <sub>3</sub> -N	250 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	--	NH <sub>3</sub> -N	--		
	Phenolic Compounds	3 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	--	Phenolic Compounds	--		

**\*Note : Presently , CETP Saykha is under Stabilization stage and no treated waste water discharge from CETP. Waste water is being collected in inlet to CETP collection sump. Wastewater receipt is much less than CETP's capacity presently.**