

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2017	8.5	Nil	pH	8.01	pH	6.65	Flow Meter, TOC meter	Storage – 700 MT Disposal – 293 MT
	COD	750 mg/L	COD	250 mg/L				COD	814 mg/L	COD	268 mg/L		
	BOD (3 days at 27°C)	300 mg/L	BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	203 mg/L	BOD (3 days at 27°C)	35 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	264 mg/L	SS	94 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23 mg/L	NH ₃ -N	20 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.59 mg/L	Phenolic Compounds	BDL		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
55	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2017	55	Nil	pH	7.97	pH	7.35	pH, Flow Meter, TOC & DO Meter	Storage - 7000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1106 mg/L	COD	240 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	234 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	251 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58 mg/L	NH ₃ -N	27 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.14 mg/L	Phenolic Compounds	0.38 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of April - 2017	40	Nil	pH	7.85	pH	7.63	pH, Flow Meter, TOC	Storage - 80 MT Disposal – 614 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1100 mg/L	COD	226 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	330 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	108 mg/L	SS	166 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.51 mg/L	Phenolic Compounds	0.19 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of April - 2017	0.35	Nil	pH	7.81	pH	7.60	pH, TOC, TSS, Flow meter	Storage – 4 MT Disposal – 19 MT
	COD	4000 mg/L	COD	250 mg/L				COD	1340 mg/L	COD	230 mg/L		
	BOD	1500 mg/L	BOD	30 mg/L				BOD	360 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	118 mg/L	SS	36 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	13 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.71 mg/L	Phenolic Compounds	0.22 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2017	88	Nil	pH	7.53	pH	7.66	pH, Flow Meter, TOC, COD	Disposal – 929 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1088 mg/L	COD	226 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	325 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	188 mg/L	SS	71 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.32 mg/L	Phenolic Compounds	0.37 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of April - 2017	95	Nil	pH	7.85	pH	8.15	pH, Flow Meter, COD, BOD, TSS	Storage – 653 MT Disposal – 19 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1080 mg/L	COD	212 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	340 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	144 mg/L	SS	60 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.49 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2017	22	Nil	pH	7.94	pH	7.47	pH, Flow meter, COD, BOD, TSS	Storage - 50 MT
	COD	1000 mg/L	COD	100 mg/L				COD	1180 mg/L	COD	210 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	340 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	196 mg/L	SS	34 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.57 mg/L	Phenolic Compounds	0.16 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6.5 to 8.5	Average value of April - 2017	35	Nil	pH	7.21	pH	8.11	pH, Flow Meter, COD Meter including TOC	Storage - 150 MT
	COD		COD	100 mg/L				COD	1070 mg/L	COD	107 mg/L		
	BOD		BOD	30 mg/L				BOD	330 mg/L	BOD	22 mg/L		
	SS		SS	<60 mg/L				SS	274 mg/L	SS	14 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.37 mg/L	Phenolic Compounds	0.08 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	Not Furnished	pH	6.5 to 8.5	No visit in the month of April - 2017	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD		COD	100 mg/L				COD	-	COD	-		
	BOD		BOD	30 mg/L				BOD	-	BOD	-		
	SS		SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	Not Furnished	pH	5.5-8.5	Average value of April - 2017	0.35	Nil	pH	7.02	pH	7.63	pH, Flow Meter, TOC	Storage – 150 MT
	COD		COD	100 mg/L				COD	1828 mg/L	COD	457 mg/L		
	BOD		BOD	30 mg/L				BOD	546 mg/L	BOD	73 mg/L		
	SS		SS	100 mg/L				SS	226 mg/L	SS	107 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	60 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	1.5 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	Not Furnished	pH	5.5-8.5	Average value of April - 2017	1.10	Nil	pH	1.24	pH	7.55	pH, Flow, COD, BOD, TSS, TOC	Storage - Nil
	COD		COD	100 mg/L				COD	2971 mg/L	COD	473 mg/L		
	BOD (3 days at 27°C)		BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	886 mg/L	BOD (3 days at 27°C)	29 mg/L		
	SS		SS	100 mg/L				SS	207 mg/L	SS	216 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	50 mg/L	NH ₃ -N	31 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	27.26 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.)(BEAIL), Ankleshwar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	Not Furnished	pH	6-9	Average value of April - 2017	40	Nil	pH	7.48	pH	7.64	pH, Flow Meter, TOC, TSS	Storage – 2500 MT
	COD		COD	500 mg/L				COD	1298 mg/L	COD	488 mg/L		
	BOD		BOD	100 mg/L				BOD	398 mg/L	BOD	35 mg/L		
	SS		SS	100 mg/L				SS	70 mg/L	SS	48 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	360 mg/L	NH ₃ -N	189 mg/L		
	Phenolic Compounds		Phenolic Compounds	5 mg/L				Phenolic Compounds	2.05 mg/L	Phenolic Compounds	BDL		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of April - 2017	4.80	Nil	pH	7.36	pH	6.94	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	2000 mg/L	COD	250 mg/L				COD	1237 mg/L	COD	570 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	393 mg/L	BOD	109 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	408 mg/L	SS	164 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.57 mg/L	Phenolic Compounds	0.57 mg/L		

M/s. Enviro Infrastructure Co. Ltd., Umraya(Padra), Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of April - 2017	1.50	Nil	pH	7.26	pH	7.67	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	549 mg/L	COD	213 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	175 mg/L	BOD	39 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	128 mg/L	SS	54 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	15 mg/L	NH ₃ -N	10 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.42 mg/L	Phenolic Compounds	0.34 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April - 2017	3.00	Nil	pH	-	pH	-	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
16	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April - 2017	20	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April-2017	1.00	Nil	pH	-	pH	-	Flow meter at inlet & outlet, COD, pH, TSS, BOD	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April - 2017	0.60	Nil	pH	-	pH	-	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April - 2017	0.015	Nil	pH	-	pH	-	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April - 2017	0.60	Nil	pH	-	pH	-	Flow Meter	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of April - 2017	0.35	Nil	pH	-	pH	7.44	-	Disposal - 25 MT
	COD	2500 mg/L	COD	250 mg/L				COD	-	COD	1120 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	360 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	132 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydu Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of April - 2017	1.3	Nil	pH	-	pH	6.80	pH, TOC meter	-
	COD	850 mg/L	COD					COD	8 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	2 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	1 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of April - 2017	0.10	Nil	pH	-	pH	8.00	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	29 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	6 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	16 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	No CETP Designed Inlet Quality prescribed as it is a CETP of rice mill cluster	pH	6.5-8.5	Average value of April - 2017	1.00	Nil	pH	-	pH	7.97	-	Sludge is used as Manure
	COD		COD	250 mg/L				COD	-	COD	413 mg/L		
	BOD		BOD	100 mg/L				BOD	-	BOD	155 mg/L		
	SS		SS	100 mg/L				SS	-	SS	220 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	32 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	0.30 mg/L		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	No CETP Designed Inlet Quality prescribed as it is the CETP of Rice Mills	pH	6.5-8.5	Average value of April - 2017	1.50	Nil	pH	6.98	pH	7.90	-	Sludge is used as Manure
	COD		COD	250mg/L				COD	1667 mg/L	COD	106 mg/L		
	BOD		BOD	100 mg/L				BOD	661 mg/L	BOD	36 mg/L		
	SS		SS	100 mg/L				SS	138 mg/L	SS	25 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	1.08 mg/L	Phenolic Compounds	BDL		

M/s. Jay Khodiyar Enviro -Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Not Furnished	pH	6.5 to 8.5	No visit in the month of April - 2017	0.007	Nil	pH	-	pH	-	-	-
	COD		COD	250 mg/L				COD	-	COD	-		
	BOD		BOD	30 mg/L				BOD	-	BOD	-		
	SS		SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	Not Furnished	pH	6.5 to 8.5	Average value of April - 2017	7.00	Nil	pH	9.94	pH	7.40	pH, Flow meter	Storage – 5 MT
	COD		COD	250 mg/L				COD	1050 mg/L	COD	225 mg/L		
	BOD		BOD	30 mg/L				BOD	341 mg/L	BOD	68 mg/L		
	SS		SS	100 mg/L				SS	6256 mg/L	SS	5800 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	26 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	-	pH	6.5 to 8.5	No visit in the month of April - 2017	0.07	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	-	COD	250 mg/L				COD	-	COD	-		
	BOD	-	BOD	100 mg/L				BOD	-	BOD	-		
	SS	-	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	-	pH	6.5 to 8.5	Average value of month of April - 2017	6.00	Nil	pH	11.09	pH	8.84	pH, Flow meter, SS, Color, MLSS, COD	Storage – 1000 MT Disposal – 337 MT
	COD	-	COD	100 mg/L				COD	938 mg/L	COD	214 mg/L		
	BOD	-	BOD	30 mg/L				BOD	263 mg/L	BOD	55 mg/L		
	SS	-	SS	100 mg/L				SS	1680 mg/L	SS	3608 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of April - 2017	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2017	0.10	Nil	pH	7.38	pH	7.51	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	100 mg/L				COD	317 mg/L	COD	39 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	30 mg/L				BOD(3 days at 27° C)	104 mg/L	BOD(3 days at 27° C)	12 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	146 mg/L	SS	16 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	194 mg/L	NH ₃ -N	47 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		