

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	8.5	Nil	pH	7.39	pH	7.72	Flow Meter, TOC meter	Storage- 200 MT
	COD	750 mg/L	COD	250 mg/L				COD	810 mg/L	COD	278 mg/L		
	BOD (3 days at 27°C)	300 mg/L	BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	197 mg/L	BOD (3 days at 27°C)	36 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	83 mg/L	SS	78 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	2 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.43 mg/L	Phenolic Compounds	0.30 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	55	Nil	pH	7.40	pH	7.36	pH, Flow Meter, TOC & DO Meter	Storage – 17000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	907 mg/L	COD	268 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	239 mg/L	BOD	41 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	106 mg/L	SS	88 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58 mg/L	NH ₃ -N	49 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.57 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of August - 2017	40	Nil	pH	7.64	pH	7.79	pH, Flow Meter, TOC	Storage - 1200 MT
	COD	1000 mg/L	COD	250 mg/L				COD	920 mg/L	COD	274 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	152 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	152 mg/L	SS	400 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.82 mg/L	Phenolic Compounds	0.34 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2017	0.35	Nil	pH	7.97	pH	7.51	pH, TOC, Flow meter	Storage – 15 MT
	COD	4000 mg/L	COD	250 mg/L				COD	1552 mg/L	COD	263 mg/L		
	BOD	1500 mg/L	BOD	30 mg/L				BOD	200 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	322 mg/L	SS	44 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	21 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.70 mg/L	Phenolic Compounds	0.26 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	88	Nil	pH	7.59	pH	7.67	pH, Flow Meter, TOC, COD	Storage – 1700 MT
	COD	1000 mg/L	COD	250 mg/L				COD	968 mg/L	COD	273 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	190 mg/L	BOD	30 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	162 mg/L	SS	26 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	6 mg/L	NH ₃ -N	5 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.54 mg/L	Phenolic Compounds	0.28 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2017	95	Nil	pH	7.14	pH	7.85	pH, Flow Meter, COD, BOD, TSS	Storage – 750 MT Disposal – 86 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1494 mg/L	COD	278 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	311 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	188 mg/L	SS	200 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	30 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.27 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	22	Nil	pH	7.65	pH	7.64	pH, Flow meter, COD, BOD, TSS	Storage – 350 MT
	COD	1000 mg/L	COD	100 mg/L				COD	1520 mg/L	COD	99 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	320 mg/L	BOD	15 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	208 mg/L	SS	10 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	43 mg/L	NH ₃ -N	8 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.80 mg/L	Phenolic Compounds	0.22 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6.5 to 8.5	Average value of August - 2017	35	Nil	pH	7.12	pH	7.76	pH, Flow Meter, TOC meter	Storage – 70 MT Disposal – 10 MT
	COD		COD	100 mg/L				COD	1707 mg/L	COD	267 mg/L		
	BOD		BOD	30 mg/L				BOD	310 mg/L	BOD	30 mg/L		
	SS		SS	<60 mg/L				SS	240 mg/L	SS	64 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	45 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	1.13 mg/L	Phenolic Compounds	0.37 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	Not Furnished	pH	6.5 to 8.5	Average value of August - 2017	1.00	Nil	pH	7.05	pH	6.97	pH, Flow Meter	Storage – 1 MT Disposal – 5 MT
	COD		COD	100 mg/L				COD	424 mg/L	COD	254 mg/L		
	BOD		BOD	30 mg/L				BOD	100 mg/L	BOD	28 mg/L		
	SS		SS	<60 mg/L				SS	36 mg/L	SS	54 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.24 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	Not Furnished	pH	5.5-8.5	Average value of August - 2017	0.35	Nil	pH	6.80	pH	7.79	pH, Flow Meter, TOC	Storage – 24 MT
	COD		COD	100 mg/L				COD	1145 mg/L	COD	437 mg/L		
	BOD		BOD	30 mg/L				BOD	241 mg/L	BOD	28 mg/L		
	SS		SS	100 mg/L				SS	110 mg/L	SS	20 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	55 mg/L	NH ₃ -N	34 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	1.02 mg/L	Phenolic Compounds	0.45 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	Not Furnished	pH	5.5-8.5	Average value of August - 2017	1.10	Nil	pH	7.90	pH	8.02	pH, Flow, COD, BOD, TSS, TOC	Storage - Nil
	COD		COD	100 mg/L				COD	5798 mg/L	COD	903 mg/L		
	BOD (3 days at 27°C)		BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	612 mg/L	BOD (3 days at 27°C)	19 mg/L		
	SS		SS	100 mg/L				SS	270 mg/L	SS	20 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	66 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	1.62 mg/L	Phenolic Compounds	0.82 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.)(BEAIL), Ankleshwar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	Not Furnished	pH	6-9	Average value of August - 2017	40	Nil	pH	7.8	pH	7.48	pH, Flow Meter, TOC, TSS	Storage – 80 MT Disposal – 475 MT
	COD		COD	500 mg/L				COD	942 mg/L	COD	608 mg/L		
	BOD		BOD	100 mg/L				BOD	221 mg/L	BOD	29 mg/L		
	SS		SS	100 mg/L				SS	261 mg/L	SS	59 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	166 mg/L	NH ₃ -N	168 mg/L		
	Phenolic Compounds		Phenolic Compounds	5 mg/L				Phenolic Compounds	1.4 mg/L	Phenolic Compounds	0.62 mg/L		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of August - 2017	4.80	Nil	pH	7.71	pH	7.47	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	2000 mg/L	COD	250 mg/L				COD	1051 mg/L	COD	520 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	390 mg/L	BOD	61 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	628 mg/L	SS	82 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	45 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.66 mg/L	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya(Padra), Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of August - 2017	1.50	Nil	pH	7.57	pH	7.92	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	471 mg/L	COD	242 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	140 mg/L	BOD	60 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	272 mg/L	SS	40 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	3.00	Nil	pH	8.19	pH	8.19	-	Storage – 3500 MT
	COD	3000 mg/L	COD	250 mg/L				COD	4668 mg/L	COD	1104 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	1931 mg/L	BOD	369 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	432 mg/L	SS	217 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	180 mg/L	NH ₃ -N	43 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.07 mg/L	Phenolic Compounds	BDL		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
16	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	20	Nil	pH	7.18	pH	7.75	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	1679 mg/L	COD	955 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	675 mg/L	BOD	339 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	453 mg/L	SS	120 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	52 mg/L	NH ₃ -N	54 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.02 mg/L	Phenolic Compounds	BDL		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	1.00	Nil	pH	7.43	pH	7.11	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 72 MT
	COD	3000 mg/L	COD	250 mg/L				COD	672 mg/L	COD	196 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	286 mg/L	BOD	48 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	20 mg/L	SS	38 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	7 mg/L	NH ₃ -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.46 mg/L	Phenolic Compounds	0.87 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	0.60	Nil	pH	-	pH	7.69	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	310 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	125 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	60 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	0.015	Nil	pH	-	pH	7.73	-	Storage – 5 MT Disposal – 15 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	900 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	253 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	112 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	19 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2017	0.60	Nil	pH	4.44	pH	6.56	Flow Meter	Storage – 80 MT
	COD	3000 mg/L	COD	250 mg/L				COD	2924 mg/L	COD	140 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	1374 mg/L	BOD	43 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	22290 mg/L	SS	116 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	85 mg/L	NH ₃ -N	81 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2017	0.35	Nil	pH	7.22	pH	6.66	pH meter, flow meter, TOC meter	Storage - 20 MT
	COD	2500 mg/L	COD	250 mg/L				COD	1851 mg/L	COD	1511 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	974 mg/L	BOD	366 mg/L		
	SS	-	SS	100 mg/L				SS	488 mg/L	SS	162 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	40 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	8.61	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of August - 2017	1.3	Nil	pH	-	pH	6.60	pH, TOC meter	Storage – 25 MT
	COD	850 mg/L	COD					COD	6 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	2 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	3 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

M/s. Tata Motors Ltd, Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of August - 2017	0.10	Nil	pH	-	pH	8.10	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	34 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	12 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	8 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	4 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	No CETP Designed Inlet Quality prescribed as it is a CETP of rice mill cluster	pH	6.5-8.5	Average value of August - 2017	1.00	Nil	pH	-	pH	8.20	-	Sludge is used as Manure
	COD		COD	250 mg/L				COD	-	COD	47 mg/L		
	BOD		BOD	100 mg/L				BOD	-	BOD	15 mg/L		
	SS		SS	100 mg/L				SS	-	SS	4 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	No CETP Designed Inlet Quality prescribed as it is the CETP of Rice Mills	pH	6.5-8.5	Average value of August - 2017	1.50	Nil	pH	-	pH	7.97	-	Sludge is used as Manure
	COD		COD	250mg/L				COD	304 mg/L				
	BOD		BOD	100 mg/L				BOD	101 mg/L				
	SS		SS	100 mg/L				SS	110 mg/L				
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	40 mg/L				
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	BDL				

M/s. Jay Khodiyar Enviro -Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Not Furnished	pH	6.5 to 8.5	Average value of August - 2017	0.007	Nil	pH	1.44	pH	7.49	-	Storage – 500 kg Disposal – 10 MT
	COD		COD	250 mg/L				COD	26 mg/L	COD	8 mg/L		
	BOD		BOD	30 mg/L				BOD	6 mg/L	BOD	2 mg/L		
	SS		SS	100 mg/L				SS	30 mg/L	SS	20 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	17 mg/L	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	Not Furnished	pH	6.5 to 8.5	No sampling in the month of August - 2017	7.00	Nil	pH	-	pH	-	pH, Flow meter	-
	COD		COD	250 mg/L				COD	-	COD	-		
	BOD		BOD	30 mg/L				BOD	-	BOD	-		
	SS		SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	-	pH	6.5 to 8.5	No sampling from inlet and outlet in the month of August - 2017	0.07	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	-	COD	250 mg/L				COD	-	COD	-		
	BOD	-	BOD	100 mg/L				BOD	-	BOD	-		
	SS	-	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	-	pH	6.5 to 8.5	Average value of August - 2017	6.00	Nil	pH	10.79	pH	-	pH, Flow meter, SS, Color, MLSS, COD	Storage – 300 MT
	COD	-	COD	100 mg/L				COD	397 mg/L	COD	-		
	BOD	-	BOD	30 mg/L				BOD	127 mg/L	BOD	-		
	SS	-	SS	100 mg/L				SS	140 mg/L	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	6 mg/L	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No sampling in the month of August - 2017	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	No sampling in the month of August - 2017	0.10	Nil	pH	-	pH	-	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	30 mg/L				BOD(3 days at 27° C)	-	BOD(3 days at 27° C)	-		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		