

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	23	Nil	pH	7.47	pH	7.21	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 4000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1445 mg/L	COD	299 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	372 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	216 mg/L	SS	58 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	24 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.16 mg/L	Phenolic Compounds	0.23 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	1.1	Nil	pH	7.08	pH	7.42	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage-41 MT Disposal – 25 MT
	COD	2000 mg/L	COD	250 mg/L				COD	573 mg/L	COD	189 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	134 mg/L	BOD	64 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	166 mg/L	SS	54 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.79 mg/L	Phenolic Compounds	0.53 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	0.7	Nil	pH	6.37	pH	7.13	Flow Meter	Storage – 350 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1064 mg/L	COD	131 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	243 mg/L	BOD	36 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1762 mg/L	SS	56 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	93 mg/L	NH ₃ -N	54 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	BDL		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	0.8	Nil	pH	6.96	pH	7.39	-	Storage - 15 MT Disposal – 16 MT
	COD	750 mg/L	COD	250 mg/L				COD	533 mg/L	COD	214 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	256 mg/L	BOD	77 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	88 mg/L	SS	80 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	69 mg/L	NH ₃ -N	26 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.55 mg/L	Phenolic Compounds	0.15 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	4.5	Nil	pH	7.14	pH	7.57	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	4647 mg/L	COD	598 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	975 mg/L	BOD	105 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1940 mg/L	SS	122 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	92 mg/L	NH ₃ -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.89 mg/L	Phenolic Compounds	0.03 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.040	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	0.020	Nil	pH	7.49	pH	7.75	-	Storage-20 MT
	COD	1500 mg/L	COD	250 mg/L				COD	1981 mg/L	COD	1373 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	507 mg/L	BOD	327 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	852 mg/L	SS	392 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35 mg/L	NH ₃ -N	24 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.6 mg/L	Phenolic Compounds	0.33 mg/L		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	100	Nil	pH	6.59	pH	7.48	-	-
	COD	1200 mg/L	COD	250 mg/L				COD	847 mg/L	COD	281 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	341 mg/L	BOD	81 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	696 mg/L	SS	56 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	53 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.15 mg/L	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of August - 2019	0.10	Nil	pH	-	pH	7.21	pH, DO meter, TOC meter, Flow meter	Storage - 5 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	31 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	8 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	24 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of August - 2019	1.8	Nil	pH	7.27	pH	7.38	pH, TOC meter	Storage-25 MT
	COD	850 mg/L	COD					COD	284 mg/L	COD	14 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	108 mg/L	BOD (3 days at 27°C)	02 mg/L		
	SS	300 mg/L	SS					SS	78 mg/L	SS	08 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	26 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	No visit in the month of August - 2019	0.3	Nil	pH	-	pH	-	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of August - 2019	4	Nil	pH	-	pH	7.91	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	160 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	40 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	52 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	Average value of August - 2019	6.4	Nil	pH	-	pH	6.50	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	219 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	32 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	180 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of August - 2019	2.2	Nil	pH	-	pH	7.75	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	230 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	38 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	54 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds			

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	2.31	Nil	pH	6.85	pH	-	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	3049 mg/L	COD	-		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	612 mg/L	BOD (3 days at 27°C)	-		
	SS	-	SS	150 mg/L				SS	136 mg/L	SS	-		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	67 mg/L	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	2.77 mg/L	Phenolic Compounds	-		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	No sampling in August-2019	31.92	Nil	pH	-	pH	-	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	0.45	Nil	pH	6.99	pH	7.03	pH, Flow Meter, TOC	-
	COD	10000 mg/L	COD	1000 mg/L				COD	2595 mg/L	COD	687 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	545 mg/L	BOD	24 mg/L		
	SS	-	SS	150 mg/L				SS	284 mg/L	SS	68 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	78 mg/L	NH ₃ -N	38 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	9.63 mg/L	Phenolic Compounds	1.39 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2019	0.236	Nil	pH	7.35	pH	7.62	pH, TOC, TSS, Flow meter	-
	COD	3000 mg/L	COD	250 mg/L				COD	1057 mg/L	COD	184 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	264 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	250 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	32 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.41 mg/L	Phenolic Compounds	0.36 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of August - 2019	32.83	Nil	pH	7.04	pH	7.11	pH, Flow Meter, TOC	Storage-1700 MT
	COD	1000 mg/L	COD	250 mg/L				COD	767 mg/L	COD	259 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	152 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	412 mg/L	SS	90 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33 mg/L	NH ₃ -N	20 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.39 mg/L	Phenolic Compounds	0.85 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2019	98	Nil	pH	7.34	pH	7.7	pH, Flow Meter, COD, BOD, TSS	Storage-560 MT Disposal – 194 MT
	COD	1000 mg/L	COD	250 mg/L				COD	860 mg/L	COD	237 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	202 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	136 mg/L	SS	72 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	24 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.41 mg/L	Phenolic Compounds	0.47 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	81.5	Nil	pH	7.17	pH	7.61	pH, Flow Meter, TOC, COD	Storage-5500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1059 mg/L	COD	223 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	258 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	210 mg/L	SS	80 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	34 mg/L	NH ₃ -N	22 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.31 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.84	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	0.5	Nil	pH	7.32	pH	7.34	-	Storage-6 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	596 mg/L	COD	88 mg/L		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	118 mg/L	BOD	16 mg/L		
	SS	<150 mg/L	SS	<5 mg/L				SS	60 mg/L	SS	66 mg/L		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	6 mg/L	NH ₃ -N	5 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	1.36 mg/L	Phenolic Compounds	0.34 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	No visit in the month of August - 2019	29	Nil	pH	-	pH	-	pH, Flow Meter, COD Meter including TOC	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.75	pH	-	pH	6.5 to 8.5	Average value of August - 2019	1.39	Nil	pH	6.82	pH	6.95	pH, Flow Meter	Storage-8 MT
	COD	500 mg/L	COD	100 mg/L				COD	347 mg/L	COD	47 mg/L		
	BOD	200 mg/L	BOD	30 mg/L				BOD	72 mg/L	BOD	8 mg/L		
	SS	-	SS	<60 mg/L				SS	132 mg/L	SS	60 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.34 mg/L	Phenolic Compounds	0.45 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	25	Nil	pH	7.50	pH	7.38	pH, Flow meter, COD, BOD, TSS	Storage-1700 MT Disposal – 2965 MT
	COD	1000 mg/L	COD	250 mg/L				COD	910 mg/L	COD	182 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	216 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	210 mg/L	SS	60 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58 mg/L	NH ₃ -N	36 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.63 mg/L	Phenolic Compounds	0.34 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of August - 2019	54	Nil	pH	7.90	pH	7.57	pH, Flow Meter, TOC & DO Meter	Storage-16400 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1133 mg/L	COD	247 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	310 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	92 mg/L	SS	63 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	47 mg/L	NH ₃ -N	44 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	10.72 mg/L	Phenolic Compounds	0.47 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	9	Nil	pH	7.71	pH	7.81	Flow Meter, TOC meter	Storage-250 MT
	COD	1000 mg/L	COD	250 mg/L				COD	705 mg/L	COD	238 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	184 mg/L	BOD (3 days at 27°C)	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	46 mg/L	SS	28 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	2 mg/L	NH ₃ -N	44 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.81 mg/L	Phenolic Compounds	0.09 mg/L		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No sampling in the month of August - 2019	5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	No visit in the month of August - 2019	10	Nil	pH	-	pH	-	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	Average value of August - 2019	7.00	Nil	pH	-	pH	7.89	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	149 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	24 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	101 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	16 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of August - 2019	0.09	Nil	pH	7.14	pH	7.12	pH, Flow Meter	Storage-9 MT
	COD	1000 mg/L	COD	100 mg/L				COD	762 mg/L	COD	144 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	140 mg/L	BOD	38 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	308 mg/L	SS	30 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	10 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No visit in the month of August - 2019	0.013	Nil	pH	-	pH	-	-	-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.35	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of August - 2019	0.35	Nil	pH	-	pH	7.74	-	Storage – 21 MT Disposal – 11 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	138 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	17 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	38 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	5 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of August - 2019	0.15	Nil	pH	6.69	pH	6.71	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	408 mg/L	COD	78 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	104 mg/L	BOD(3 days at 27° C)	24 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	792 mg/L	SS	28 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.4 mg/L	Phenolic Compounds	0.0 mg/L		