

**M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	8.5	Nil	pH	7.21	pH	7.32	Flow Meter, TOC meter	Storage – 350 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1086 mg/L	COD	304 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	201 mg/L	BOD (3 days at 27°C)	34 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	212 mg/L	SS	67 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	44 mg/L	NH <sub>3</sub> -N	31 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.33 mg/L	Phenolic Compounds	0.34 mg/L		

**M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	55	Nil	pH	7.56	pH	7.67	pH, Flow Meter, TOC & DO Meter	Storage – 23,000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1496 mg/L	COD	390 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	220 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	270 mg/L	SS	41 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	82 mg/L	NH <sub>3</sub> -N	55 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.25 mg/L	Phenolic Compounds	0.51 mg/L		

**M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of December - 2017	40	Nil	pH	6.74	pH	7.53	pH, Flow Meter, TOC	Storage - 600 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1404 mg/L	COD	270 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	310 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	304 mg/L	SS	298 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	49 mg/L	NH <sub>3</sub> -N	36 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.70 mg/L	Phenolic Compounds	0.44 mg/L		

**M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of December - 2017	0.35	Nil	pH	6.83	pH	7.38	pH, TOC, TSS, Flow meter	Storage – 5 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1506 mg/L	COD	235 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	326 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	138 mg/L	SS	40 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	44 mg/L	NH <sub>3</sub> -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.74 mg/L	Phenolic Compounds	0.27 mg/L		

**M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	88	Nil	pH	7.27	pH	7.53	pH, Flow Meter, TOC, COD	Storage – 100 MT Disposal – 640 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1124 mg/L	COD	220 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	190 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	292 mg/L	SS	10 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	47 mg/L	NH <sub>3</sub> -N	17 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.62 mg/L	Phenolic Compounds	0.22 mg/L		

**M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of December - 2017	95	Nil	pH	7.37	pH	7.64	pH, Flow Meter, COD, BOD, TSS	Storage – 815 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1343 mg/L	COD	283 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	290 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	492 mg/L	SS	122 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	40 mg/L	NH <sub>3</sub> -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.27 mg/L		

**M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	22	Nil	pH	7.51	pH	7.99	pH, Flow meter, COD, BOD, TSS	Storage – 50 MT Disposal – 261 MT
	COD	1000 mg/L	COD	250 mg/L				COD	989 mg/L	COD	120 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	252 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	318 mg/L	SS	28 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	37 mg/L	NH <sub>3</sub> -N	9 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.15 mg/L		

**M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of December - 2017	35	Nil	pH	7.70	pH	7.96	pH, Flow Meter, COD Meter including TOC	Storage -110 MT Disposal – 99 MT
	COD	1000 mg/L	COD	250 mg/L				COD	624 mg/L	COD	190 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	150 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	166 mg/L	SS	162 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	38 mg/L	NH <sub>3</sub> -N	19 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.43 mg/L	Phenolic Compounds	0.23 mg/L		



**M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	Average value of December - 2017	1.00	Nil	pH	6.90	pH	7.46	pH, Flow Meter	Storage – 3 MT Disposal – 5 MT
	COD	500 mg/L	COD	100 mg/L				COD	522 mg/L	COD	69 mg/L		
	BOD	200 mg/L	BOD	30 mg/L				BOD	125 mg/L	BOD	15 mg/L		
	SS	-	SS	<60 mg/L				SS	72 mg/L	SS	14 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.21 mg/L	Phenolic Compounds	0.03 mg/L		

**M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	-	pH	5.5-8.5	Average value of December - 2017	0.35	Nil	pH	7.21	pH	7.72	pH, Flow Meter, TOC	Storage – 17 MT Disposal – 521 MT
	COD	10000 mg/L	COD	500 mg/L				COD	2039 mg/L	COD	673 mg/L		
	BOD	3500 mg/L	BOD	100 mg/L				BOD	317 mg/L	BOD	52 mg/L		
	SS	-	SS	100 mg/L				SS	244 mg/L	SS	106 mg/L		
	NH <sub>3</sub> -N	100 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	66 mg/L	NH <sub>3</sub> -N	45 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.22 mg/L	Phenolic Compounds	0.82 mg/L		

**M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of December - 2017	1.10	Nil	pH	1.48	pH	7.9	pH, Flow, COD, BOD, TSS, TOC	Storage - Nil
	COD	11000 mg/L	COD	1000 mg/L				COD	3625 mg/L	COD	842 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	714 mg/L	BOD (3 days at 27°C)	26 mg/L		
	SS	-	SS	100 mg/L				SS	176 mg/L	SS	46 mg/L		
	NH <sub>3</sub> -N	100 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	77 mg/L	NH <sub>3</sub> -N	23 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	4.09 mg/L	Phenolic Compounds	0.98 mg/L		

**M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.)(BEAIL), Ankleshwar**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of December - 2017	40	Nil	pH	7.47	pH	7.68	pH, Flow Meter, TOC, TSS	Storage – 100 MT Disposal – 969 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1929 mg/L	COD	869 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	528 mg/L	BOD	28 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	247 mg/L	SS	76 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	245 mg/L	NH <sub>3</sub> -N	213 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	2.04 mg/L	Phenolic Compounds	1.21 mg/L		

**M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of December - 2017	4.80	Nil	pH	6.94	pH	6.98	pH, COD, BOD, TSS, NH <sub>3</sub> -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1014 mg/L	COD	171 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	262 mg/L	BOD	26 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	336 mg/L	SS	122 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	32 mg/L	NH <sub>3</sub> -N	0.84 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.8 mg/L	Phenolic Compounds	0.72 mg/L		

**M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of December - 2017	1.50	Nil	pH	7.41	pH	7.94	pH, Flow Meter, TOC, TSS, Color, NH <sub>3</sub> -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	665 mg/L	COD	288 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	194 mg/L	BOD	42 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	120 mg/L	SS	6 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	19 mg/L	NH <sub>3</sub> -N	15 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.18 mg/L	Phenolic Compounds	BDL		

**M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	3.00	Nil	pH	7.46	pH	7.69	-	Storage- 3500 MT
	COD	2000 mg/L	COD	250 mg/L				COD	4612 mg/L	COD	480 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	1815 mg/L	BOD	151 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	956 mg/L	SS	208 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	207 mg/L	NH <sub>3</sub> -N	10 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.62 mg/L	Phenolic Compounds	BDL		

**M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	20	Nil	pH	7.78	pH	7.65	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	2000 mg/L	COD	250 mg/L				COD	2536 mg/L	COD	1224 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	1288 mg/L	BOD	407 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1305 mg/L	SS	164 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	85 mg/L	NH <sub>3</sub> -N	57 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.93 mg/L	Phenolic Compounds	BDL		



**M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	1.00	Nil	pH	7.25	pH	7.73	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage –60 MT
	COD	2000 mg/L	COD	250 mg/L				COD	866 mg/L	COD	398 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	360 mg/L	BOD	131 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	188 mg/L	SS	72 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	39 mg/L	NH <sub>3</sub> -N	24 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.55 mg/L	Phenolic Compounds	0.96 mg/L		

**M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	0.60	Nil	pH	-	pH	7.85	-	-
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	539 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	173 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	343 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	63 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of December - 2017	0.015	Nil	pH	-	pH	-	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	0.60	Nil	pH	-	pH	7.30	Flow Meter	Storage – 250 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	204 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	73 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	16 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	95 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of December - 2017	0.35	Nil	pH	6.72	pH	7.98	-	Storage – 40 MT
	COD	2000 mg/L	COD	250 mg/L				COD	3487 mg/L	COD	681 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	1318 mg/L	BOD	224 mg/L		
	SS	-	SS	100 mg/L				SS	517 mg/L	SS	172 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	22 mg/L	NH <sub>3</sub> -N	60 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	8.22 mg/L	Phenolic Compounds	BDL		

**M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of December - 2017	1.3	Nil	pH	-	pH	7.12	pH, TOC meter	Storage – 40 MT
	COD	850 mg/L	COD					COD	6 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	2 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH <sub>3</sub> -N	<10 mg/L	NH <sub>3</sub> -N					NH <sub>3</sub> -N	6 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

**M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of December - 2017	0.10	Nil	pH	-	pH	8.32	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	35 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	9 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	8 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	5 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of December - 2017	1.00	Nil	pH	-	pH	7.80	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	575 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	169 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	240 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	40 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		



**M/s. Vinayak Jal SudhikaranSahakariMandali Ltd, Bavla, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of December - 2017	1.50	Nil	pH	-	pH	8.09	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250mg/L				COD	-	COD	180 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	51 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	306 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	11 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Jay Khodiyar Enviro -Technologies Pvt. Ltd., Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No visit in the month of December - 2017	0.007	Nil	pH	-	pH	-	-	-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	No visit in the month of December - 2017	7.00	Nil	pH	-	pH	-	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of December - 2017	0.07	Nil	pH	6.64	pH	6.68	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	2416 mg/L	COD	554 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	846 mg/L	BOD	187 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	630 mg/L	SS	80 mg/L		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	45 mg/L	NH <sub>3</sub> -N	35 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Bhatgam Washing GhatSuddhikaranYojana Pvt. Ltd., Bhatgam, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of December - 2017	6.00	Nil	pH	10.22	pH	7.94	pH, Flow meter, SS, Color, MLSS, COD	Storage – 110 MT
	COD	1000 mg/L	COD	100 mg/L				COD	210 mg/L	COD	62 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	73 mg/L	BOD	19 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	280 mg/L	SS	40 mg/L		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	3 mg/L	NH <sub>3</sub> -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Veraval Industries Association, Veraval, Junagadh**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	Average value of December - 2017	1.5	Nil	pH	6.69	pH	7.25	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	1434 mg/L	COD	343 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	631 mg/L	BOD	133 mg/L		
	SS	200 mg/L	SS	100 mg/L				SS	252 mg/L	SS	88 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	392 mg/L	NH <sub>3</sub> -N	330 mg/L		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2017	0.10	Nil	pH	6.87	pH	6.98	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	329 mg/L	COD	132 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	102 mg/L	BOD(3 days at 27° C)	39 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	60 mg/L	SS	14 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	7 mg/L	NH <sub>3</sub> -N	6 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.2 mg/L	Phenolic Compounds	0.1 mg/L		