

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of February - 2019	20	Nil	pH	7.70	pH	7.14	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 1300 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1260 mg/L	COD	372 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	297 mg/L	BOD	33 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	206 mg/L	SS	112 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	47 mg/L	NH ₃ -N	18 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.81 mg/L	Phenolic Compounds	0.35 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of February – 2019	1.00	Nil	pH	-	pH	-	Flow meter at inlet & outlet, COD, pH, TSS, BOD	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of Februart - 2019	0.60	Nil	pH	-	pH	-	Flow Meter	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of Februart - 2019	0.60	Nil	pH	-	pH	-	-	-
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	3.00	Nil	pH	7.74	pH	7.16	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	3238 mg/L	COD	1890 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	548 mg/L	BOD	494 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	296 mg/L	SS	295 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	50 mg/L	NH ₃ -N	62 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.18 mg/L	Phenolic Compounds	6.17 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	0.015	Nil	pH	8.12	pH	7.91	-	Storage – 15 MT Disposal – 18 MT
	COD	1500 mg/L	COD	250 mg/L				COD	1933 mg/L	COD	181 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	529 mg/L	BOD	35 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1193 mg/L	SS	68 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	326 mg/L	NH ₃ -N	13 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.63 mg/L	Phenolic Compounds	0.01 mg/L		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	100	Nil	pH	7.19	pH	7.84	-	Storage – 150-200 MT
	COD	1200 mg/L	COD	250 mg/L				COD	860 mg/L	COD	398 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	380 mg/L	BOD	84 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	576 mg/L	SS	160 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	71 mg/L	NH ₃ -N	60 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.84 mg/L	Phenolic Compounds	0.15 mg/L		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	No Visit in the month of February - 2019	0.10	Nil	pH	-	pH	-	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	No Visit in the month of February - 2019	1.3	Nil	pH	-	pH	-	pH, TOC meter	-
	COD	850 mg/L	COD					COD	-				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	-				
	SS	300 mg/L	SS					SS	-				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	-				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	-				

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	No Visit in the month of February - 2019	1.00	Nil	pH	-	pH	-	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	No Visit in the month of February - 2019	1.50	Nil	pH	-	pH	-	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of Februart - 2019	4.80	Nil	pH	7.062	pH	6.92	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	936 mg/L	COD	243 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	122 mg/L	BOD	24 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	255 mg/L	SS	52 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of Februart - 2019	1.50	Nil	pH	7.58	pH	7.94	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	574 mg/L	COD	279 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	79 mg/L	BOD	36 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	108 mg/L	SS	62 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	9 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of Februart - 2019	1.10	Nil	pH	7.27	pH	7.35	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	3977 mg/L	COD	683 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	1051 mg/L	BOD (3 days at 27°C)	24 mg/L		
	SS	-	SS	100 mg/L				SS	1112 mg/L	SS	30 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	80 mg/L	NH ₃ -N	41 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	12.65 mg/L	Phenolic Compounds	0.55 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of February - 2019	40	Nil	pH	7.75	pH	7.25	pH, Flow Meter, TOC, TSS	Storage – 200 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1209 mg/L	COD	587 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	273 mg/L	BOD	18 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	155 mg/L	SS	40 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	121 mg/L	NH ₃ -N	63 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	1.67 mg/L	Phenolic Compounds	1.24 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	0.35	Nil	pH	7.28	pH	7.69	pH, Flow Meter, TOC	Storage – 145 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2214 mg/L	COD	808 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	552 mg/L	BOD	26 mg/L		
	SS	-	SS	150 mg/L				SS	192 mg/L	SS	108 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	47 mg/L	NH ₃ -N	41 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	4.46 mg/L	Phenolic Compounds	0.36 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of February - 2019	0.35	Nil	pH	-	pH	7.635	pH, TOC, TSS, Flow meter	Storage – 25 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	578 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	121 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	127 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	104 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	21 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of February - 2019	40	Nil	pH	7.28	pH	7.705	pH, Flow Meter, TOC	Storage – 900 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1669 mg/L	COD	918 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	751 mg/L	BOD	402 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	282 mg/L	SS	181 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23 mg/L	NH ₃ -N	47 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.49 mg/L	Phenolic Compounds	0.43 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	No Visit in the month of February - 2019	95	Nil	pH	-	pH	-	pH, Flow Meter, COD, BOD, TSS	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	88	Nil	pH	7.02	pH	7.515	pH, Flow Meter, TOC, COD	Storage – 150 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1136 mg/L	COD	716 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	557 mg/L	BOD	271 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	228 mg/L	SS	69 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	47 mg/L	NH ₃ -N	48 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	01.825 mg/L	Phenolic Compounds	4.03 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	No Visit in the month of Februart - 2019	35	Nil	pH	-	pH	-	pH, Flow Meter, COD Meter including TOC	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	No visit in the month of February - 2019	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	22	Nil	pH	7.67	pH	8.05	pH, Flow meter, COD, BOD, TSS	Storage - 60 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1461 mg/L	COD	345 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	763 mg/L	BOD	87 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	196 mg/L	SS	272 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.30 mg/L	Phenolic Compounds	BDL		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of February - 2019	55	Nil	pH	7.98	pH	7.34	pH, Flow Meter, TOC & DO Meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	1047 mg/L	COD	260 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	248 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	166 mg/L	SS	63 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	52 mg/L	NH ₃ -N	43 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	8.053 mg/L	Phenolic Compounds	0.759 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of Februart - 2019	8.5	Nil	pH	7.75	pH	8.12	Flow Meter, TOC meter	Storage – 450 MT
	COD	1000 mg/L	COD	250 mg/L				COD	707 mg/L	COD	147 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	177 mg/L	BOD (3 days at 27°C)	18 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	108 mg/L	SS	33 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.877 mg/L	Phenolic Compounds	0.321		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of February – 2019	6.00	Nil	pH	10.99	pH	8.87	pH, Flow meter, SS, Color, MLSS, COD	Storage – 120 MT
	COD	1000 mg/L	COD	100 mg/L				COD	1329 mg/L	COD	462 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	213 mg/L	BOD	54 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	610 mg/L	SS	170 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	140 mg/L	NH ₃ -N	0.280 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	Average value of Februart - 2019	7.00	Nil	pH	9.135	pH	-	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	2091 mg/L	COD	-		
	BOD	350 mg/L	BOD	100 mg/L				BOD	646 mg/L	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	422 mg/L	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20.20 mg/L	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	No visit in the month of February - 2019	0.07	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of Februart - 2019	0.007	Nil	pH	1.40	pH	7.30	-	Disposal – 10 MT
	COD	250 mg/L	COD	100 mg/L				COD	64 mg/L	COD	10 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	14 mg/L	BOD	3 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	56 mg/L	SS	94 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	8 mg/L	NH ₃ -N	0.558 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of Februart - 2019	0.35	Nil	pH	7.7	pH	7.31	-	Disposal – 25 MT
	COD	2000 mg/L	COD	250 mg/L				COD	561 mg/L	COD	384 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	165 mg/L	BOD	62 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	92 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	8 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.09 mg/L		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of February - 2019	0.10	Nil	pH	-	pH	7.13	pH, COD, BOD, TSS, Ammonical Nitrogen	
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	58 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	-	BOD(3 days at 27° C)	23 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	10 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.2 mg/L		