

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Sachin Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|--|----------|------------------------------------|--|
| | | | | | | | | | | | | | |
| 16 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 23 | Nil | pH | 7.32 | pH | 7.10 | pH, Flow Meter, TOC, COD, BOD, TSS | - |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | 928 mg/L | COD | 498 mg/L | | |
| | BOD | 700 mg/L | BOD | 30 mg/L | | | | BOD | 280 mg/L | BOD | 67 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 150 mg/L | SS | 56 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 41 mg/L | NH ₃ -N | 17 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.56 mg/L | Phenolic Compounds | BDL | | |

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|-------------------------------|--|
| | | | | | | | | | | | | | |
| 1.2 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 1.1 | Nil | pH | 7.35 | pH | 6.52 | Flow meter, COD, pH, TSS, BOD | Storage – 70 MT |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | 789 mg/L | COD | 269 mg/L | | |
| | BOD | 700 mg/L | BOD | 30 mg/L | | | | BOD | 288 mg/L | BOD | 49 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 417 mg/L | SS | 42 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 28 mg/L | NH ₃ -N | 5 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.32 mg/L | Phenolic Compounds | 0.29 mg/L | | |

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|------------------------|--|
| | | | | | | | | | | | | | |
| 0.45 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.7 | Nil | pH | 6.99 | pH | 6.99 | Flow Meter | Storage – 550 MT |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | 283 mg/L | COD | 821 mg/L | | |
| | BOD | 700 mg/L | BOD | 30 mg/L | | | | BOD | 72 mg/L | BOD | 236 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 124 mg/L | SS | 3727 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 179 mg/L | NH ₃ -N | 176 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.47 mg/L | Phenolic Compounds | 0.11 mg/L | | |

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|------------------------|--|
| | | | | | | | | | | | | | |
| 1.00 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.8 | Nil | pH | 7.29 | pH | 7.49 | - | - |
| | COD | 750 mg/L | COD | 250 mg/L | | | | COD | 858 mg/L | COD | 462 mg/L | | |
| | BOD | 250 mg/L | BOD | 30 mg/L | | | | BOD | 399 mg/L | BOD | 165 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 525 mg/L | SS | 335 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 35 mg/L | NH ₃ -N | 57 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.71 mg/L | Phenolic Compounds | 0.47 mg/L | | |

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|------------------------|--|
| | | | | | | | | | | | | | |
| 3.00 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 4.5 | Nil | pH | 7.88 | pH | 7.25 | - | Storage – 4000 MT |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | 3174 mg/L | COD | 542 mg/L | | |
| | BOD | 700 mg/L | BOD | 30 mg/L | | | | BOD | 895 mg/L | BOD | 125 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 430 mg/L | SS | 232 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 130 mg/L | NH ₃ -N | 22 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 2.54 mg/L | Phenolic Compounds | 0.23 mg/L | | |

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|---------|------------------------|--|
| | | | | | | | | | | | | | |
| 0.040 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.020 | Nil | pH | 8.25 | pH | 8.25 | - | Storage – 20 MT Disposal – 23 MT |
| | COD | 1500 mg/L | COD | 250 mg/L | | | | COD | 1317 mg/L | COD | 81 mg/L | | |
| | BOD | 500 mg/L | BOD | 30 mg/L | | | | BOD | 354 mg/L | BOD | 13 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 158 mg/L | SS | 22 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 367 mg/L | NH ₃ -N | 9 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.58 mg/L | Phenolic Compounds | BDL | | |

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|------------------------|--|
| | | | | | | | | | | | | | |
| 100 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 100 | Nil | pH | 6.83 | pH | 7.65 | - | - |
| | COD | 1200 mg/L | COD | 250 mg/L | | | | COD | 1031 mg/L | COD | 158 mg/L | | |
| | BOD | 500 mg/L | BOD | 30 mg/L | | | | BOD | 277 mg/L | BOD | 45 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 500 mg/L | SS | 74 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 53 mg/L | NH ₃ -N | 32 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.79 mg/L | Phenolic Compounds | 0.26 mg/L | | |

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|----------------|--|----------|-----------------------------|-----------------------------------|--|------------------------|---|---------------------------------|---------|-------------------------------------|--|
| | | | | | | | | | | | | | |
| 1.5 | pH | 6-10.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.10 | Nil | pH | - | pH | 7.57 | pH, DO meter, TOC meter, Flow meter | Storage - 6 MT |
| | COD | 900 mg/L | COD | 100 mg/L | | | | COD | - | COD | - | | |
| | BOD | 250 mg/L | BOD | 30 mg/L | | | | BOD | - | BOD | 8 mg/L | | |
| | SS | 100 mg/L | SS | 100 mg/L | | | | SS | - | SS | 18 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | - | | |
| | Phenolic Compounds | Not Applicable | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|----------------------|----------|--|--|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|--------|------------------------|--|
| | | | | | | | | | | | | | |
| 3 | pH | 6- 8 | pH | No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE | Average value of Jan - 2020 | 1.8 | Nil | pH | 7.41 | pH | 6.67 | pH, TOC meter | Storage – 12 MT |
| | COD | 850 mg/L | COD | | | | | COD | 556 mg/L | COD | 6 mg/L | | |
| | BOD (3 days at 27°C) | 400 mg/L | BOD (3 days at 27°C) | | | | | BOD (3 days at 27°C) | 257 mg/L | BOD (3 days at 27°C) | 1 mg/L | | |
| | SS | 300 mg/L | SS | | | | | SS | 38 mg/L | SS | 4 mg/L | | |
| | NH ₃ -N | <10 mg/L | NH ₃ -N | | | | | NH ₃ -N | 18 mg/L | NH ₃ -N | 1 mg/L | | |
| | Phenolic Compounds | <3 mg/L | Phenolic Compounds | | | | | Phenolic Compounds | 0.79 mg/L | Phenolic Compounds | BDL | | |

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------------|-----------------------------|-----------------------------------|--|------------------------|---|---------------------------------|----------|------------------------|--|
| | | | | | | | | | | | | | |
| 1.00 | pH | 5.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.3 | Nil | pH | - | pH | 7.05 | - | - |
| | COD | 4500 mg/L | COD | 250 mg/L | | | | COD | - | COD | 187 mg/L | | |
| | BOD | 1500 mg/L | BOD | 100 mg/L | | | | BOD | - | BOD | 67 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | - | SS | 64 mg/L | | |
| | NH ₃ -N | - | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | 7 mg/L | | |
| | Phenolic Compounds | - | Phenolic Compounds | Not Applicable | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------------|-----------------------------|-----------------------------------|--|------------------------|---|---------------------------------|----------|------------------------|--|
| | | | | | | | | | | | | | |
| 1.50 | pH | 5.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 4 | Nil | pH | - | pH | 8.04 | - | - |
| | COD | 4500 mg/L | COD | 250 mg/L | | | | COD | - | COD | 177 mg/L | | |
| | BOD | 1500 mg/L | BOD | 100 mg/L | | | | BOD | - | BOD | 60 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | - | SS | 44 mg/L | | |
| | NH ₃ -N | - | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | 13 mg/L | | |
| | Phenolic Compounds | - | Phenolic Compounds | Not Applicable | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|------------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|----------|--|--|
| | | | | | | | | | | | | | |
| 12 | pH | 5 to 9 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 6.4 | Nil | pH | 6.87 | pH | 6.52 | pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature | - |
| | COD | 1500 mg/L | COD | 250 mg/L | | | | COD | 1535 mg/L | COD | 207 mg/L | | |
| | BOD | 500 mg/L | BOD | 100 mg/L | | | | BOD | 320 mg/L | BOD | 26 mg/L | | |
| | SS | 600 mg/L | SS | 100 mg/L | | | | SS | 448 mg/L | SS | 128 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 638 mg/L | NH ₃ -N | 1 mg/L | | |
| | Phenolic Compounds | 5 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|------------|-----------------------------|-----------------------------------|--|------------------------|---|---------------------------------|----------|---|--|
| | | | | | | | | | | | | | |
| 4.50 | pH | 5 to 9 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 2.2 | Nil | pH | - | pH | 7.75 | pH, Flow Meter, TOC, TSS, Color, NH ₃ -N | - |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | - | COD | 234 mg/L | | |
| | BOD | 500 mg/L | BOD | 100 mg/L | | | | BOD | - | BOD | 38 mg/L | | |
| | SS | 600 mg/L | SS | 100 mg/L | | | | SS | - | SS | 152 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | 12 mg/L | | |
| | Phenolic Compounds | 5 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|----------------------|------------|--|-----------|-----------------------------|-----------------------------------|--|------------------------|------------|---------------------------------|-----------|------------------------------|--|
| | | | | | | | | | | | | | |
| 3.5 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 2.31 | Nil | pH | 7.02 | pH | 7.28 | pH, Flow, COD, BOD, TSS, TOC | - |
| | COD | 11000 mg/L | COD | 1000 mg/L | | | | COD | 3031 mg/L | COD | 785 mg/L | | |
| | BOD (3 days at 27°C) | 3600 mg/L | BOD (3 days at 27°C) | 200 mg/L | | | | BOD (3 days at 27°C) | 524 mg/L | BOD (3 days at 27°C) | 24 mg/L | | |
| | SS | - | SS | 150 mg/L | | | | SS | 942 mg/L | SS | 84 mg/L | | |
| | NH ₃ -N | 100 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 68 mg/L | NH ₃ -N | 55 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 5 mg/L | | | | Phenolic Compounds | 11.18 mg/L | Phenolic Compounds | 0.46 mg/L | | |

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|--------------------------|--|
| | | | | | | | | | | | | | |
| 40 | pH | 6.5-8.5 | pH | 6-9 | Average value of Jan - 2020 | 31.92 | Nilfg | pH | 7.30 | pH | 8.03 | pH, Flow Meter, TOC, TSS | Storage – 1500 MT |
| | COD | 1000 mg/L | COD | 500 mg/L | | | | COD | 769 mg/L | COD | 1039 mg/L | | |
| | BOD | 200 mg/L | BOD | 100 mg/L | | | | BOD | 68 mg/L | BOD | 150 mg/L | | |
| | SS | 150 mg/L | SS | 100 mg/L | | | | SS | 40 mg/L | SS | 186 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 140 mg/L | NH ₃ -N | 118 mg/L | | |
| | Phenolic Compounds | 5 mg/L | Phenolic Compounds | 5 mg/L | | | | Phenolic Compounds | 0.51 mg/L | Phenolic Compounds | 8.97 mg/L | | |

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|------------|--|-----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|----------|------------------------|--|
| | | | | | | | | | | | | | |
| 1.02 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.45 | Nil | pH | 6.78 | pH | 7.44 | pH, Flow Meter, TOC | Storage – 150 MT |
| | COD | 10000 mg/L | COD | 1000 mg/L | | | | COD | 4182 mg/L | COD | 816 mg/L | | |
| | BOD | 3000 mg/L | BOD | 200 mg/L | | | | BOD | 615 mg/L | BOD | 32 mg/L | | |
| | SS | - | SS | 150 mg/L | | | | SS | 1256 mg/L | SS | 42 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 121 mg/L | NH ₃ -N | 60 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 1.90 mg/L | Phenolic Compounds | 0.1 mg/L | | |

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|------------|--|------------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|--------------------------|--|
| | | | | | | | | | | | | | |
| 1 | pH | 6.5 to 8.5 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 0.236 | Nil | pH | 6.76 | pH | 7.60 | pH, TOC, TSS, Flow meter | Storage – 1800 MT |
| | COD | 3000 mg/L | COD | 250 mg/L | | | | COD | 1825 mg/L | COD | 189 mg/L | | |
| | BOD | 1200 mg/L | BOD | 30 mg/L | | | | BOD | 399 mg/L | BOD | 21 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 284 mg/L | SS | 54 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 52 mg/L | NH ₃ -N | 38 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 1.50 mg/L | Phenolic Compounds | 0.60 mg/L | | |

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|----------------------|-----------------------|------------------|--|----------|-----------------------------------|---|--|------------------------|-----------|------------------------------------|-----------|------------------------------|---|
| | | | | | | | | | | | | | |
| 50 | pH | Not Furnished | pH | 6.5-8.5 | Average value of Jan - 2020 | 32.83 | Nil | pH | 7.38 | pH | 7.46 | pH, Flow Meter, TOC | Storage – 350 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 892 mg/L | COD | 221 mg/L | | |
| | BOD | 400 mg/L | BOD | 30 mg/L | | | | BOD | 192 mg/L | BOD | 23 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 210 mg/L | SS | 72 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 22 mg/L | NH ₃ -N | 18 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 01 mg/L | | | | Phenolic Compounds | 1.09 mg/L | Phenolic Compounds | 0.45 mg/L | | |

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|------------|--|------------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|-------------------------------|--|
| | | | | | | | | | | | | | |
| 150 | pH | 6.5 to 8.5 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 98 | Nil | pH | 7.78 | pH | 7.96 | pH, Flow Meter, COD, BOD, TSS | Storage - 600 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 912 mg/L | COD | 204 mg/L | | |
| | BOD | 400 mg/L | BOD | 30 mg/L | | | | BOD | 182 mg/L | BOD | 22 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 180 mg/L | SS | 94 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 27 mg/L | NH ₃ -N | 18 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 1.09 mg/L | Phenolic Compounds | 0.57 mg/L | | |

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|--------------------------|--|
| | | | | | | | | | | | | | |
| 100 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 81.5 | Nil | pH | 7.30 | pH | 7.90 | pH, Flow Meter, TOC, COD | Storage - 1000 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 908 mg/L | COD | 210 mg/L | | |
| | BOD | 400 mg/L | BOD | 30 mg/L | | | | BOD | 199 mg/L | BOD | 22 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 230 mg/L | SS | 40 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 22 mg/L | NH ₃ -N | 16 mg/L | | |
| | Phenolic Compounds | 01 mg/L | Phenolic Compounds | 01 mg/L | | | | Phenolic Compounds | 1.20 mg/L | Phenolic Compounds | 0.71 mg/L | | |

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|---|---------------------------------|-----------|------------------------|--|
| | | | | | | | | | | | | | |
| 0.84 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.5 | Nil | pH | - | pH | 7.28 | - | Storage - 8 MT |
| | COD | <500 mg/L | COD | <20 mg/L | | | | COD | - | COD | 32 mg/L | | |
| | BOD | <200 mg/L | BOD | <5 mg/L | | | | BOD | - | BOD | 4 mg/L | | |
| | SS | <150 mg/L | SS | <5 mg/L | | | | SS | - | SS | 72 mg/L | | |
| | NH ₃ -N | - | NH ₃ -N | - | | | | NH ₃ -N | - | NH ₃ -N | BDL | | |
| | Phenolic Compounds | - | Phenolic Compounds | - | | | | Phenolic Compounds | - | Phenolic Compounds | 0.46 mg/L | | |

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|------------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|---|--|
| | | | | | | | | | | | | | |
| 60 | pH | 6.5-8.5 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 29 | Nil | pH | 7.51 | pH | 7.35 | pH, Flow Meter, COD Meter including TOC | Storage – 200 MT Disposal - 623 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 870 mg/L | COD | 178 mg/L | | |
| | BOD | 400 mg/L | BOD | 100 mg/L | | | | BOD | 189 mg/L | BOD | 21 mg/L | | |
| | SS | 300 mg/L | SS | <60 mg/L | | | | SS | 196 mg/L | SS | 92 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 32 mg/L | NH ₃ -N | 27 mg/L | | |
| | Phenolic Compounds | - | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 1.35 mg/L | Phenolic Compounds | 0.68 mg/L | | |

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|----------|--|------------|-----------------------------|-----------------------------------|--|------------------------|----------|---------------------------------|---------|------------------------|--|
| | | | | | | | | | | | | | |
| 3.75 | pH | - | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 1.39 | Nil | pH | 6.92 | pH | 7.35 | pH, Flow Meter | Storage – 2 MT Disposal – 5 MT |
| | COD | 500 mg/L | COD | 100 mg/L | | | | COD | 256 mg/L | COD | 37 mg/L | | |
| | BOD | 200 mg/L | BOD | 30 mg/L | | | | BOD | 36 mg/L | BOD | 6 mg/L | | |
| | SS | - | SS | <60 mg/L | | | | SS | 126 mg/L | SS | 32 mg/L | | |
| | NH ₃ -N | - | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | - | | |
| | Phenolic Compounds | - | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.71 | Phenolic Compounds | 0.32 | | |

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|-------------------------------|--|
| | | | | | | | | | | | | | |
| 45 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 25 | Nil | pH | 8.11 | pH | 7.94 | pH, Flow meter, COD, BOD, TSS | Storage – 1000 MT Disposal – 1331 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 815 mg/L | COD | 198 mg/L | | |
| | BOD | 400 mg/L | BOD | 30 mg/L | | | | BOD | 180 mg/L | BOD | 20 mg/L | | |
| | SS | 300 mg/L | SS | <60 mg/L | | | | SS | 244 mg/L | SS | 52 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 24 mg/L | NH ₃ -N | 17 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 1.18 mg/L | Phenolic Compounds | 0.61 mg/L | | |

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|--------------------------------|--|
| | | | | | | | | | | | | | |
| 55 | pH | 6.5-8.5 | 0. | 6.5-8.5 | Average value of Jan - 2020 | 54 | Nil | pH | 8.07 | pH | 7.38 | pH, Flow Meter, TOC & DO Meter | Storage – 18520 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 1260 mg/L | COD | 249 mg/L | | |
| | BOD | 400 mg/L | BOD | 30 mg/L | | | | BOD | 370 mg/L | BOD | 28 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 521 mg/L | SS | 84 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 56 mg/L | NH ₃ -N | 47 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 5.65 mg/L | Phenolic Compounds | 0.79 mg/L | | |

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|----------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|-----------|------------------------|--|
| | | | | | | | | | | | | | |
| 12.5 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 9 | Nil | pH | 7.89 | pH | 7.90 | Flow Meter, TOC meter | Storage – 150 MT |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 375 mg/L | COD | 180 mg/L | | |
| | BOD (3 days at 27°C) | 400 mg/L | BOD (3 days at 27°C) | 100 mg/L | | | | BOD (3 days at 27°C) | 112 mg/L | BOD (3 days at 27°C) | 25 mg/L | | |
| | SS | 300 mg/L | SS | 100 mg/L | | | | SS | 42 mg/L | SS | 62 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 2 mg/L | NH ₃ -N | 31 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.98 mg/L | Phenolic Compounds | 0.15 mg/L | | |

M/s. Veraval Industries Association, Veraval, Junagadh

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|----------------------|--------------------|--------------|--|----------|--|---|--|------------------------|---|------------------------------------|---|------------------------------|---|
| | | | | | | | | | | | | | |
| 5 | pH | 5.5 to 9 | pH | 6 to 9 | No sampling in the month of Jan - 2020 | 5 | Nil | pH | - | pH | - | - | - |
| | COD | 3500 mg/L | COD | 250 mg/L | | | | COD | - | COD | - | | |
| | BOD | 1000 mg/L | BOD | 100 mg/L | | | | BOD | - | BOD | - | | |
| | SS | 200 mg/L | SS | 100 mg/L | | | | SS | - | SS | - | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | - | | |
| | Phenol | - | Phenol | - | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-------------------------------------|-----------------------------------|--|------------------------|---|---------------------------------|---|--------------------------------------|--|
| | | | | | | | | | | | | | |
| 30 | pH | 10.5-12 | pH | 6.5-9 | No visit in the month of Jan - 2020 | 10 | Nil | pH | - | pH | - | pH, Flow meter, SS, Color, MLSS, COD | - |
| | COD | 1000 mg/L | COD | 100 mg/L | | | | COD | - | COD | - | | |
| | BOD | 350 mg/L | BOD | 30 mg/L | | | | BOD | - | BOD | - | | |
| | SS | 2000 mg/L | SS | 100 mg/L | | | | SS | - | SS | - | | |
| | NH ₃ -N | 75 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | - | | |
| | Phenolic Compounds | 5 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|-----------|---------------------------------|----------|------------------------|--|
| | | | | | | | | | | | | | |
| 10.00 | pH | 10.5-12.0 | pH | 6.5-9 | Average value of Jan - 2020 | 7.00 | Nil | pH | 7.24 | pH | 7.27 | pH, Flow meter | - |
| | COD | 1000 mg/L | COD | 250 mg/L | | | | COD | 1659 mg/L | COD | 193 mg/L | | |
| | BOD | 350 mg/L | BOD | 100 mg/L | | | | BOD | 525 mg/L | BOD | 49 mg/L | | |
| | SS | 2000 mg/L | SS | 100 mg/L | | | | SS | 688 mg/L | SS | 84 mg/L | | |
| | NH ₃ -N | 75 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 27 mg/L | NH ₃ -N | 9 mg/L | | |
| | Phenolic Compounds | 5 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|----------|---------------------------------|----------|------------------------|--|
| | | | | | | | | | | | | | |
| 0.09 | pH | 10.5-12 | pH | 6.5 to 9 | Average value of Jan - 2020 | 0.09 | Nil | pH | 6.66 | pH | 6.52 | pH, Flow Meter | Storage – 4 MT Disposal – 11 MT |
| | COD | 1000 mg/L | COD | 100 mg/L | | | | COD | 961 mg/L | COD | 639 mg/L | | |
| | BOD | 350 mg/L | BOD | 30 mg/L | | | | BOD | 294 mg/L | BOD | 174 mg/L | | |
| | SS | 2000 mg/L | SS | 100 mg/L | | | | SS | 120 mg/L | SS | 60 mg/L | | |
| | NH ₃ -N | 75 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 6 mg/L | NH ₃ -N | 21 mg/L | | |
| | Phenolic Compounds | 5 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | - | | |

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|----------|--|------------|-----------------------------|-----------------------------------|--|------------------------|----------|---------------------------------|---------|------------------------|--|
| | | | | | | | | | | | | | |
| 0.025 | pH | Up to 5 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 0.013 | Nil | pH | 2.85 | pH | 7.69 | - | - |
| | COD | 250 mg/L | COD | 100 mg/L | | | | COD | 13 mg/L | COD | 6 mg/L | | |
| | BOD | 100 mg/L | BOD | 30 mg/L | | | | BOD | 4 mg/L | BOD | 2 mg/L | | |
| | SS | 250 mg/L | SS | 100 mg/L | | | | SS | 530 mg/L | SS | 36 mg/L | | |
| | NH ₃ -N | - | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 6 mg/L | NH ₃ -N | 1 mg/L | | |
| | Phenolic Compounds | - | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | BDL | Phenolic Compounds | BDL | | |

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|--------------------|------------|--|------------|-----------------------------|-----------------------------------|--|------------------------|---|---------------------------------|----------|------------------------|--|
| | | | | | | | | | | | | | |
| 0.35 | pH | 6.5 to 8.5 | pH | 6.5 to 8.5 | Average value of Jan - 2020 | 0.35 | Nil | pH | - | pH | 8.19 | - | Storage – 70 MT |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | - | COD | 172 mg/L | | |
| | BOD | 700 mg/L | BOD | 100 mg/L | | | | BOD | - | BOD | 45 mg/L | | |
| | SS | - | SS | 100 mg/L | | | | SS | - | SS | 52 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | - | NH ₃ -N | 18 mg/L | | |
| | Phenolic Compounds | - | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | - | Phenolic Compounds | BDL | | |

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

| Capacity in (MLD) | Inlet Norms | | Final Effluent Quality Stds. Or ZLD Conditions | | Date of Monitoring | Waste Water treated in CETP (MLD) | Waste Water bypassed untreated in the area, if any (MLD) | Observed Inlet Quality | | Observed Final Effluent Quality | | Status of Online CEQMS | Status of Hazardous Waste Storage / Disposal |
|-------------------|-----------------------|-----------|--|----------|-----------------------------|-----------------------------------|--|------------------------|----------|---------------------------------|----------|---------------------------------------|--|
| | | | | | | | | | | | | | |
| 2.5 | pH | 6.5-8.5 | pH | 6.5-8.5 | Average value of Jan - 2020 | 0.15 | Nil | pH | 7.65 | pH | 7.79 | pH, COD, BOD, TSS, Ammonical Nitrogen | - |
| | COD | 2000 mg/L | COD | 250 mg/L | | | | COD | 563 mg/L | COD | 64 mg/L | | |
| | BOD (3 days at 27° C) | 1000 mg/L | BOD(3 days at 27° C) | 100 mg/L | | | | BOD(3 days at 27° C) | 225 mg/L | BOD(3 days at 27° C) | 14 mg/L | | |
| | SS | 800 mg/L | SS | 100 mg/L | | | | SS | 201 mg/L | SS | 43 mg/L | | |
| | NH ₃ -N | 50 mg/L | NH ₃ -N | 50 mg/L | | | | NH ₃ -N | 55 mg/L | NH ₃ -N | 18 mg/L | | |
| | Phenolic Compounds | 1 mg/L | Phenolic Compounds | 1 mg/L | | | | Phenolic Compounds | 0.3 mg/L | Phenolic Compounds | 0.1 mg/L | | |