

**M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	8.5	Nil	pH	7.10	pH	7.24	Flow Meter, TOC meter	-
	COD	750 mg/L	COD	250 mg/L				COD	746 mg/L	COD	145 mg/L		
	BOD (3 days at 27°C)	300 mg/L	BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	159 mg/L	BOD (3 days at 27°C)	30 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	144 mg/L	SS	57 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	10 mg/L	NH <sub>3</sub> -N	13 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.34 mg/L		

**M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
55	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	55	Nil	pH	7.43	pH	7.3	pH, Flow Meter, TOC & DO Meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	771 mg/L	COD	232 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	172 mg/L	BOD	32 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	150 mg/L	SS	85 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	34 mg/L	NH <sub>3</sub> -N	31 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.04 mg/L	Phenolic Compounds	0.46 mg/L		

**M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of July - 2017	40	Nil	pH	6.99	pH	6.93	pH, Flow Meter, TOC	Storage - 1100 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1300 mg/L	COD	269 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	290 mg/L	BOD	54 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	178 mg/L	SS	44 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	13 mg/L	NH <sub>3</sub> -N	11 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.82 mg/L	Phenolic Compounds	0.19 mg/L		

**M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2017	0.35	Nil	pH	7.46	pH	6.88	pH, TOC, TSS, Flow meter	Storage – 10 MT
	COD	4000 mg/L	COD	250 mg/L				COD	965 mg/L	COD	266 mg/L		
	BOD	1500 mg/L	BOD	30 mg/L				BOD	180 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	158 mg/L	SS	42 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	33 mg/L	NH <sub>3</sub> -N	15 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.71 mg/L	Phenolic Compounds	0.59 mg/L		

**M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	88	Nil	pH	7.28	pH	7.49	pH, Flow Meter, TOC, COD	Storage – 1030 MT Disposal – 316 MT
	COD	1000 mg/L	COD	250 mg/L				COD	863 mg/L	COD	215 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	188 mg/L	BOD	40 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	198 mg/L	SS	52 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	21 mg/L	NH <sub>3</sub> -N	10 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.25 mg/L	Phenolic Compounds	0.17 mg/L		

**M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2017	95	Nil	pH	7.19	pH	7.51	pH, Flow Meter, COD, BOD, TSS	Storage – 700 MT
	COD	1000 mg/L	COD	250 mg/L				COD	813 mg/L	COD	293 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	96 mg/L	BOD	40 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	188 mg/L	SS	130 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	40 mg/L	NH <sub>3</sub> -N	15 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.69 mg/L	Phenolic Compounds	0.52 mg/L		

**M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	22	Nil	pH	7.57	pH	7.08	pH, Flow meter, COD, BOD, TSS	Storage – 150 MT
	COD	1000 mg/L	COD	100 mg/L				COD	1382 mg/L	COD	178 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	300 mg/L	BOD	23 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	190 mg/L	SS	42 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	42 mg/L	NH <sub>3</sub> -N	10 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.98 mg/L	Phenolic Compounds	0.72 mg/L		

**M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2017	35	Nil	pH	7.18	pH	7.31	pH, Flow Meter, COD Meter including TOC	Storage – 70 MT
	COD		COD	100 mg/L				COD	1052 mg/L	COD	136 mg/L		
	BOD		BOD	30 mg/L				BOD	240 mg/L	BOD	26 mg/L		
	SS		SS	<60 mg/L				SS	128 mg/L	SS	64 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	36 mg/L	NH <sub>3</sub> -N	11 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.88 mg/L	Phenolic Compounds	0.23 mg/L		



**M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	Not Furnished	pH	6.5 to 8.5	No sampling in the month of July - 2017	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD		COD	100 mg/L				COD	-	COD	-		
	BOD		BOD	30 mg/L				BOD	-	BOD	-		
	SS		SS	<60 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Panoli Enviro Technology Ltd., GIDC-Panoli, Bharuch**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	Not Furnished	pH	5.5-8.5	Average value of July - 2017	0.35	Nil	pH	7.24	pH	7.58	pH, Flow Meter, TOC	Storage - Nil
	COD		COD	100 mg/L				COD	1083 mg/L	COD	291 mg/L		
	BOD		BOD	30 mg/L				BOD	160 mg/L	BOD	27 mg/L		
	SS		SS	100 mg/L				SS	268 mg/L	SS	12 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	52 mg/L	NH <sub>3</sub> -N	10 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	1.52 mg/L	Phenolic Compounds	0.59 mg/L		

**M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	Not Furnished	pH	5.5-8.5	Average value of July - 2017	1.10	Nil	pH	1.58	pH	7.10	pH, Flow, COD, BOD, TSS, TOC	Storage - Nil
	COD		COD	100 mg/L				COD	3416 mg/L	COD	962 mg/L		
	BOD (3 days at 27°C)		BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	809 mg/L	BOD (3 days at 27°C)	15 mg/L		
	SS		SS	100 mg/L				SS	186 mg/L	SS	48 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	41 mg/L	NH <sub>3</sub> -N	49 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	7.21 mg/L	Phenolic Compounds	0.72 mg/L		

**M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.)(BEAIL), Ankleshwar**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	Not Furnished	pH	6-9	Average value of July - 2017	40	Nil	pH	7.30	pH	7.00	pH, Flow Meter, TOC, TSS	Storage – 50 MT
	COD		COD	500 mg/L				COD	1149 mg/L	COD	691 mg/L		
	BOD		BOD	100 mg/L				BOD	76 mg/L	BOD	25 mg/L		
	SS		SS	100 mg/L				SS	80 mg/L	SS	34 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	201 mg/L	NH <sub>3</sub> -N	199 mg/L		
	Phenolic Compounds		Phenolic Compounds	5 mg/L				Phenolic Compounds	3.43 mg/L	Phenolic Compounds	1.47 mg/L		

**M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of July - 2017	4.80	Nil	pH	7.36	pH	7.09	pH, COD, BOD, TSS, NH <sub>3</sub> -N, Color, TOC, Temperature	-
	COD	2000 mg/L	COD	250 mg/L				COD	671 mg/L	COD	187 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	161 mg/L	BOD	34 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	559 mg/L	SS	96 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	19 mg/L	NH <sub>3</sub> -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.95 mg/L	Phenolic Compounds	0.33 mg/L		

**M/s. Enviro Infrastructure Co. Ltd., Umraya(Padra), Vadodara**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of July - 2017	1.50	Nil	pH	7.98	pH	8.04	pH, Flow Meter, TOC, TSS, Color, NH <sub>3</sub> -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	453 mg/L	COD	242 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	121 mg/L	BOD	32 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	236 mg/L	SS	60 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	8 mg/L	NH <sub>3</sub> -N	10 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.48 mg/L	Phenolic Compounds	0.48 mg/L		

**M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	3.00	Nil	pH	-	pH	7.87	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	764 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	233 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	112 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	60 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	1.84 mg/L		

**M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
16	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	20	Nil	pH	-	pH	7.16	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	613 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	179 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	146 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	64 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		



**M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	1.00	Nil	pH	-	pH	7.11	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 40 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	196 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	48 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	38 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.87 mg/L		

**M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	0.60	Nil	pH	-	pH	7.81	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	132 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	40 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	12 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	32 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	0.015	Nil	pH	-	pH	7.38	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	655 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	203 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	154 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	0.60	Nil	pH	-	pH	7.07	Flow Meter	Storage – 50 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	136 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	42 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	10 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	72 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2017	0.35	Nil	pH	-	pH	7.38	TOC analyzer	Storage - 16 MT
	COD	2500 mg/L	COD	250 mg/L				COD	-	COD	1001 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	306 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	165 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	25 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of July - 2017	1.3	Nil	pH	-	pH	6.75	pH, TOC meter	-
	COD	850 mg/L	COD					COD	4 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	1 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH <sub>3</sub> -N	<10 mg/L	NH <sub>3</sub> -N					NH <sub>3</sub> -N	1 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

**M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of July - 2017	0.10	Nil	pH	-	pH	7.65	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	22 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	8 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	12 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	1 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	No CETP Designed Inlet Quality prescribed as it is a CETP of rice mill cluster	pH	6.5-8.5	Average value of July - 2017	1.00	Nil	pH	-	pH	7.25	-	Sludge is used as Manure
	COD		COD	250 mg/L				COD	-	COD	834 mg/L		
	BOD		BOD	100 mg/L				BOD	-	BOD	261 mg/L		
	SS		SS	100 mg/L				SS	-	SS	136 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	30 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	0.67 mg/L		



**M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	No CETP Designed Inlet Quality prescribed as it is the CETP of Rice Mills	pH	6.5-8.5	Average value of July - 2017	1.50	Nil	pH	6.8	pH	7.81	-	Sludge is used as Manure
	COD		COD	250mg/L				COD	1193 mg/L	COD	141 mg/L		
	BOD		BOD	100 mg/L				BOD	480 mg/L	BOD	44 mg/L		
	SS		SS	100 mg/L				SS	193 mg/L	SS	72 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	60 mg/L	NH <sub>3</sub> -N	9 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	1.02 mg/L	Phenolic Compounds	BDL		

**M/s. Jay Khodiyar Enviro -Technologies Pvt. Ltd., Rajkot**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2017	0.007	Nil	pH	-	pH	7.43	-	Storage – 35 kg  Disposal – 10 MT
	COD		COD	250 mg/L				COD	-	COD	6 mg/L		
	BOD		BOD	30 mg/L				BOD	-	BOD	1 mg/L		
	SS		SS	100 mg/L				SS	-	SS	280 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	0.56 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

**M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	Not Furnished	pH	6.5 to 8.5	Average value of July - 2017	7.00	Nil	pH	7.57	pH	7.50	pH, Flow meter	Disposal – 22MT
	COD		COD	250 mg/L				COD	437 mg/L	COD	109 mg/L		
	BOD		BOD	30 mg/L				BOD	141 mg/L	BOD	33 mg/L		
	SS		SS	100 mg/L				SS	400 mg/L	SS	30 mg/L		
	NH <sub>3</sub> -N		NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	2 mg/L	NH <sub>3</sub> -N	2 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	-	pH	6.5 to 8.5	Average value of July - 2017	0.07	Nil	pH	6.84	pH	7.03	pH, Flow Meter	Storage – 17 MT
	COD	-	COD	250 mg/L				COD	876 mg/L	COD	388 mg/L		
	BOD	-	BOD	100 mg/L				BOD	283 mg/L	BOD	121 mg/L		
	SS	-	SS	100 mg/L				SS	410 mg/L	SS	310 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	6 mg/L	NH <sub>3</sub> -N	3 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	-	pH	6.5 to 8.5	Average value of July - 2017	6.00	Nil	pH	8.29	pH	8.09	pH, Flow meter, SS, Color, MLSS, COD	Storage – 140 MT
	COD	-	COD	100 mg/L				COD	524 mg/L	COD	152 mg/L		
	BOD	-	BOD	30 mg/L				BOD	162 mg/L	BOD	41 mg/L		
	SS	-	SS	100 mg/L				SS	144 mg/L	SS	243 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	62 mg/L	NH <sub>3</sub> -N	24 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Veraval Industries Association, Veraval, Junagadh**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No sampling in the month of July - 2017	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch**

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2017	0.10	Nil	pH	7.27	pH	7.34	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	100 mg/L				COD	198 mg/L	COD	140 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	30 mg/L				BOD(3 days at 27° C)	82 mg/L	BOD(3 days at 27° C)	45 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	68 mg/L	SS	20 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	4 mg/L	NH <sub>3</sub> -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		