

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	23	Nil	pH	7.50	pH	7.12	pH, Flow Meter, TOC, COD, BOD, TSS	Storage - 6000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1302 mg/L	COD	308 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	377 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	306 mg/L	SS	72 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51.24 mg/L	NH ₃ -N	24 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.1 mg/L	Phenolic Compounds	0.284 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	1.1	Nil	pH	7.16	pH	6.45	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage - 55 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1162 mg/L	COD	224 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	369 mg/L	BOD	33 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	786 mg/L	SS	68 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	49.17 mg/L	NH ₃ -N	2.69 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.71 mg/L	Phenolic Compounds	0.04 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.7	Nil	pH	6.23	pH	7.08	Flow Meter	Storage - 500 MT Disposal - 69 MT
	COD	2000 mg/L	COD	250 mg/L				COD	548 mg/L	COD	246 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	155 mg/L	BOD	49 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1634 mg/L	SS	202 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	61.54 mg/L	NH ₃ -N	78 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.711 mg/L	Phenolic Compounds	BDL		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.8	Nil	pH	5.78	pH	7.16	-	Storage - 25 MT
	COD	750 mg/L	COD	250 mg/L				COD	1059 mg/L	COD	500 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	480 mg/L	BOD	237 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	126 mg/L	SS	132 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51.86 mg/L	NH ₃ -N	42 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.15 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	4.5	Nil	pH	7.84	pH	7.96	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	3550 mg/L	COD	459 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	963 mg/L	BOD	56 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	790 mg/L	SS	176 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	110.66 mg/L	NH ₃ -N	30 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.158 mg/L	Phenolic Compounds	BDL		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.040	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.020	Nil	pH	7.65	pH	7.68	-	Storage - 28 MT
	COD	1500 mg/L	COD	250 mg/L				COD	624 mg/L	COD	162 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	95 mg/L	BOD	33 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	116 mg/L	SS	44 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	1.96 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.06 mg/L	Phenolic Compounds	BDL		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	100	Nil	pH	6.96	pH	7.97	-	Storage – 900 MT
	COD	1200 mg/L	COD	250 mg/L				COD	983 mg/L	COD	242 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	345 mg/L	BOD	76 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	368 mg/L	SS	104 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	45.19 mg/L	NH ₃ -N	56 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.03 mg/L	Phenolic Compounds	0.14 mg/L		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of September - 2019	0.10	Nil	pH	-	pH	8.15	pH, DO meter, TOC meter, Flow meter	Storage – 5 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	27 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	3 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	10 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	
3	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of September - 2019	1.8	Nil	pH	-	pH	6.25	pH, TOC meter	Storage – 30 MT
	COD	850 mg/L	COD					COD	12 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	3 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	2 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.3	Nil	pH	-	pH	7.96	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	443 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	148 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	104 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	27 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of September - 2019	4	Nil	pH	-	pH	8.01	-	-
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	268 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	65 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	242 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	8.74 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	Average value of September - 2019	6.4	Nil	pH	7.86	pH	6.51	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1604 mg/L	COD	141 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	404 mg/L	BOD	18 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	718 mg/L	SS	118 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	37.52 mg/L	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.96 mg/L	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of September - 2019	2.2	Nil	pH	-	pH	7.71	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-----
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	202 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	38 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	70 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	2.31	Nil	pH	-	pH	6.80	pH, Flow, COD, BOD, TSS, TOC	
	COD	11000 mg/L	COD	1000 mg/L				COD	-	COD	261 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	-	BOD (3 days at 27°C)	-		
	SS	-	SS	150 mg/L				SS	-	SS	-		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.42 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of September - 2019	31.92	Nil	pH	7.99	pH	6.54	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	1638 mg/L	COD	476 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	304 mg/L	BOD	18 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	772 mg/L	SS	94 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	104.94 mg/L	NH ₃ -N	71 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	4.38 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.45	Nil	pH	6.78	pH	6.75	pH, Flow Meter, TOC	Storage-150 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2944 mg/L	COD	882 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	484 mg/L	BOD	26 mg/L		
	SS	-	SS	150 mg/L				SS	630 mg/L	SS	118 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	40.04 mg/L	NH ₃ -N	33 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	11.06 mg/L	Phenolic Compounds	0.49 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of September - 2019	0.236	Nil	pH	7.19	pH	7.56	pH, TOC, TSS, Flow meter	Storage-550 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1556 mg/L	COD	207 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	386 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	354 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.71 mg/L	Phenolic Compounds	0.73 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of September - 2019	32.83	Nil	pH	7.09	pH	7.12	pH, Flow Meter, TOC	Storage-2500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	780 mg/L	COD	239 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	187 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	252 mg/L	SS	92 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	24 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.56 mg/L	Phenolic Compounds	0.48 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	No visit in the month of September-2019	98	Nil	pH	-	pH	-	pH, Flow Meter, COD, BOD, TSS	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	81.5	Nil	pH	6.4	pH	7.32	pH, Flow Meter, TOC, COD	Storage-3500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	993 mg/L	COD	237 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	208 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	210 mg/L	SS	88 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	34 mg/L	NH ₃ -N	27 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.36 mg/L	Phenolic Compounds	0.70 mg/L		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.84	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.5	Nil	pH	7.25	pH	7.51	-	Storage – 6 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	392 mg/L	COD	69 mg/L		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	80 mg/L	BOD	11 mg/L		
	SS	<150 mg/L	SS	<5 mg/L				SS	228 mg/L	SS	86 mg/L		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	5.04 mg/L	NH ₃ -N	2.24 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	0.71 mg/L	Phenolic Compounds	0.46 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of September - 2019	29	Nil	pH	7.44	pH	7.12	pH, Flow Meter, COD Meter including TOC	Storage-700 MT
	COD	1000 mg/L	COD	250 mg/L				COD	977 mg/L	COD	206 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	202 mg/L	BOD	21 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	222 mg/L	SS	88 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	44 mg/L	NH ₃ -N	29 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.29 mg/L	Phenolic Compounds	0.38 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.75	pH	-	pH	6.5 to 8.5	No visit in the month of September-2019	1.39	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	25	Nil	pH	7.69	pH	7.55	pH, Flow meter, COD, BOD, TSS	Storage-2200 MT Disposal-2965 MT
	COD	1000 mg/L	COD	250 mg/L				COD	718 mg/L	COD	199 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	157 mg/L	BOD	23 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	280 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	17 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.38 mg/L	Phenolic Compounds	0.31 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of September - 2019	54	Nil	pH	7.87	pH	7.69	pH, Flow Meter, TOC & DO Meter	Storage -17000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	657 mg/L	COD	231 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	120 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	90 mg/L	SS	58 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	46 mg/L	NH ₃ -N	41 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.99 mg/L	Phenolic Compounds	0.845 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	9	Nil	pH	7.69	pH	7.82	Flow Meter, TOC meter	Storage – 300 MT
	COD	1000 mg/L	COD	250 mg/L				COD	392 mg/L	COD	171 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	88 mg/L	BOD (3 days at 27°C)	20 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	112 mg/L	SS	44 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33 mg/L	NH ₃ -N	29 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.89 mg/L	Phenolic Compounds	0.37 mg/L		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of September-2019	5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of September - 2019	10	Nil	pH	11.14	pH	9.27	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	341 mg/L	COD	272 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	103 mg/L	BOD	53 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	496 mg/L	SS	660 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	8.4 mg/L	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	Average value of September - 2019	7.00	Nil	pH	8.91	pH	7.95	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	449 mg/L	COD	94 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	82 mg/L	BOD	30 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	198 mg/L	SS	134 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	61.32 mg/L	NH ₃ -N	28 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of September - 2019	0.09	Nil	pH	6.65	pH	6.83	pH, Flow Meter	Storage – 10 MT
	COD	1000 mg/L	COD	100 mg/L				COD	745 mg/L	COD	27 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	197 mg/L	BOD	8 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	256 mg/L	SS	02 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	9.8 mg/L	NH ₃ -N	13 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of September - 2019	0.013	Nil	pH	6.20	pH	7.99	-	Storage – 4 MT
	COD	250 mg/L	COD	100 mg/L				COD	16 mg/L	COD	11 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	3.9 mg/L	BOD	2.7 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	48 mg/L	SS	06 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	1.68 mg/L	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.35	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of September - 2019	0.35	Nil	pH	-	pH	7.98	-	Storage – 25 MT Disposal – 11 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	102 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	20 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	56 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	6 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of September - 2019	0.15	Nil	pH	7.67	pH	7.20	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	421 mg/L	COD	83 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	152 mg/L	BOD(3 days at 27° C)	24 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	36 mg/L	SS	18 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	71.68 mg/L	NH ₃ -N	45 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.4 mg/L	Phenolic Compounds	0.1 mg/L		