

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	8.5	Nil	pH	6.79	pH	7.64	Flow Meter, TOC meter	Storage – 500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1099 mg/L	COD	242 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	259 mg/L	BOD (3 days at 27°C)	37 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	285 mg/L	SS	100 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	8 mg/L	NH ₃ -N	30 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.38 mg/L	Phenolic Compounds	0.173 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of April - 2018	55	Nil	pH	7.88	pH	7.62	pH, Flow Meter, TOC & DO Meter	Storage- 3200 MT
	COD	1000 mg/L	COD	250 mg/L				COD	981 mg/L	COD	391 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	230 mg/L	BOD	83 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	445 mg/L	SS	84 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	72 mg/L	NH ₃ -N	73 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.73 mg/L	Phenolic Compounds	0.35 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of April - 2018	40	Nil	pH	7.07	pH	7.94	pH, Flow Meter, TOC	Storage – 275 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1600 mg/L	COD	280 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	475 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	292 mg/L	SS	72 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	54 mg/L	NH ₃ -N	35 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.27 mg/L	Phenolic Compounds	0.13 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of April - 2018	0.35	Nil	pH	7.64	pH	7.24	pH, TOC, TSS, Flow meter	Storage – 20 MT Disposed – 21 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1700 mg/L	COD	290 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	495 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	236 mg/L	SS	92 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	34 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.45 mg/L		

M/s. Pandesara Infrastructure Ltd.,GIDC-Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	88	Nil	pH	7.71	pH	7.83	pH, Flow Meter, TOC, COD	Storage – 40 MT Disposal – 830 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1071 mg/L	COD	262 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	305 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	120 mg/L	SS	18 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	30 mg/L	NH ₃ -N	15 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.58 mg/L	Phenolic Compounds	0.33 mg/L		

M/s. Palsana Enviro Protection Ltd.,(PEPL),Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of April – 2018	95	Nil	pH	8.20	pH	8.26	pH, Flow Meter, COD, BOD, TSS	Storage- 550 MT Disposed – 52.79 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1606 mg/L	COD	270 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	405 mg/L	BOD	30 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	194 mg/L	SS	56 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.71 mg/L	Phenolic Compounds	0.31 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	22	Nil	pH	7.92	pH	7.89	pH, Flow meter, COD, BOD, TSS	Storage -50 MT Disposal – 654 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1320 mg/L	COD	192 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	395 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	224 mg/L	SS	8 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	48 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.48 mg/L	Phenolic Compounds	0.17 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of April – 2018	35	Nil	pH	8.02	pH	7.99	pH, Flow Meter, COD Meter including TOC	Storage - 80 MT Disposal – 286 MT
	COD	1000 mg/L	COD	250 mg/L				COD	878 mg/L	COD	205 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	205 mg/L	BOD	30 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	130 mg/L	SS	22 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.21 mg/L	Phenolic Compounds	0.53 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	No visit in the month of April – 2018	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	-	pH	5.5-8.5	Average value of April - 2018	0.35	Nil	pH	7.24	pH	7.8	pH, Flow Meter, TOC	Storage – 100 MT
	COD	3500 mg/L	COD	500 mg/L				COD	2911 mg/L	COD	586 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	862 mg/L	BOD	25 mg/L		
	SS	-	SS	100 mg/L				SS	443 mg/L	SS	58 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	75 mg/L	NH ₃ -N	42 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.1 mg/L	Phenolic Compounds	0.96 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of April - 2018	1.10	Nil	pH	1.99	pH	7.56	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	4718 mg/L	COD	695 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	1362 mg/L	BOD (3 days at 27°C)	27 mg/L		
	SS	-	SS	100 mg/L				SS	709 mg/L	SS	46 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	65 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	11.085 mg/L	Phenolic Compounds	0.415 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of April - 2018	40	Nil	pH	7.78	pH	6.882	pH, Flow Meter, TOC, TSS	Storage – 50 MT Disposed- 1200 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1038 mg/L	COD	467 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	241 mg/L	SS	70 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	91 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of April - 2018	4.80	Nil	pH	7.12	pH	7.04	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1499 mg/L	COD	552 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	315 mg/L	BOD	71 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	342 mg/L	SS	106 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	106 mg/L	NH ₃ -N	4 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.21 mg/L	Phenolic Compounds	0.92 mg/L		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of April - 2018	1.50	Nil	pH	7.69	pH	7.78	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	693 mg/L	COD	258 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	232 mg/L	BOD	34 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	282 mg/L	SS	26 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.16 mg/L	Phenolic Compounds	1.03 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	3.00	Nil	pH	7.21	pH	7.77	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	3675 mg/L	COD	847 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	1170 mg/L	BOD	190 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	342 mg/L	SS	140 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	129 mg/L	NH ₃ -N	27 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.40 mg/L	Phenolic Compounds	0.30 mg/L		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	20	Nil	pH	7.43	pH	7.24	pH, Flow Meter, TOC, COD, BOD, TSS	Spray Dryer Sludge Storage- 50 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1819 mg/L	COD	491 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	408 mg/L	BOD	75 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	900 mg/L	SS	120 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	57 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.87 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	1.00	Nil	pH	7.63	pH	7.69	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 20 MT
	COD	2000 mg/L	COD	250 mg/L				COD	2009 mg/L	COD	492 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	623 mg/L	BOD	75 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	310 mg/L	SS	130 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	73 mg/L	NH ₃ -N	36 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.81 mg/L	Phenolic Compounds	0.566 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	0.60	Nil	pH	8.28	pH	8.12	-	-
	COD	750 mg/L	COD	250 mg/L				COD	195 mg/L	COD	83 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	26 mg/L	BOD	15 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	114 mg/L	SS	12 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	51 mg/L	NH ₃ -N	36 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.195 mg/L	Phenolic Compounds	0.134 mg/L		

M/s. Narol Dyestuff Enviro Society.,Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	0.015	Nil	pH	8.00	pH	8.08	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	1972 mg/L	COD	207 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	240 mg/L	BOD	46 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	792 mg/L	SS	196 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	6 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.48 mg/L	Phenolic Compounds	BDL		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of April - 2018	0.60	Nil	pH	7.17	pH	7.30	Flow Meter	Storage- 125 MT
	COD	2000 mg/L	COD	250 mg/L				COD	820 mg/L	COD	360 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	175 mg/L	BOD	78 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	3890 mg/L	SS	132 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	109 mg/L	NH ₃ -N	69 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.53 mg/L	Phenolic Compounds	0.22 mg/L		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of April - 2018	0.35	Nil	pH	7.09	pH	7.61	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	2061 mg/L	COD	397 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	329 mg/L	BOD	124 mg/L		
	SS	-	SS	100 mg/L				SS	613 mg/L	SS	190 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35 mg/L	NH ₃ -N	6 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.39 mg/L	Phenolic Compounds	0.65 mg/L		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of April - 2018	1.3	Nil	pH	7.37	pH	6.56	pH, TOC meter	Storage - 22 MT
	COD	850 mg/L	COD					COD	248 mg/L	COD	30 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	151 mg/L	BOD (3 days at 27°C)	9 mg/L		
	SS	300 mg/L	SS					SS	48 mg/L	SS	8 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	23 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.24 mg/L	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of April - 2018	0.10	Nil	pH	6.96	pH	7.90	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	224 mg/L	COD	55 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	111 mg/L	BOD	20 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	168 mg/L	SS	24 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35 mg/L	NH ₃ -N	0.56 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.04 mg/L	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of April - 2018	1.00	Nil	pH	6.24	pH	7.61	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250 mg/L				COD	1801 mg/L	COD	587 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	910 mg/L	BOD	252 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	236 mg/L	SS	193 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	48 mg/L	NH ₃ -N	25 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of April - 2018	1.50	Nil	pH	6.82	pH	7.84	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250 mg/L				COD	1370 mg/L	COD	192 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	907 mg/L	BOD	97 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	118 mg/L	SS	76 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	77 mg/L	NH ₃ -N	13 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of April – 2018	0.007	Nil	pH	1.95	pH	7.72	-	Storage – 8 MT
	COD	250 mg/L	COD	100 mg/L				COD	21 mg/L	COD	11 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	4 mg/L	BOD	2 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	168 mg/L	SS	34 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	13 mg/L	NH ₃ -N	0.5 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	Average value of April - 2018	7.00	Nil	pH	8.62	pH	7.72	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	995 mg/L	COD	143 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	397 mg/L	BOD	38 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	220 mg/L	SS	93 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of April - 2018	0.07	Nil	pH	6.92	pH	7.48	pH, Flow Meter	Storage – 9 kg
	COD	1000 mg/L	COD	100 mg/L				COD	979 mg/L	COD	539 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	174 mg/L	BOD	57 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	274 mg/L	SS	94 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	6 mg/L	NH ₃ -N	7 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam,Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	No visit in the month of April - 2018	6.00	Nil	pH	-	pH	-	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	Average value of April - 2018	1.5	Nil	pH	7.03	pH	7.67	-	Storage- 500 kg
	COD	3500 mg/L	COD	250 mg/L				COD	1244 mg/L	COD	168 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	398 mg/L	BOD	51 mg/L		
	SS	200 mg/L	SS	100 mg/L				SS	196 mg/L	SS	86 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	917 mg/L	NH ₃ -N	231 mg/L		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of April - 2018	0.10	Nil	pH	-	pH	-	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	-	BOD(3 days at 27° C)	-		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		