

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	20	Nil	pH	-	pH	7.42	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	618 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	109 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	142 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	13 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.5 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	1.00	Nil	pH	-	pH	7.67	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 30 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	455 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	111 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	228 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	75 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	1 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	0.60	Nil	pH	-	pH	7.20	Flow Meter	Storage - 250 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	413 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	63 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	102 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	6 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	1.9 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	0.60	Nil	pH	-	pH	7.04	-	-
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	105 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	16 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	18 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	42 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	2 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	3.00	Nil	pH	7.48	pH	7.78	-	Storage – 3500 MT
	COD	2000 mg/L	COD	250 mg/L				COD	3638 mg/L	COD	1935 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	685 mg/L	BOD	278 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	220 mg/L	SS	326 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33.66 mg/L	NH ₃ -N	80 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.46 mg/L	Phenolic Compounds	1.4 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	0.015	Nil	pH	-	pH	7.92	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	754 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	141 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	142 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	22 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.53 mg/L		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	100	Nil	pH	7.150	pH	8.15	-	-
	COD	1200 mg/L	COD	250 mg/L				COD	829 mg/L	COD	395 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	388 mg/L	BOD	132 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	564 mg/L	SS	86 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	63 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.09 mg/L	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of December - 2018	0.10	Nil	pH	-	pH	9.15	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	92 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	13 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	16 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of December - 2018	1.3	Nil	pH	-	pH	6.94	pH, TOC meter	Storage – 5 MT
	COD	850 mg/L	COD					COD	20 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	03 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	1 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of December - 2018	1.00	Nil	pH	-	pH	7.67	-	Sludge is used as manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	282 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	56 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	88 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	5 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of December - 2018	1.50	Nil	pH	-	pH	8.04	-	Sludge is used as manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	201 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	50 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	38 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	12 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of December - 2018	4.80	Nil	pH	7.20	pH	7.12	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1818 mg/L	COD	192 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	312 mg/L	BOD	17 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	226 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1 mg/L	Phenolic Compounds	0.155 mg/L		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of December - 2018	1.50	Nil	pH	7.84	pH	8.01	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	2022 mg/L	COD	270 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	273 mg/L	BOD	52 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	4358 mg/L	SS	104 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	10 mg/L	NH ₃ -N	7 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.19 mg/L	Phenolic Compounds	BDL		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of December - 2018	1.10	Nil	pH	6.975	pH	7.59	pH, Flow, COD, BOD, TSS, TOC	Storage – 75 MT
	COD	11000 mg/L	COD	1000 mg/L				COD	3574 mg/L	COD	604 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	857 mg/L	BOD (3 days at 27°C)	27 mg/L		
	SS	-	SS	100 mg/L				SS	774 mg/L	SS	103 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	72 mg/L	NH ₃ -N	57 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	13.44 mg/L	Phenolic Compounds	0.43 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of December - 2018	40	Nil	pH	7.475	pH	6.97	pH, Flow Meter, TOC, TSS	Storage – 250 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1108 mg/L	COD	466 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	282 mg/L	BOD	22 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	163 mg/L	SS	107 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	107 mg/L	NH ₃ -N	48 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	15.505 mg/L	Phenolic Compounds	0.61 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	0.35	Nil	pH	6.89	pH	7.625	pH, Flow Meter, TOC	Storage – 75 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2335 mg/L	COD	551 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	614 mg/L	BOD	28 mg/L		
	SS	-	SS	150 mg/L				SS	631 mg/L	SS	177 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	58 mg/L	NH ₃ -N	42 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.785 mg/L	Phenolic Compounds	0.47 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of December - 2018	0.35	Nil	pH	7.32	pH	7.52	pH, TOC, TSS, Flow meter	Storage – 30 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1275 mg/L	COD	230 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	294 mg/L	BOD	27 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	218 mg/L	SS	126 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	67 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.66 mg/L	Phenolic Compounds	0.45 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of December - 2018	40	Nil	pH	6.72	pH	6.94	pH, Flow Meter, TOC	Storage – 1600 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1090 mg/L	COD	284 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	272 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	148 mg/L	SS	122 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	42 mg/L	NH ₃ -N	24 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.09 mg/L	Phenolic Compounds	0.27 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of December - 2018	95	Nil	pH	7.18	pH	7.38	pH, Flow Meter, COD, BOD, TSS	Storage- 600 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1015 mg/L	COD	211 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	248 mg/L	BOD	21 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	280 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	46 mg/L	NH ₃ -N	22 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.44 mg/L	Phenolic Compounds	0.28 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	88	Nil	pH	7.01	pH	7.53	pH, Flow Meter, TOC, COD	Storage – 600 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1005 mg/L	COD	226 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	216 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	186 mg/L	SS	48 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	46 mg/L	NH ₃ -N	24 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.44 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of December - 2018	35	Nil	pH	7.11	pH	7.25	pH, Flow Meter, COD Meter including TOC	Storage – 350 MT
	COD	1000 mg/L	COD	250 mg/L				COD	944 mg/L	COD	193 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	248 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	144 mg/L	SS	98 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.26 mg/L	Phenolic Compounds	0.28 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	No visit in the month of December - 2018	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	22	Nil	pH	7.36	pH	7.81	pH, Flow meter, COD, BOD, TSS	Storage - 50 MT
	COD	1000 mg/L	COD	250 mg/L				COD	793 mg/L	COD	150 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	198 mg/L	BOD	18 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	256 mg/L	SS	18 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	24 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.28 mg/L	Phenolic Compounds	0.28 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of December - 2018	55	Nil	pH	8.02	pH	7.76	pH, Flow Meter, TOC & DO Meter	Storage – 11000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1150 mg/L	COD	268 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	272 mg/L	BOD	33 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	354 mg/L	SS	95 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	60 mg/L	NH ₃ -N	46 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.11 mg/L	Phenolic Compounds	0.53 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of December - 2018	8.5	Nil	pH	7.225	pH	8.06	Flow Meter, TOC meter	Storage – 650 MT
	COD	1000 mg/L	COD	250 mg/L				COD	900 mg/L	COD	212 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	214 mg/L	BOD (3 days at 27°C)	30 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	276 mg/L	SS	82 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	173 mg/L	NH ₃ -N	35 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.865 mg/L	Phenolic Compounds	0.18 mg/L		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	Average value of December - 2018	1.5	Nil	pH	6.97	pH	7.71	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	2252 mg/L	COD	520 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	840 mg/L	BOD	124 mg/L		
	SS	200 mg/L	SS	100 mg/L				SS	310 mg/L	SS	290 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	210 mg/L	NH ₃ -N	191 mg/L		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	No visit in the month of December - 2018	6.00	Nil	pH	-	pH	-	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	Average value of December - 2018	7.00	Nil	pH	9.88	pH	7.45	pH, Flow meter	Storage – 200MT
	COD	1000 mg/L	COD	250 mg/L				COD	1809 mg/L	COD	131 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	542 mg/L	BOD	37 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	692 mg/L	SS	52 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20.20 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of December - 2018	0.07	Nil	pH	6.83	pH	6.82	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	905 mg/L	COD	496 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	270 mg/L	BOD	69 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	254 mg/L	SS	358 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	16.38 mg/L	NH ₃ -N	20 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of December - 2018	0.007	Nil	pH	1.61	pH	7.20	-	-
	COD	250 mg/L	COD	100 mg/L				COD	57 mg/L	COD	8 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	13 mg/L	BOD	1 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	420 mg/L	SS	52 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	14 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of December - 2018	0.35	Nil	pH	-	pH	7.20	-	Storage – 15 MT Disposal – 30 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	498 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	137 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	134 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	26 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.04		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of December - 2018	0.10	Nil	pH	-	pH	-	pH, COD, BOD, TSS, Ammonical Nitrogen	--
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	-	BOD(3 days at 27° C)	-		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		