

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	8.5	Nil	pH	7.705	pH	8.04	Flow Meter, TOC meter	Storage – 475 MT
	COD	1000 mg/L	COD	250 mg/L				COD	309 mg/L	COD	170 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	59 mg/L	BOD (3 days at 27°C)	21 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	99 mg/L	SS	90 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	9 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.695 mg/L	Phenolic Compounds	0.32 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of July - 2018	55	Nil	pH	7.52	pH	7.51	pH, Flow Meter, TOC & DO Meter	Storage- 7592 MT Disposal – 6635 MT
	COD	1000 mg/L	COD	250 mg/L				COD	895 mg/L	COD	266 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	259 mg/L	BOD	36 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	255 mg/L	SS	98 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	75 mg/L	NH ₃ -N	48 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.10 mg/L	Phenolic Compounds	0.337 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of July - 2018	40	Nil	pH	7.06	pH	7.33	pH, Flow Meter, TOC	Storage – 750 MT Disposal – 38 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1051 mg/L	COD	275 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	341 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	214 mg/L	SS	79 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	48 mg/L	NH ₃ -N	26 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.51 mg/L	Phenolic Compounds	0.32 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2018	0.35	Nil	pH	7.15	pH	7.31	pH, TOC, TSS, Flow meter	Storage – 29 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1350 mg/L	COD	257 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	398 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	413 mg/L	SS	121 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	63 mg/L	NH ₃ -N	37 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.58 mg/L	Phenolic Compounds	0.35 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	88	Nil	pH	7.14	pH	7.70	pH, Flow Meter, TOC, COD	Storage – 1500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1188 mg/L	COD	276 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	355 mg/L	BOD	27 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	288 mg/L	SS	18 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	31 mg/L	NH ₃ -N	14 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.53 mg/L	Phenolic Compounds	0.23 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July – 2018	95	Nil	pH	7.10	pH	7.36	pH, Flow Meter, COD, BOD, TSS	Storage- 600 MT Disposal- 112 MT
	COD	1000 mg/L	COD	250 mg/L				COD	997 mg/L	COD	280 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	310 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	168 mg/L	SS	92 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.51 mg/L	Phenolic Compounds	0.27 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	22	Nil	pH	7.32	pH	7.65	pH, Flow meter, COD, BOD, TSS	Storage - 150 MT Disposal – 45 MT
	COD	1000 mg/L	COD	250 mg/L				COD	872 mg/L	COD	164 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	235 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	156 mg/L	SS	8 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	29 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.42 mg/L	Phenolic Compounds	0.23 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of July – 2018	35	Nil	pH	7.42	pH	7.96	pH, Flow Meter, COD Meter including TOC	Storage - 230 MT
	COD	1000 mg/L	COD	250 mg/L				COD	702 mg/L	COD	197 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	215 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	200 mg/L	SS	28 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	31 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.23 mg/L	Phenolic Compounds	0.35 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	No visit in the month of July – 2018	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	-	pH	5.5-8.5	Average value of July - 2018	0.35	Nil	pH	7.35	pH	7.67	pH, Flow Meter, TOC	Storage – 100 MT
	COD	3500 mg/L	COD	500 mg/L				COD	2758 mg/L	COD	824 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	896 mg/L	BOD	28 mg/L		
	SS	-	SS	100 mg/L				SS	160 mg/L	SS	65 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	101 mg/L	NH ₃ -N	75 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	4.995 mg/L	Phenolic Compounds	0.965 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of July - 2018	1.10	Nil	pH	6.925	pH	7.3	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	3048 mg/L	COD	691 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	999 mg/L	BOD (3 days at 27°C)	25 mg/L		
	SS	-	SS	100 mg/L				SS	183 mg/L	SS	33 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.34 mg/L	Phenolic Compounds	0.23 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of July - 2018	40	Nil	pH	7.435	pH	6.90	pH, Flow Meter, TOC, TSS	Storage – 4090 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1321 mg/L	COD	418 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	431 mg/L	BOD	22 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	141 mg/L	SS	53 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	169 mg/L	NH ₃ -N	40 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.77 mg/L	Phenolic Compounds	0.1 mg/L		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of July - 2018	4.80	Nil	pH	7.51	pH	7.22	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1111 mg/L	COD	265 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	330 mg/L	BOD	32 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	222 mg/L	SS	64 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	15 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.02 mg/L	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of July - 2018	1.50	Nil	pH	7.81	pH	8.08	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	729 mg/L	COD	280 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	256 mg/L	BOD	41 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	96 mg/L	SS	22 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.72 mg/L	Phenolic Compounds	0.44 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	3.00	Nil	pH	-	pH	7.86	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	1515 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	312 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	370 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	34 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	20	Nil	pH	7.38	pH	7.75	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	2000 mg/L	COD	250 mg/L				COD	1361 mg/L	COD	615 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	292 mg/L	BOD	96 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	323 mg/L	SS	164 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	41 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	0.13 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	1.00	Nil	pH	-	pH	7.39	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 45 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	151 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	32 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.38 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	0.60	Nil	pH	-	pH	7.69	-	Storage – 12 MT
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	255 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	79 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	250 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	10 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	0.015	Nil	pH	-	pH	8.30	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	253 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	45 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	60 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	4 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	0.60	Nil	pH	6.01	pH	7.35	Flow Meter	Storage - 320 MT
	COD	2000 mg/L	COD	250 mg/L				COD	933 mg/L	COD	171 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	242 mg/L	BOD	37 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	2204 mg/L	SS	25 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	70 mg/L	NH ₃ -N	47 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of July - 2018	0.35	Nil	pH	7.63	pH	7.8	-	Storage – 20 MT
	COD	2000 mg/L	COD	250 mg/L				COD	2051 mg/L	COD	462 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	863 mg/L	BOD	111 mg/L		
	SS	-	SS	100 mg/L				SS	753 mg/L	SS	30 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35 mg/L	NH ₃ -N	31 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.09 mg/L	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of July - 2018	1.3	Nil	pH	-	pH	7.26	pH, TOC meter	Storage - 25 MT
	COD	850 mg/L	COD					COD	33 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	6 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	1 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of July - 2018	0.10	Nil	pH	-	pH	7.65	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	36 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	7 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	20 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	4 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of July - 2018	1.00	Nil	pH	-	pH	7.52	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	490 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	135 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	320 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	45 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	--		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of July - 2018	1.50	Nil	pH	-	pH	7.95	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250mg/L				COD	-	COD	296 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	53 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	162 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	23 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No Sampling in the month of July – 2018	0.007	Nil	pH	-	pH	-	-	Storage – 9 MT
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	Average value of July - 2018	7.00	Nil	pH	10.935	pH	8.19	pH, Flow meter	Storage- 90 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1029 mg/L	COD	135 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	333 mg/L	BOD	39 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	578 mg/L	SS	95 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	No visit in the month of July – 2018	0.07	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of July - 2018	6.00	Nil	pH	10.93	pH	8.71	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	209 mg/L	COD	106 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	50 mg/L	BOD	33 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	236 mg/L	SS	388 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	26 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of July – 2018	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of July - 2018	0.10	Nil	pH	6.65	pH	6.86	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	194 mg/L	COD	36 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	79 mg/L	BOD(3 days at 27° C)	11 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	112 mg/L	SS	42 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	3 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		