

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	23	Nil	pH	7.415	pH	7.195	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 2100 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1105 mg/L	COD	398 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	252 mg/L	BOD	40 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	306 mg/L	SS	45 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	49 mg/L	NH ₃ -N	21 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.39 mg/L	Phenolic Compounds	0.11 mg/L		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.2	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	1.1	Nil	pH	7.02	pH	7.30	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 120 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1015 mg/L	COD	229 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	466 mg/L	BOD	27 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	303 mg/L	SS	68 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	31 mg/L	NH ₃ -N	7 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.94 mg/L	Phenolic Compounds	0.49 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.45	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.7	Nil	pH	-	pH	7.14	Flow Meter	Storage – 170 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	175 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	42 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	48 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	53 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.8	Nil	pH	8.14	pH	8.19	-	Storage – 4 MT Disposal – 16 MT
	COD	750 mg/L	COD	250 mg/L				COD	866 mg/L	COD	444 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	313 mg/L	BOD	140 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	158 mg/L	SS	84 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	116 mg/L	NH ₃ -N	53 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.28 mg/L	Phenolic Compounds	BDL		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	4.5	Nil	pH	7.39	pH	6.56	-	Storage – 2000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1791 mg/L	COD	496 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	395 mg/L	BOD	52 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1036 mg/L	SS	110 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	47 mg/L	NH ₃ -N	6 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.61 mg/L	Phenolic Compounds	0.07 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.040	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.020	Nil	pH	8.08	pH	8.06	-	Storage – 20 MT Disposal - 16 MT
	COD	1500 mg/L	COD	250 mg/L				COD	1385 mg/L	COD	163 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	294 mg/L	BOD	23 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	430 mg/L	SS	74 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	85 mg/L	NH ₃ -N	4 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	100	Nil	pH	6.63	pH	7.65	-	Storage 600 MT Disposal – 93 MT
	COD	1200 mg/L	COD	250 mg/L				COD	756 mg/L	COD	238 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	259 mg/L	BOD	72 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	555 mg/L	SS	60 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	56 mg/L	NH ₃ -N	54 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.27 mg/L	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of June - 2019	0.10	Nil	pH	-	pH	7.64	pH, DO meter, TOC meter, Flow meter	Storage – 4 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	22 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	10 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	No Visit in the month of June - 2019	1.8	Nil	pH	-	pH	-	pH, TOC meter	-
	COD	850 mg/L	COD					COD	-				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	-				
	SS	300 mg/L	SS					SS	-				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	-				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	-				

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.3	Nil	pH	-	pH	7.72	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	162 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	65 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	60 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	15 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of June - 2019	4	Nil	pH	-	pH	8.09	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	196 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	36 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	30 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	6 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12	pH	5 to 9	pH	6.5 to 8.5	Average value of June - 2019	6.4	Nil	pH	-	pH	6.75	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	238 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	-	BOD	37 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	-	SS	112 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of June - 2019	2.2	Nil	pH	7.28	pH	7.69	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	486 mg/L	COD	229 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	122 mg/L	BOD	35 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	160 mg/L	SS	16 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	0.5 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.5	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	2.31	Nil	pH	7.44	pH	7.67	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	4810 mg/L	COD	704 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	759 mg/L	BOD (3 days at 27°C)	25 mg/L		
	SS	-	SS	150 mg/L				SS	5500 mg/L	SS	16 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	48 mg/L	NH ₃ -N	53 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	19.98 mg/L	Phenolic Compounds	0.51 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
	Parameter	Value	Parameter	Value				Parameter	Value	Parameter	Value		
40	pH	6.5-8.5	pH	6-9	Average value of June - 2019	31.92	Nil	pH	7.6167	pH	6.745	pH, Flow Meter, TOC, TSS	-
	COD	1000 mg/L	COD	500 mg/L				COD	895 mg/L	COD	554 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	74 mg/L	NH ₃ -N	57 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.02	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.45	Nil	pH	6.82	pH	7.32	pH, Flow Meter, TOC	-
	COD	10000 mg/L	COD	1000 mg/L				COD	2295 mg/L	COD	754 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	243 mg/L	BOD	20 mg/L		
	SS	-	SS	150 mg/L				SS	162 mg/L	SS	40 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	38 mg/L	NH ₃ -N	37 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	1.55 mg/L	Phenolic Compounds	BDL		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of June - 2019	0.236	Nil	pH	7.49	pH	7.46	pH, TOC, TSS, Flow meter	Storage – 235 MT
	COD	3000 mg/L	COD	250 mg/L				COD	2430 mg/L	COD	190 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	715 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	364 mg/L	SS	66 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	48 mg/L	NH ₃ -N	36 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.27 mg/L	Phenolic Compounds	0.45 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of June - 2019	32.83	Nil	pH	7.12	pH	7.44	pH, Flow Meter, TOC	Storage – 350 MT
	COD	1000 mg/L	COD	250 mg/L				COD	980 mg/L	COD	344 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	310 mg/L	BOD	43 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	292 mg/L	SS	54 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	23 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.14 mg/L	Phenolic Compounds	0.41 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
150	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of June - 2019	98	Nil	pH	7.15	pH	7.44	pH, Flow Meter, COD, BOD, TSS	Storage – 500 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1057 mg/L	COD	238 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	264 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	350 mg/L	SS	94 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	53 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.41 mg/L	Phenolic Compounds	0.39 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	81.5	Nil	pH	7.06	pH	7.53	pH, Flow Meter, TOC, COD	Storage – 3200 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1078 mg/L	COD	336 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	208 mg/L	BOD	41 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	162 mg/L	SS	48 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	40 mg/L	NH ₃ -N	18 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	1.24 mg/L	Phenolic Compounds	0.57 mg/L		

M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.84	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.5	Nil	pH	7.12	pH	7.13	-	Storage – 5 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	500 mg/L	COD	68 mg/L		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	85 mg/L	BOD	12 mg/L		
	SS	<150 mg/L	SS	<5 mg/L				SS	68 mg/L	SS	10 mg/L		
	NH ₃ -N	-	NH ₃ -N	-				NH ₃ -N	47 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	0.41 mg/L	Phenolic Compounds	0.36 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of June - 2019	29	Nil	pH	6.82	pH	7.13	pH, Flow Meter, COD Meter including TOC	Storage – 400 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1071 mg/L	COD	326 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	250 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	184 mg/L	SS	92 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	55 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.57 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.75	pH	-	pH	6.5 to 8.5	No Visit in the month of June - 2019	1.39	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	25	Nil	pH	7.85	pH	7.87	pH, Flow meter, COD, BOD, TSS	Storage – 1000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	714 mg/L	COD	214 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	146 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	110 mg/L	SS	62 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	45 mg/L	NH ₃ -N	11 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.10 mg/L	Phenolic Compounds	0.36 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of June - 2019	54	Nil	pH	7.865	pH	7.51	pH, Flow Meter, TOC & DO Meter	Storage – 16594 MT
	COD	1000 mg/L	COD	250 mg/L				COD	922 mg/L	COD	237 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	201 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	125 mg/L	SS	76 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	48 mg/L	NH ₃ -N	33 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	4.85 mg/L	Phenolic Compounds	0.29 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	9	Nil	pH	8.56	pH	8.42	Flow Meter, TOC meter	Storage – 115 MT
	COD	1000 mg/L	COD	250 mg/L				COD	546 mg/L	COD	115 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	142 mg/L	BOD (3 days at 27°C)	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	66 mg/L	SS	22 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	4 mg/L	NH ₃ -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.641 mg/L	Phenolic Compounds	0.302 mg/L		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No Visit in the month of June - 2019	5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of June - 2019	10	Nil	pH	-	pH	9.55	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	280 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	75 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	908 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	25 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	Average value of June - 2019	7.00	Nil	pH	9.515	pH	7.52	pH, Flow meter	Storage – 70 MT
	COD	1000 mg/L	COD	250 mg/L				COD	807 mg/L	COD	208 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	222 mg/L	BOD	56 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	747 mg/L	SS	148 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	14 mg/L	NH ₃ -N	15 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of June - 2019	0.09	Nil	pH	6.75	pH	8.385	pH, Flow Meter	Storage – 15 MT
	COD	1000 mg/L	COD	100 mg/L				COD	822 mg/L	COD	357 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	153 mg/L	BOD	100 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	130 mg/L	SS	62 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	5 mg/L	NH ₃ -N	15 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of June - 2019	0.013	Nil	pH	7.9	pH	8.3	-	Storage – 3 MT
	COD	250 mg/L	COD	100 mg/L				COD	33 mg/L	COD	8 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	12 mg/L	BOD	2 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	440 mg/L	SS	26 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	15 mg/L	NH ₃ -N	0.5 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.35	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of June - 2019	0.35	Nil	pH	-	pH	7.53	-	Storage – 4 MT Disposal – 50 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	149 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	21 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	41 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	4 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.34 mg/L		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of June - 2019	0.15	Nil	pH	7.27	pH	7.27	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	393 mg/L	COD	68 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	121 mg/L	BOD(3 days at 27° C)	15 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	111 mg/L	SS	34 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	28 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.35 mg/L	Phenolic Compounds	0 mg/L		