

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	8.5	Nil	pH	7.06	pH	7.94	Flow Meter, TOC meter	Storage – 550 MT
	COD	1000 mg/L	COD	250 mg/L				COD	666 mg/L	COD	265 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	142 mg/L	BOD (3 days at 27°C)	36 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	372 mg/L	SS	106 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	16 mg/L	NH ₃ -N	22 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.89 mg/L	Phenolic Compounds	0.53 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of May - 2018	55	Nil	pH	8.00	pH	7.69	pH, Flow Meter, TOC & DO Meter	Storage- 1000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1069 mg/L	COD	267 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	269 mg/L	BOD	45 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	239 mg/L	SS	69 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	74 mg/L	NH ₃ -N	50 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.19 mg/L	Phenolic Compounds	0.37 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	No sampling in the month of May - 2018	40	Nil	pH	-	pH	-	pH, Flow Meter, TOC	Storage – 100 MT
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	400 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of May - 2018	0.35	Nil	pH	6.90	pH	7.20	pH, TOC, TSS, Flow meter	Storage – 20 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1671 mg/L	COD	287 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	486 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	708 mg/L	SS	34 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	45 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.66 mg/L	Phenolic Compounds	0.37 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	88	Nil	pH	7.00	pH	7.36	pH, Flow Meter, TOC, COD	Storage – 1015 MT Disposal – 856 MT
	COD	1000 mg/L	COD	250 mg/L				COD	954 mg/L	COD	239 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	305 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	244 mg/L	SS	150 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36 mg/L	NH ₃ -N	15 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.63 mg/L	Phenolic Compounds	0.31 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of May – 2018	95	Nil	pH	7.02	pH	7.93	pH, Flow Meter, COD, BOD, TSS	Storage- 127 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1057 mg/L	COD	282 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	305 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	168 mg/L	SS	54 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	45 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.50 mg/L	Phenolic Compounds	0.27 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	22	Nil	pH	7.34	pH	7.81	pH, Flow meter, COD, BOD, TSS	Storage -50 MT Disposal – 654 MT
	COD	1000 mg/L	COD	250 mg/L				COD	963 mg/L	COD	201 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	315 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	145 mg/L	SS	30 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	33 mg/L	NH ₃ -N	10 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.53 mg/L	Phenolic Compounds	0.23 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of May – 2018	35	Nil	pH	8.02	pH	7.99	pH, Flow Meter, COD Meter including TOC	Storage - 70 MT Disposed – 27 MT
	COD	1000 mg/L	COD	250 mg/L				COD	878 mg/L	COD	205 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	205 mg/L	BOD	30 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	130 mg/L	SS	22 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	36 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.53 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	No visit in the month of May – 2018	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	-	pH	5.5-8.5	Average value of May - 2018	0.35	Nil	pH	7.24	pH	7.8	pH, Flow Meter, TOC	Storage – 125 MT
	COD	3500 mg/L	COD	500 mg/L				COD	2911 mg/L	COD	586 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	862 mg/L	BOD	25 mg/L		
	SS	-	SS	100 mg/L				SS	443 mg/L	SS	58 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	75 mg/L	NH ₃ -N	42 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.1 mg/L	Phenolic Compounds	0.96 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of May - 2018	1.10	Nil	pH	1.99	pH	7.56	pH, Flow, COD, BOD, TSS, TOC	Storage - Nil
	COD	11000 mg/L	COD	1000 mg/L				COD	4718 mg/L	COD	695 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	1362 mg/L	BOD (3 days at 27°C)	27 mg/L		
	SS	-	SS	100 mg/L				SS	709 mg/L	SS	46 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	65 mg/L	NH ₃ -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	11.085 mg/L	Phenolic Compounds	0.42 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of May - 2018	40	Nil	pH	7.67	pH	6.92	pH, Flow Meter, TOC, TSS	Storage – 100 MT
	COD	1000 mg/L	COD	500 mg/L				COD	933 mg/L	COD	411 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	142 mg/L	SS	61 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	72 mg/L	NH ₃ -N	34 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of May - 2018	4.80	Nil	pH	7.08	pH	7.46	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1035 mg/L	COD	437 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	191 mg/L	BOD	78 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	170 mg/L	SS	141 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	174 mg/L	NH ₃ -N	0.46 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.099 mg/L	Phenolic Compounds	BDL		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of May - 2018	1.50	Nil	pH	7.46	pH	7.99	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	--
	COD	2000 mg/L	COD	250 mg/L				COD	1058 mg/L	COD	197 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	330 mg/L	BOD	34 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	92 mg/L	SS	25 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	2 mg/L	NH ₃ -N	4 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.53 mg/L	Phenolic Compounds	0.17 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	3.00	Nil	pH	-	pH	-	-	Storage – 3000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	1189 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	20	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD, BOD, TSS	Storage- 150 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1700 mg/L	COD	528 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	1.00	Nil	pH	-	pH	7.26	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 30 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	237 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	42 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	72 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	5 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	3.03 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	0.60	Nil	pH	-	pH	7.67	-	Storage – 10 MT
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	285 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	112 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	273 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	55 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.13 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	0.015	Nil	pH	-	pH	8.10	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	670 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	191 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	145 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.74 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2018	0.60	Nil	pH	6.36	pH	7.47	Flow Meter	Storage - 80 MT
	COD	2000 mg/L	COD	250 mg/L				COD	521 mg/L	COD	244 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	154 mg/L	BOD	59 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	673 mg/L	SS	91 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	82 mg/L	NH ₃ -N	109 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.07 mg/L	Phenolic Compounds	0.62 mg/L		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	No sampling in the month of May – 2018	0.35	Nil	pH	-	pH	-	-	Storage – 3 MT Disposed – 39 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	-	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	No sampling in the month of May – 2018	1.3	Nil	pH	-	pH	-	pH, TOC meter	Storage - 6 MT
	COD	850 mg/L	COD					COD	-	COD	-		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	-	BOD (3 days at 27°C)	-		
	SS	300 mg/L	SS					SS	-	SS	-		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of May - 2018	0.10	Nil	pH	-	pH	7.61	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	20 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	6 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	18 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	7 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	No sampling in the month of May – 2018	1.00	Nil	pH	-	pH	-	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	No sampling in the month of May – 2018	1.50	Nil	pH	-	pH	-	-	Sludge is used as Manure
	COD	4500 mg/L	COD	250mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No sampling in the month of May – 2018	0.007	Nil	pH	-	pH	-	-	Storage – 8 MT
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	No visit in the month of May – 2018	7.00	Nil	pH	-	pH	-	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	No visit in the month of May – 2018	0.07	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	No visit in the month of May – 2018	6.00	Nil	pH	-	pH	-	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of May – 2018	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	No visit in the month of May – 2018	0.10	Nil	pH	-	pH	-	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	-	BOD(3 days at 27° C)	-		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		