

**M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	20	Nil	pH	7.49	pH	7.22	pH, Flow Meter, TOC, COD, BOD, TSS	Storage – 4360 MT
	COD	2000 mg/L	COD	250 mg/L				COD	1276 mg/L	COD	425 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	325 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	220 mg/L	SS	58 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	58 mg/L	NH <sub>3</sub> -N	6 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.76 mg/L	Phenolic Compounds	BDL		

**M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	1.00	Nil	pH	7.01	pH	7.09	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 70 MT
	COD	2000 mg/L	COD	250 mg/L				COD	663 mg/L	COD	318 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	222 mg/L	BOD	49 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	560 mg/L	SS	52 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	21 mg/L	NH <sub>3</sub> -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.71 mg/L	Phenolic Compounds	0.15 mg/L		

**M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	0.60	Nil	pH	6.30	pH	6.60	Flow Meter	Storage – 150 MT
	COD	2000 mg/L	COD	250 mg/L				COD	567 mg/L	COD	142 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	78 mg/L	BOD	21 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	964 mg/L	SS	110 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	87 mg/L	NH <sub>3</sub> -N	54 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

**M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of May - 2019	0.60	Nil	pH	-	pH	-	-	-
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	3.00	Nil	pH	7.39	pH	7.35	-	Storage – 3000 MT
	COD	2000 mg/L	COD	250 mg/L				COD	2347 mg/L	COD	1243 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	938 mg/L	SS	461 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	63 mg/L	NH <sub>3</sub> -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.35 mg/L	Phenolic Compounds	0.427 mg/L		

**M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	0.015	Nil	pH	7.21	pH	7.41	-	Storage – 8 MT Disposal - 16 MT
	COD	1500 mg/L	COD	250 mg/L				COD	2466 mg/L	COD	1348 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	515 mg/L	BOD	165 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	608 mg/L	SS	506 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	33 mg/L	NH <sub>3</sub> -N	53 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	4.74 mg/L	Phenolic Compounds	1.1		

**M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	100	Nil	pH	7.21	pH	7.9325	-	Storage 600 MT Disposal – 93 MT
	COD	1200 mg/L	COD	250 mg/L				COD	806 mg/L	COD	336 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	284 mg/L	BOD	113 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	516 mg/L	SS	82 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	62 mg/L	NH <sub>3</sub> -N	65 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.38 mg/L	Phenolic Compounds	0.1545 mg/L		

**M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of May - 2019	0.10	Nil	pH	-	pH	8.695	pH, DO meter, TOC meter, Flow meter	Storage – 3 MT
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	52 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	10 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	20 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	1.285 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		



**M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of May - 2019	1.3	Nil	pH	7.53	pH	6.805	pH, TOC meter	Storage – 17 MT Disposal – 20 MT
	COD	850 mg/L	COD					COD	333 mg/L	COD	12 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	92 mg/L	BOD (3 days at 27°C)	2 mg/L		
	SS	300 mg/L	SS					SS	70 mg/L	SS	6 mg/L		
	NH <sub>3</sub> -N	<10 mg/L	NH <sub>3</sub> -N					NH <sub>3</sub> -N	27 mg/L	NH <sub>3</sub> -N	2 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	0.13	Phenolic Compounds	BDL		

**M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	No Visit in the month of May - 2019	1.00	Nil	pH	-	pH	-	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	No Visit in the month of May - 2019	1.50	Nil	pH	-	pH	-	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of May - 2019	4.80	Nil	pH	7.08	pH	7.09	pH, COD, BOD, TSS, NH <sub>3</sub> -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1739 mg/L	COD	218 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	246 mg/L	BOD	41 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	280 mg/L	SS	88 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	320 mg/L	NH <sub>3</sub> -N	3 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.50 mg/L	Phenolic Compounds	BDL		

**M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of May - 2019	1.50	Nil	pH	7.89	pH	8.15	pH, Flow Meter, TOC, TSS, Color, NH <sub>3</sub> -N	Storage – 150 MT Disposal – 32 MT
	COD	2000 mg/L	COD	250 mg/L				COD	359 mg/L	COD	186 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	92 mg/L	BOD	22 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	132 mg/L	SS	24 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	3 mg/L	NH <sub>3</sub> -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of May - 2019	1.10	Nil	pH	7.13	pH	7.05	pH, Flow, COD, BOD, TSS, TOC	-
	COD	11000 mg/L	COD	1000 mg/L				COD	4349 mg/L	COD	916 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	939 mg/L	BOD (3 days at 27°C)	31 mg/L		
	SS	-	SS	100 mg/L				SS	154 mg/L	SS	46 mg/L		
	NH <sub>3</sub> -N	100 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	31 mg/L	NH <sub>3</sub> -N	31 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	16.60 mg/L	Phenolic Compounds	0.55 mg/L		

**M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of May - 2019	40	Nil	pH	7.835	pH	6.877	pH, Flow Meter, TOC, TSS	Storage – 300 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1442 mg/L	COD	561 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	150 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	150 mg/L	NH <sub>3</sub> -N	43 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	0.35	Nil	pH	7.12	pH	7.59	pH, Flow Meter, TOC	Storage – 110 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2395 mg/L	COD	889 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	534 mg/L	BOD	30 mg/L		
	SS	-	SS	150 mg/L				SS	408 mg/L	SS	56 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	33 mg/L	NH <sub>3</sub> -N	30 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	0.73 mg/L	Phenolic Compounds	BDL		



**M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of May - 2019	0.35	Nil	pH	7.47	pH	7.73	pH, TOC, TSS, Flow meter	-
	COD	3000 mg/L	COD	250 mg/L				COD	2215 mg/L	COD	205 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	38 mg/L	BOD	25 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	556 mg/L	SS	75 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	160 mg/L	NH <sub>3</sub> -N	43 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.73 mg/L	Phenolic Compounds	0.36 mg/L		

**M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of May - 2019	40	Nil	pH	7.89	pH	7.53	pH, Flow Meter, TOC	Storage – 100 MT Disposal – 556 MT
	COD	1000 mg/L	COD	250 mg/L				COD	940 mg/L	COD	346 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	195 mg/L	BOD	45 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	170 mg/L	SS	68 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	40 mg/L	NH <sub>3</sub> -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.36 mg/L	Phenolic Compounds	0.32 mg/L		

**M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of May - 2019	95	Nil	pH	7.12	pH	7.855	pH, Flow Meter, COD, BOD, TSS	Storage – 500 MT Disposal – 194 MT
	COD	1000 mg/L	COD	250 mg/L				COD	935 mg/L	COD	146 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	290 mg/L	BOD	20 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	88 mg/L	SS	56 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	34 mg/L	NH <sub>3</sub> -N	8 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.42 mg/L	Phenolic Compounds	0.4 mg/L		

**M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	88	Nil	pH	6.90	pH	7.52	pH, Flow Meter, TOC, COD	Storage – 1100 MT Disposal – 252 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1105 mg/L	COD	348 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	235 mg/L	BOD	40 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	90 mg/L	SS	70 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	66 mg/L	NH <sub>3</sub> -N	17 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.36 mg/L	Phenolic Compounds	0.57 mg/L		

**M/s. CETP of Kejriwal Integrated Textile Park Ltd – KITPL**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.84	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	0.5	Nil	pH	8.11	pH	7.97	-	Storage – 3.5 MT
	COD	<500 mg/L	COD	<20 mg/L				COD	673 mg/L	COD	68 mg/L		
	BOD	<200 mg/L	BOD	<5 mg/L				BOD	96 mg/L	BOD	8 mg/L		
	SS	<150 mg/L	SS	<5 mg/L				SS	120 mg/L	SS	18 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-				NH <sub>3</sub> -N	29 mg/L	NH <sub>3</sub> -N	18 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	-				Phenolic Compounds	0.34 mg/L	Phenolic Compounds	0.34 mg/L		

**M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of May - 2019	35	Nil	pH	7.31	pH	7.45	pH, Flow Meter, COD Meter including TOC	Storage – 240 MT Disposal – 27 MT
	COD	1000 mg/L	COD	250 mg/L				COD	925 mg/L	COD	201 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	285 mg/L	BOD	20 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	194 mg/L	SS	62 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	18 mg/L	NH <sub>3</sub> -N	20 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.41 mg/L	Phenolic Compounds	0.39 mg/L		

**M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	Average value of May - 2019	1.00	Nil	pH	7.47	pH	7.26	pH, Flow Meter	Storage – 1.5 MT Disposal – 5 MT
	COD	500 mg/L	COD	100 mg/L				COD	198 mg/L	COD	65 mg/L		
	BOD	200 mg/L	BOD	30 mg/L				BOD	28 mg/L	BOD	10 mg/L		
	SS	-	SS	<60 mg/L				SS	84 mg/L	SS	16 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.36 mg/L	Phenolic Compounds	0.32 mg/L		

**M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	22	Nil	pH	7.635	pH	7.675	pH, Flow meter, COD, BOD, TSS	Storage – 200 MT Disposal – 5212 MT
	COD	1000 mg/L	COD	250 mg/L				COD	943 mg/L	COD	205 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	214 mg/L	BOD	22 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	303 mg/L	SS	53 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	32 mg/L	NH <sub>3</sub> -N	20 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.51 mg/L	Phenolic Compounds	0.425 mg/L		



**M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of May - 2019	55	Nil	pH	7.463	pH	7.55	pH, Flow Meter, TOC & DO Meter	Storage – 12760 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1331 mg/L	COD	287 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	328 mg/L	BOD	32 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	111 mg/L	SS	67 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	67 mg/L	NH <sub>3</sub> -N	52 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	5.25 mg/L	Phenolic Compounds	0.641 mg/L		

**M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	8.5	Nil	pH	8.02	pH	8.17	Flow Meter, TOC meter	Storage – 100 MT
	COD	1000 mg/L	COD	250 mg/L				COD	250 mg/L	COD	191 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	68 mg/L	BOD (3 days at 27°C)	23 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	64 mg/L	SS	54 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	18 mg/L	NH <sub>3</sub> -N	39 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.905 mg/L	Phenolic Compounds	0.32 mg/L		

**M/s. Veraval Industries Association, Veraval, Junagadh**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	Average value of May - 2019	1.5	Nil	pH	7.88	pH	7.08	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	788 mg/L	COD	317 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	86 mg/L	BOD	86 mg/L		
	SS	200 mg/L	SS	100 mg/L				SS	328 mg/L	SS	166 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	189 mg/L	NH <sub>3</sub> -N	192 mg/L		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of May - 2019	6.00	Nil	pH	-	pH	8.70	pH, Flow meter, SS, Color, MLSS, COD	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	129 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	25 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	632 mg/L		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-9	Average value of May - 2019	7.00	Nil	pH	-	pH	6.91	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	-	COD	731 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	-	BOD	195 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	126 mg/L		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	5 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	Average value of May - 2019	0.07	Nil	pH	6.6	pH	7.86	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	1515 mg/L	COD	557 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	563 mg/L	BOD	220 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	572 mg/L	SS	94 mg/L		
	NH <sub>3</sub> -N	75 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	36 mg/L	NH <sub>3</sub> -N	20 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

**M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	Average value of May - 2019	0.007	Nil	pH	1.54	pH	7.51	-	Storage – 1 MT
	COD	250 mg/L	COD	100 mg/L				COD	68 mg/L	COD	18 mg/L		
	BOD	100 mg/L	BOD	30 mg/L				BOD	18 mg/L	BOD	3 mg/L		
	SS	250 mg/L	SS	100 mg/L				SS	168 mg/L	SS	36 mg/L		
	NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	15 mg/L	NH <sub>3</sub> -N	1 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	BDL	Phenolic Compounds	BDL		

**M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of May - 2019	0.35	Nil	pH	-	pH	7.94	-	Storage – 13 MT Disposal – 24 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	304 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	63 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	104 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	-	NH <sub>3</sub> -N	46 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.07 mg/L		



**M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch**

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of May - 2019	0.10	Nil	pH	7.36	pH	7.29	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	295 mg/L	COD	30 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	115 mg/L	BOD(3 days at 27° C)	5 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	52 mg/L	SS	26 mg/L		
	NH <sub>3</sub> -N	50 mg/L	NH <sub>3</sub> -N	50 mg/L				NH <sub>3</sub> -N	53 mg/L	NH <sub>3</sub> -N	2 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.4 mg/L	Phenolic Compounds	0.0 mg/L		