

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	8.5	Nil	pH	7.75	pH	8.02	Flow Meter, TOC meter	Storage – 640 MT
	COD	750 mg/L	COD	250 mg/L				COD	811 mg/L	COD	267 mg/L		
	BOD (3 days at 27°C)	300 mg/L	BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	254 mg/L	BOD (3 days at 27°C)	42 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	202 mg/L	SS	81 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	7 mg/L	NH ₃ -N	49 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.68 mg/L	Phenolic Compounds	0.39 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	55	Nil	pH	7.83	pH	7.43	pH, Flow Meter, TOC & DO Meter	Storage - 10200 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1149 mg/L	COD	304 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	301 mg/L	BOD	44 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	206 mg/L	SS	73 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	67 mg/L	NH ₃ -N	35 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.68 mg/L	Phenolic Compounds	0.28 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of November - 2016	40	Nil	pH	67.03	pH	7.48	Flow Meter, TOC	Storage - 1000 MT Disposal – 2030 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1781 mg/L	COD	277 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	533 mg/L	BOD	44 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	430 mg/L	SS	26 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	12 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.46 mg/L	Phenolic Compounds	0.12 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of November - 2016	0.35	Nil	pH	7.66	pH	7.75	Flow Meter, TOC, pH, TSS	Storage – 15 MT Disposal - 22 MT
	COD	4000 mg/L	COD	250 mg/L				COD	1696 mg/L	COD	176 mg/L		
	BOD	1500 mg/L	BOD	30 mg/L				BOD	518 mg/L	BOD	38 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	316 mg/L	SS	58 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	16 mg/L	NH ₃ -N	13 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.53 mg/L	Phenolic Compounds	BDL		

M/s. Pandesara Infrastructure Ltd., GIDC-Pandesara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	88	Nil	pH	6.70	pH	7.30	Flow Meter, TOC	Storage – 50 MT Disposal – 31 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1745 mg/L	COD	268 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	548 mg/L	BOD	51 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	198 mg/L	SS	50 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	27 mg/L	NH ₃ -N	15 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.90 mg/L	Phenolic Compounds	0.33 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of November - 2016	95	Nil	pH	7.35	pH	7.68	pH, Flow Meter, TOC	Disposal - 171 MT
	COD	1000 mg/L	COD	250 mg/L				COD	865 mg/L	COD	205 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	265 mg/L	BOD	47 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	226 mg/L	SS	45 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.62 mg/L	Phenolic Compounds	0.16 mg/L		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	22	Nil	pH	8.10	pH	7.79	pH, Flow meter, MLSS meter, DO meter	Storage - 700 MT Disposal - 574 MT
	COD	1000 mg/L	COD	100 mg/L				COD	930 mg/L	COD	175 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	308 mg/L	BOD	35 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	252 mg/L	SS	50 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	9 mg/L	NH ₃ -N	5 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.41 mg/L	Phenolic Compounds	0.08 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd,Palsana, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6.5 to 8.5	Average value of November - 2016	35	Nil	pH	7.46	pH	8.25	pH, Flow Meter, COD Meter including TOC	Storage - 300 MT
	COD		COD	100 mg/L				COD	1110 mg/L	COD	230 mg/L		
	BOD		BOD	30 mg/L				BOD	340 mg/L	BOD	50 mg/L		
	SS		SS	<60 mg/L				SS	204 mg/L	SS	54 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	6 mg/L	NH ₃ -N	4 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.75 mg/L	Phenolic Compounds	0.12 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	Not Furnished	pH	6.5 to 8.5	Average value of November - 2016	1.00	Nil	pH	6.99	pH	7.86	pH, Flow Meter, COD Meter including TOC	Storage – 2 MT
	COD		COD	100 mg/L				COD	1118 mg/L	COD	462 mg/L		
	BOD		BOD	30 mg/L				BOD	335 mg/L	BOD	87 mg/L		
	SS		SS	<60 mg/L				SS	38 mg/L	SS	26 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	0.62 mg/L	Phenolic Compounds	0.21 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	Not Furnished	pH	5.5-8.5	Average value of November - 2016	0.35	Nil	pH	7.7	pH	761	pH, Flow Meter, TOC	-
	COD		COD	100 mg/L				COD	3116 mg/L	COD	636 mg/L		
	BOD		BOD	30 mg/L				BOD	929 mg/L	BOD	144 mg/L		
	SS		SS	100 mg/L				SS	706 mg/L	SS	79 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	60 mg/L	NH ₃ -N	43 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	2.68 mg/L	Phenolic Compounds	0.73 mg/L		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	Not Furnished	pH	5.5-8.5	Average value of November - 2016	1.10	Nil	pH	1.43	pH	6.87	-	Storage - Nil
	COD		COD	100 mg/L				COD	4774 mg/L	COD	832 mg/L		
	BOD (3 days at 27°C)		BOD (3 days at 27°C)	30 mg/L				BOD (3 days at 27°C)	1482 mg/L	BOD (3 days at 27°C)	173 mg/L		
	SS		SS	100 mg/L				SS	592 mg/L	SS	85 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	49 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	7.4 mg/L	Phenolic Compounds	0.97 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.),(BEAIL), Ankleshwar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	Not Furnished	pH	6-9	Average value of November - 2016	40	Nil	pH	7.87	pH	7.25	pH, Flow Meter, TOC	Storage – 200 MT
	COD		COD	500 mg/L				COD	1375 mg/L	COD	697 mg/L		
	BOD		BOD	100 mg/L				BOD	413 mg/L	BOD	64 mg/L		
	SS		SS	100 mg/L				SS	136 mg/L	SS	82 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	130 mg/L	NH ₃ -N	156 mg/L		
	Phenolic Compounds		Phenolic Compounds	5 mg/L				Phenolic Compounds	1.58 mg/L	Phenolic Compounds	0.72 mg/L		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of November - 2016	4.80	Nil	pH	7.54	pH	7.30	Flow Meter, COD	-
	COD	2000 mg/L	COD	250 mg/L				COD	1435 mg/L	COD	133 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	760 mg/L	BOD	38 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	790 mg/L	SS	136 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	11 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.70 mg/L	Phenolic Compounds	-		

M/s. Enviro Infrastructure Co. Ltd., Umraya(Padra), Vadodara

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of November - 2016	1.50	Nil	pH	8.07	pH	7.84	pH, Flow Meter, TOC and Total Nitrogen	-
	COD	2000 mg/L	COD	250 mg/L				COD	884 mg/L	COD	212 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	279 mg/L	BOD	21 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	590 mg/L	SS	72 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	7 mg/L	NH ₃ -N	4 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	1.41 mg/L	Phenolic Compounds	0.19 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	3.00	Nil	pH	-	pH	7.44	-	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	2571 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	918 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	112 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	56 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	12 mg/L		

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	20	Nil	pH	-	pH	7.87	Flow Meter, TOC, COD, BOD, TSS	-
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	422 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	109 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	106 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	66 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	1.00	Nil	pH	-	pH	7.35	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 85 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	885 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	211 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	120 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	26 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.59 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	0.60	Nil	pH	-	pH	8.30	-	Storage – 14 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	609 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	259 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	116 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	53 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.31 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	0.015	Nil	pH	-	pH	8.36	-	Storage - 15 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	163 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	48 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	60 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	6 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhdyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	0.60	Nil	pH	-	pH	7.06	Flow Meter	Storage – 400 MT
	COD	3000 mg/L	COD	250 mg/L				COD	-	COD	176 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	-	BOD	55 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	136 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	91 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of November - 2016	0.35	Nil	pH	7.69	pH	7.58	-	Storage – 15 MT Disposal – 31 MT
	COD	2500 mg/L	COD	250 mg/L				COD	2223 mg/L	COD	1369 mg/L		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	733 mg/L	BOD	419 mg/L		
	SS	-	SS	100 mg/L				SS	273 mg/L	SS	112 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	98 mg/L	NH ₃ -N	183 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	8.96 mg/L	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt. Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6 to 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of November - 2016	1.3	Nil	pH	7.47	pH	6.58	pH, TOC meter	Storage : 20 MT
	COD	850 mg/L	COD					COD	266 mg/L	COD	14 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	102 mg/L	BOD (3 days at 27°C)	4 mg/L		
	SS	300 mg/L	SS					SS	80 mg/L	SS	4 mg/L		
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	46 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of November - 2016	0.10	Nil	pH	-	pH	7.69	pH, DO meter, TOC meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	56 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	16 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	22 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	2 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	No CETP Inlet norms prescribed as it is a CETP of rice mill cluster	pH	6.5-8.5	Average value of November - 2016	1.00	Nil	pH	-	pH	7.54	-	Sludge is used as Manure
	COD		COD	250 mg/L				COD	-	COD	709 mg/L		
	BOD		BOD	100 mg/L				BOD	-	BOD	287 mg/L		
	SS		SS	100 mg/L				SS	-	SS	174 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	28 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	No CETP inlet norms prescribed as it is the CETP of Rice Mills	pH	6.5-8.5	Average value of November - 2016	1.50	Nil	pH	-	pH	8.04	-	Sludge is used as Manure
	COD		COD	250mg/L				COD	-	COD	181 mg/L		
	BOD		BOD	100 mg/L				BOD	-	BOD	54 mg/L		
	SS		SS	100 mg/L				SS	-	SS	20 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	14 mg/L		
	Phenolic Compounds		Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Rajkot Electroplating Association, Rajkot

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No visit in the month of November - 2016									

M/s. Jay Khodiyar Enviro -Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No visit in the month of November - 2016									

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	Not Furnished	pH	6.5 to 8.5	Average value of November - 2016	7.00	Nil	pH	9.88	pH	7.43	pH, Flow meter	Storage – 110 MT
	COD		COD	250 mg/L				COD	802 mg/L	COD	113 mg/L		
	BOD		BOD	30 mg/L				BOD	268 mg/L	BOD	35 mg/L		
	SS		SS	100 mg/L				SS	282 mg/L	SS	242 mg/L		
	NH ₃ -N		NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds		Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No sampling in the month of November - 2016									

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	-	pH	6.5 to 8.5	Average value of month of November - 2016	6.00	Nil	pH	10.81	pH	9.72	pH, Flow meter, SS, Color, MLSS, COD	Storage - 1800 MT
	COD	-	COD	100 mg/L				COD	161 mg/L	COD	142 mg/L		
	BOD	-	BOD	30 mg/L				BOD	53 mg/L	BOD	43 mg/L		
	SS	-	SS	100 mg/L				SS	985 mg/L	SS	2570 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	10 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Designed Inlet Quality	Final Effluent Quality Stds. Or ZLD Conditions	Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality	Observed Final Effluent Quality	Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
No sampling in the month of November - 2016									

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Designed Inlet Quality		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2016	0.10	Nil	pH	7.6	pH	8.4	pH, COD, BOD, TSS, Ammonical Nitrogen	-
	COD	2000 mg/L	COD	100 mg/L				COD	30 mg/L	COD	50 mg/L		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	30 mg/L				BOD(3 days at 27° C)	10 mg/L	BOD(3 days at 27° C)	14 mg/L		
	SS	800 mg/L	SS	100 mg/L				SS	19 mg/L	SS	12 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	1 mg/L	NH ₃ -N	3 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.32 mg/L	Phenolic Compounds	0.39 mg/L		