

M/s. The Green Environment Services Co. Op. Society Ltd, Vatva, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
16	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of November – 2018	20	Nil	pH	-	pH	-	pH, Flow Meter, TOC, COD, BOD, TSS	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Odhav Enviro Project Ltd., Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.6	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	1.00	Nil	pH	-	pH	7.37	Flow meter at inlet & outlet, COD, pH, TSS, BOD	Storage – 15 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	1046 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	198 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	122 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	46 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.11 mg/L		

M/s. Gujarat Vepari Maha Mandal Sahkari Udhyogik Vasahat Ltd, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	0.60	Nil	pH	-	pH	7.57	Flow Meter	Storage - 300 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	420 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	101 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	128 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	81 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.07 mg/L		

M/s. Odhav Green Enviro Project Association, Odhav, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	0.60	Nil	pH	-	pH	7.62	-	-
	COD	750 mg/L	COD	250 mg/L				COD	-	COD	327 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	95 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	124 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	25 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.19 mg/L		

M/s. Naroda Enviro Project Ltd., Naroda, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
3.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	3.00	Nil	pH	-	pH	8.29	-	-
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	2354 mg/L		
	BOD	700 mg/L	BOD	30 mg/L				BOD	-	BOD	344 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	626 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	73 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.38 mg/L		

M/s. Narol Dyestuff Enviro Society., Narol, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.10	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	0.015	Nil	pH	-	pH	8.08	-	-
	COD	1500 mg/L	COD	250 mg/L				COD	-	COD	407 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	-	BOD	107 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	78 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	9 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	0.15 mg/L		

M/s. Narol Textile Infrastructure & Enviro Management, (ATPA Swarnim Gujarat Enviro P. Ltd), Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	100	Nil	pH	7.150	pH	7.68	-	Storage – 350 MT
	COD	1200 mg/L	COD	250 mg/L				COD	829 mg/L	COD	782 mg/L		
	BOD	500 mg/L	BOD	30 mg/L				BOD	388 mg/L	BOD	218 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	564 mg/L	SS	810 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	63 mg/L	NH ₃ -N	63 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.09 mg/L	Phenolic Compounds	BDL		

M/s. Tata Motors Ltd Vendors Park, Sanand, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6-10.5	pH	6.5-8.5	Average value of November - 2018	0.10	Nil	pH	-	pH	8.32	pH, DO meter, TOC meter, Flow meter	-
	COD	900 mg/L	COD	100 mg/L				COD	-	COD	47 mg/L		
	BOD	250 mg/L	BOD	30 mg/L				BOD	-	BOD	06 mg/L		
	SS	100 mg/L	SS	100 mg/L				SS	-	SS	12 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	1 mg/L		
	Phenolic Compounds	Not Applicable	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. Zydus Infrastructure Pvt.Ltd, Changodar, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.5	pH	6- 8	pH	No outlet norms are prescribed as it is a ZLD based CETP by the means of MEE	Average value of November - 2018	1.3	Nil	pH	-	pH	7.80	pH, TOC meter	-
	COD	850 mg/L	COD					COD	17 mg/L				
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)					BOD (3 days at 27°C)	02 mg/L				
	SS	300 mg/L	SS					SS	4 mg/L				
	NH ₃ -N	<10 mg/L	NH ₃ -N					NH ₃ -N	2 mg/L				
	Phenolic Compounds	<3 mg/L	Phenolic Compounds					Phenolic Compounds	BDL				

M/s. Bavla Eco Project Ltd., Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	5.5-8.5	pH	6.5-8.5	Average value of November - 2018	1.00	Nil	pH	-	pH	8.47	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	175 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	39 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	14 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	3 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Vinayak Jal Sudhikaran Sahakari Mandali Ltd, Bavla, Ahmedabad

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.50	pH	5.5-8.5	pH	6.5-8.5	Average value of November - 2018	1.50	Nil	pH	-	pH	8.58	-	Sludge Is Used As Manure
	COD	4500 mg/L	COD	250 mg/L				COD	-	COD	200 mg/L		
	BOD	1500 mg/L	BOD	100 mg/L				BOD	-	BOD	46 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	-	SS	20 mg/L		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	6 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	Not Applicable				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Nandesari Industrial Association (CETP), GIDC-Nandesari, Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
6.80	pH	5 to 9	pH	6.5 to 8.5	Average value of November - 2018	4.80	Nil	pH	7.13	pH	6.87	pH, COD, BOD, TSS, NH ₃ -N, Color, TOC, Temperature	-
	COD	1500 mg/L	COD	250 mg/L				COD	1552 mg/L	COD	172 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	198 mg/L	BOD	22 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	976 mg/L	SS	52 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	20 mg/L	NH ₃ -N	2 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	3.68 mg/L	Phenolic Compounds	0.33 mg/L		

M/s. Enviro Infrastructure Co. Ltd., Umraya (Padra), Vadodara

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
4.50	pH	5 to 9	pH	6.5 to 8.5	Average value of November - 2018	1.50	Nil	pH	7.685	pH	7.97	pH, Flow Meter, TOC, TSS, Color, NH ₃ -N	-
	COD	2000 mg/L	COD	250 mg/L				COD	501 mg/L	COD	258 mg/L		
	BOD	500 mg/L	BOD	100 mg/L				BOD	119 mg/L	BOD	28 mg/L		
	SS	600 mg/L	SS	100 mg/L				SS	126 mg/L	SS	48 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	13 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.375 mg/L	Phenolic Compounds	BDL		

M/s. Enviro Technology Ltd., GIDC-Ankleshwar, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.80	pH	-	pH	5.5-8.5	Average value of November - 2018	1.10	Nil	pH	6.695	pH	7.195	pH, Flow, COD, BOD, TSS, TOC	Storage – Nil
	COD	11000 mg/L	COD	1000 mg/L				COD	3573 mg/L	COD	662.5 mg/L		
	BOD (3 days at 27°C)	3600 mg/L	BOD (3 days at 27°C)	200 mg/L				BOD (3 days at 27°C)	993 mg/L	BOD (3 days at 27°C)	23.5 mg/L		
	SS	-	SS	100 mg/L				SS	259 mg/L	SS	36 mg/L		
	NH ₃ -N	100 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	64 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	19.505 mg/L	Phenolic Compounds	0.75 mg/L		

M/s. Narmada Clean Tech Ltd., (Bharuch Eco-Aqua Infrastructure Ltd.,) (BEAIL), Ankleshwar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
40	pH	6.5-8.5	pH	6-9	Average value of November - 2018	40	Nil	pH	7.84	pH	6.94	pH, Flow Meter, TOC, TSS	Storage – 150 MT
	COD	1000 mg/L	COD	500 mg/L				COD	1168 mg/L	COD	465 mg/L		
	BOD	200 mg/L	BOD	100 mg/L				BOD	498 mg/L	BOD	139 mg/L		
	SS	150 mg/L	SS	100 mg/L				SS	222 mg/L	SS	88 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	116 mg/L	NH ₃ -N	41 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	4.38 mg/L	Phenolic Compounds	0.57 mg/L		

M/s. Panoli Enviro Technology Ltd., GIDC-Panoil, Bharuch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
1.00	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	0.35	Nil	pH	7.225	pH	7.44	pH, Flow Meter, TOC	Storage – 200 MT
	COD	10000 mg/L	COD	1000 mg/L				COD	2760 mg/L	COD	802 mg/L		
	BOD	3000 mg/L	BOD	200 mg/L				BOD	825 mg/L	BOD	28 mg/L		
	SS	-	SS	150 mg/L				SS	265 mg/L	SS	55 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	38 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	5 mg/L				Phenolic Compounds	4.215 mg/L	Phenolic Compounds	0.6 mg/L		

M/s. Globe Enviro Care Ltd. [chemical units], GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.50	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of November - 2018	0.35	Nil	pH	6.74	pH	8.21	pH, TOC, TSS, Flow meter	Storage – 50 MT
	COD	3000 mg/L	COD	250 mg/L				COD	1211 mg/L	COD	287 mg/L		
	BOD	1200 mg/L	BOD	30 mg/L				BOD	348 mg/L	BOD	28 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	398 mg/L	SS	78 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	57 mg/L	NH ₃ -N	22 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.20 mg/L	Phenolic Compounds	0.31 mg/L		

M/s. Sachin Infra Environment Ltd., GIDC-Sachin, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
50	pH	Not Furnished	pH	6.5-8.5	Average value of November - 2018	40	Nil	pH	7.54	pH	7.33	pH, Flow Meter, TOC	Storage – 2000 MT
	COD	1000 mg/L	COD	250 mg/L				COD	704 mg/L	COD	231 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	197 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	1974 mg/L	SS	92 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	39 mg/L	NH ₃ -N	14 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.28 mg/L	Phenolic Compounds	0.44 mg/L		

M/s. Palsana Enviro Protection Ltd., (PEPL), Kadodara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of November – 2018	95	Nil	pH	6.97	pH	7.05	pH, Flow Meter, COD, BOD, TSS	Storage- 587 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1116 mg/L	COD	259 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	282 mg/L	BOD	26 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	232 mg/L	SS	34 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	38 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.28 mg/L	Phenolic Compounds	0.31 mg/L		

M/s. Pandesara Infrastructure Ltd., GIDC- Pandesara, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
100	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	88	Nil	pH	6.83	pH	6.89	pH, Flow Meter, TOC, COD	Storage – 1800 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1107 mg/L	COD	237 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	272 mg/L	BOD	24 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	338 mg/L	SS	60 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	40 mg/L	NH ₃ -N	17 mg/L		
	Phenolic Compounds	01 mg/L	Phenolic Compounds	01 mg/L				Phenolic Compounds	0.45 mg/L	Phenolic Compounds	0.31 mg/L		

M/s. Gujarat Eco Textile Park Pvt Ltd, Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
60	pH	6.5-8.5	pH	6.5 to 8.5	Average value of November – 2018	35	Nil	pH	7.08	pH	7.67	pH, Flow Meter, COD Meter including TOC	Storage – 350 MT Disposal - 104 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1189 mg/L	COD	196 mg/L		
	BOD	400 mg/L	BOD	100 mg/L				BOD	328 mg/L	BOD	23 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	242 mg/L	SS	98 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	35 mg/L	NH ₃ -N	19 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.26 mg/L	Phenolic Compounds	0.28 mg/L		

M/s. Fairdeal Textile Parks Pvt. Ltd, Kosamaba, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.25	pH	-	pH	6.5 to 8.5	No visit in the month of November – 2018	1.00	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	500 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	200 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	-	SS	<60 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. New Palsana Industrial Co. Op. Society Ltd., Palsana, Surat

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
45	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	22	Nil	pH	6.98	pH	7.37	pH, Flow meter, COD, BOD, TSS	Storage - 300 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1073 mg/L	COD	179 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	268 mg/L	BOD	20 mg/L		
	SS	300 mg/L	SS	<60 mg/L				SS	138 mg/L	SS	30 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	45 mg/L	NH ₃ -N	12 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.44 mg/L	Phenolic Compounds	0.20 mg/L		

M/s. Vapi Waste & Effluent Management Co. Ltd, Vapi

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
55	pH	6.5-8.5	0.	6.5-8.5	Average value of November - 2018	55	Nil	pH	7.76	pH	7.74	pH, Flow Meter, TOC & DO Meter	Storage – 13324 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1081 mg/L	COD	259 mg/L		
	BOD	400 mg/L	BOD	30 mg/L				BOD	279 mg/L	BOD	29 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	335 mg/L	SS	95 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	66 mg/L	NH ₃ -N	52 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	2.17 mg/L	Phenolic Compounds	0.565 mg/L		

M/s. Sarigam Clean Initiative (Old Name-Gujarat Industrial Development Corporation), Sarigam

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
12.5	pH	6.5-8.5	pH	6.5-8.5	Average value of November - 2018	8.5	Nil	pH	7.615	pH	8.195	Flow Meter, TOC meter	Storage – 675 MT
	COD	1000 mg/L	COD	250 mg/L				COD	1066 mg/L	COD	202 mg/L		
	BOD (3 days at 27°C)	400 mg/L	BOD (3 days at 27°C)	100 mg/L				BOD (3 days at 27°C)	2377 mg/L	BOD (3 days at 27°C)	24 mg/L		
	SS	300 mg/L	SS	100 mg/L				SS	306 mg/L	SS	73 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	54 mg/L	NH ₃ -N	16 mg/L		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	0.97 mg/L	Phenolic Compounds	0.23 mg/L		

M/s. Veraval Industries Association, Veraval, Junagadh

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
5	pH	5.5 to 9	pH	6 to 9	No visit in the month of November – 2018	1.5	Nil	pH	-	pH	-	-	-
	COD	3500 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD	1000 mg/L	BOD	100 mg/L				BOD	-	BOD	-		
	SS	200 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenol	-	Phenol	-				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Bhatgam Washing Ghat Suddhikaran Yojana Pvt. Ltd., Bhatgam, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
30	pH	10.5-12	pH	6.5-9	Average value of November - 2018	6.00	Nil	pH	10.90	pH	8.57	pH, Flow meter, SS, Color, MLSS, COD	Storage – 120 MT Disposal – 168.23 MT
	COD	1000 mg/L	COD	100 mg/L				COD	447 mg/L	COD	52 mg/L		
	BOD	350 mg/L	BOD	30 mg/L				BOD	50 mg/L	BOD	15 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	200 mg/L	SS	42 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	23 mg/L	NH ₃ -N	1 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jetpur Dyeing & Printing Association, Jetpur, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
10.00	pH	10.5-12.0	pH	6.5-8.5	Average value of November - 2018	7.00	Nil	pH	6.93	pH	7.44	pH, Flow meter	-
	COD	1000 mg/L	COD	250 mg/L				COD	892 mg/L	COD	208 mg/L		
	BOD	350 mg/L	BOD	100 mg/L				BOD	253 mg/L	BOD	45 mg/L		
	SS	2000 mg/L	SS	100 mg/L				SS	152 mg/L	SS	92 mg/L		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	28 mg/L	NH ₃ -N	9 mg/L		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Shri Dhareshwar GIDC Vistar Association, Dhareshwar, Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.09	pH	10.5-12	pH	6.5 to 9	No visit in the month of November – 2018	0.07	Nil	pH	-	pH	-	pH, Flow Meter	-
	COD	1000 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	350 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	2000 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	75 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	5 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Jay Khodiyar Enviro-Technologies Pvt. Ltd., Rajkot

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.025	pH	Up to 5	pH	6.5 to 8.5	No Visit in the month of November - 2018	0.007	Nil	pH	-	pH	-	-	-
	COD	250 mg/L	COD	100 mg/L				COD	-	COD	-		
	BOD	100 mg/L	BOD	30 mg/L				BOD	-	BOD	-		
	SS	250 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	-	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		

M/s. Kalol GIDC Industries Association, Kadi, Gandhinagar

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
0.40	pH	6.5 to 8.5	pH	6.5 to 8.5	Average value of November - 2018	0.35	Nil	pH	-	pH	7.01	-	Storage – 35 MT Disposal – 23.45 MT
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	360 mg/L		
	BOD	700 mg/L	BOD	100 mg/L				BOD	-	BOD	106 mg/L		
	SS	-	SS	100 mg/L				SS	-	SS	272 mg/L		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	8 mg/L		
	Phenolic Compounds	-	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	BDL		

M/s. MPSEZ Utilities (P) Limited, Mundra, Kutch

Capacity in (MLD)	Inlet Norms		Final Effluent Quality Stds. Or ZLD Conditions		Date of Monitoring	Waste Water treated in CETP (MLD)	Waste Water bypassed untreated in the area, if any (MLD)	Observed Inlet Quality		Observed Final Effluent Quality		Status of Online CEQMS	Status of Hazardous Waste Storage / Disposal
2.5	pH	6.5-8.5	pH	6.5-8.5	No Visit in the month of November - 2018	0.10	Nil	pH	-	pH	-	pH, COD, BOD, TSS, Ammonical Nitrogen	--
	COD	2000 mg/L	COD	250 mg/L				COD	-	COD	-		
	BOD (3 days at 27° C)	1000 mg/L	BOD(3 days at 27° C)	100 mg/L				BOD(3 days at 27° C)	-	BOD(3 days at 27° C)	-		
	SS	800 mg/L	SS	100 mg/L				SS	-	SS	-		
	NH ₃ -N	50 mg/L	NH ₃ -N	50 mg/L				NH ₃ -N	-	NH ₃ -N	-		
	Phenolic Compounds	1 mg/L	Phenolic Compounds	1 mg/L				Phenolic Compounds	-	Phenolic Compounds	-		